



Needham Risk Management Resource Group, LLC

Competence ▫ Ethics ▫ Integrity ▫ Results

January 6, 2017

Mr. Jeffrey P. Simons, Superintendent
East Greenbush Central School District
29 Englewood Avenue
East Greenbush, NY 12061

RE: Donald P. Sutherland Elementary Lead-in-Water Testing Results

Dear Mr. Simons,

Needham Risk Management has performed lead sample collection for all potable water sources in the East Greenbush Central School District according to the New York State Department of Health (NYSDOH) School Potable Water Testing and Standards. The samples were collected at all five elementary schools by the deadline of September 30, 2016, and at Howard L. Goff Middle School and Columbia High School by their deadline of October 31, 2016.

Listed below are the test results for Donald P. Sutherland Elementary School. Of the 70 samples taken, 9 were above the NYSDOH action level of 15 parts per billion. The District's analytical results have been reported to the Rensselaer County Department of Health, as required by the standard. Prior to returning any outlet to service, a confirmation sample will be performed to ensure the effectiveness of the corrective action that was taken.

If you have any questions, please do not hesitate to contact me.

Sincerely,

Michael Needham, CSP, CFPS, RES, CET
Safety & Health Consultant

Attachments

573 Columbia Turnpike, Suite 3
East Greenbush, NY 12061
Telephone: (518) 860-1758 Fax: (518) 860-1759
Email: team@theneedhamgroup.com
www.theneedhamgroup.com

Donald P. Sutherland Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
DPS-0-DW-1	Outside - Gym	Fountain	0.004
DPS-1-DW-2	Room 64	Fountain	0.007
DPS-1-DW-3	Room 65	Fountain	0.006
DPS-1-DW-4	Room 62	Fountain	0.008
DPS-1-DW-5	Room 63	Fountain	0.008
DPS-1-DW-6	Room 60	Fountain	0.014
DPS-1-DW-7	Room 61	Fountain	0.025
DPS-1-DW-8	Outside Gym by Room 61	Fountain	0.004
DPS-1-DW-9	Nurse Cold Faucet	Fountain	0.007
DPS-1-DW-12	Room 34	Fountain	0.011
DPS-1-DW-13	Room 35	Fountain	0.008
DPS-1-DW-14	Room 36	Fountain	0.012
DPS-1-DW-15	Room 37	Fountain	0.009
DPS-1-WC-16	Room 40	Fountain	0.002
DPS-1-WC-17	Room 44	Fountain	0.002
DPS-1-EC-18	Food Lab Cold	Sink	0.027
DPS-1-IM-20	Food Lab Ice Maker	Ice Maker	0.001
DPS-1-DW-21	Room 26	Fountain	0.006
DPS-1-KC-22	Kitchen Cold Faucet	Sink	<.001
DPS-1-FC-24	Faculty Room Cold Faucet	Sink	0.007
DPS-1-IM-26	Faculty Room Ice Maker	Ice Maker	0.004
DPS-1-DW-27	Outside Main Office	Fountain	0.008
DPS-1-DW-28	Music Room	Fountain	0.022
DPS-1-DW-29	Outside Library	Fountain	0.003
DPS-1-FC-30	Library Sink Cold	Sink	0.042
DPS-1-BF-31	Girls Room across/Library	Sink	<.001
DPS-1-BF-32	Girls Room across/Library	Sink	0.019
DPS-1-BF-33	Girls Room across/Library	Sink	0.012
DPS-1-BF-34	Girls Room across/Library	Sink	0.011
DPS-1-BF-35	Boys Room across/Music Rm	Sink	0.008
DPS-1-BF-36	Boys Room across/Music Rm	Sink	0.006
DPS-1-CF-38	Music Room Sink Left	Sink	0.013
DPS-1-CF-39	Music Room Sink Right	Sink	0.007
DPS-1-CF-40	Band Room Opposite Music Rm	Sink	0.014
DPS-1-CF-41	Conference Rm Main Entrance	Sink	0.012
DPS-1-CF-42	Room 26 Sink	Sink	0.014
DPS-1-CF-43	Room 26 Small Sink	Sink	0.013
DPS-1-CF-44	Room 29 Art Room Plastic Tub	Sink	0.017
DPS-1-CF-45	Room 29 Art Room SS Sink	Sink	0.033
DPS-1-CF-46	Room 40 Small Sink	Sink	0.002
DPS-1-CF-47	Room 40 Large Sink	Sink	0.002
DPS-1-CF-48	Room 41 Small	Sink	0.008
DPS-1-CF-49	Room 41 Large	Sink	0.006
DPS-1-CF-50	Room 42 Small	Sink	0.008

Donald P. Sutherland Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
DPS-1-CF-51	Room 42 Large	Sink	0.002
DPS-1-CF-52	Room 43 Small	Sink	0.005
DPS-1-CF-53	Room 43 Large	Sink	0.004
DPS-1-CF-54	Room 44 Small	Sink	0.005
DPS-1-CF-55	Room 44 Large	Sink	0.008
DPS-1-CF-56	Room 37 Small	Sink	0.003
DPS-1-CF-57	Room 37 Large	Sink	0.013
DPS-1-CF-58	Room 36 Small	Sink	0.005
DPS-1-CF-59	Room 36 Large	Sink	0.013
DPS-1-CF-60	Room 35 Small	Sink	0.002
DPS-1-CF-61	Room 35 Large	Sink	0.016
DPS-1-CF-62	Room 34 Small	Sink	0.009
DPS-1-CF-63	Room 34 Large	Sink	0.014
DPS-1-CF-64	Room 32 Sink	Sink	0.010
DPS-1-CF-65	Nurse's Bathroom Room 30	Sink	0.007
DPS-1-CF-66	Boys Room by Gym	Sink	0.031
DPS-1-CF-67	Girls Room by Gym	Sink	0.005
DPS-1-CF-68	Room 61 Sink	Sink	0.005
DPS-1-CF-69	Room 60 Sink	Sink	0.015
DPS-1-CF-70	Room 63 Sink	Sink	0.012
DPS-1-CF-71	Room 62 Sink	Sink	0.012
DPS-1-CF-72	Room 65 Sink	Sink	0.002
DPS-1-CF-73	Room 64 Sink	Sink	0.002
DPS-1-CF-74	Girls Locker Room Sink	Sink	0.004
DPS-1-CF-75	Boys Locker Room Sink	Sink	0.008
DPS-1-CF-76	Main Office Sink	Sink	0.007