



Needham Risk Management Resource Group, LLC

Competence ▫ Ethics ▫ Integrity ▫ Results

January 6, 2017

Mr. Jeffrey P. Simons, Superintendent
East Greenbush Central School District
29 Englewood Avenue
East Greenbush, NY 12061

RE: East Greenbush Central School District Lead-in-Water Testing Results

Dear Mr. Simons,

Needham Risk Management has performed lead sample collection for all potable water sources in the East Greenbush Central School District according to the New York State Department of Health (NYSDOH) School Potable Water Testing and Standards. The samples were collected at all five elementary schools by the deadline of September 30, 2016, and at Howard L. Goff Middle School and Columbia High School by their deadline of October 31, 2016.

Listed below are the test results for each school. Of the 796 samples taken, 102 were above the NYSDOH action level of 15 parts per billion. The District's analytical results have been reported to the Rensselaer County Department of Health, as required by the standard. Prior to returning any outlet to service, a confirmation sample will be performed to ensure the effectiveness of the corrective action that was taken.

If you have any questions, please do not hesitate to contact me.

Sincerely,

Michael Needham, CSP, CFPS, RES, CET
Safety & Health Consultant

Attachments

573 Columbia Turnpike, Suite 3
East Greenbush, NY 12061
Telephone: (518) 860-1758 Fax: (518) 860-1759
Email: team@theneedhamgroup.com
www.theneedhamgroup.com

Bell Top Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
BTE - 1 - KC - 1	Kitchen	Sink	<.001
BTE - 1 - KH - 2	Kitchen	Sink	<.001
BTE - 1 - KC - 3	Kitchen	Sink	<.001
BTE - 1 - KH - 4	Kitchen	Sink	<.001
BTE - 1 - FC - 1	Faculty Room	Sink	<.001
BTE - 1 - LC - 1	Food Lab	Sink	<.001
BTE - 1 - NS - 1	Health Office	Sink	<.001
BTE - 1 - NIM - 1	Health Office	Ice Maker	<.001
BTE - 1 - FIM - 3	Faculty Room	Ice Maker	0.001
BTE - 1 - DW-1	Rm 60 Drinking Water Bubbler	Fountain	0.002
BTE - 1 - DW-2	Rm 50 Drinking Water Bubbler	Fountain	0.002
BTE - 1 - DW-3	Rm 50 Drinking Water Bubbler	Fountain	0.002
BTE - 1 - DW-5	Rm 240 Drinking Water Bubbler	Fountain	0.030
BTE - 1 - DW-6	Rm 250 Drinking Water Bubbler	Fountain	0.001
BTE - 1 - DW-7	Rm 260 Drinking Water Bubbler	Fountain	0.003
BTE - 1 - DW-8	Rm 270 Drinking Water Bubbler	Fountain	<.001
BTE - 1 - DW-9	Rm 280 Drinking Water Bubbler	Fountain	0.004
BTE - 1 - DW-10	Rm 290 Drinking Water Bubbler	Fountain	0.002
BTE - 1 - DW-11	Rm 300 Drinking Water Bubbler	Fountain	<.001
BTE - 1 - DW-12	Rm 310 Drinking Water Bubbler	Fountain	0.001
BTE - 1 - DW-13	Rm 350 Drinking Water Bubbler	Fountain	0.002
BTE - 1 - DW-14	Rm 370 Drinking Water Bubbler	Fountain	0.001
BTE - 1 - DW-15	Hall by Library Water Bubbler	Fountain	0.003
BTE - 1 - CW-1	Water Cooler by Cafeteria	Fountain	0.002
BTE - 1 - CW-2	Kindergarten Wlg Water Cooler	Fountain	<.001
BTE - 1 - DW-16	North Side Gym Cooler	Fountain	<.001
BTE - 1 - DW-17	South Side Wdl Gym Cooler	Fountain	<.001
BTE-0-BC-1	Baker Room Sink	Sink	0.005
BTE-0-CF-1	Room 330	Sink	0.006
BTE-1-BF-1	Girls Gym	Sink	<.001
BTE-1-BF-2	Boys Gym	Sink	<.001
BTE-1-CF-2	Room 20 Sink Near Bathroom	Sink	<.001
BTE-1-CF-3	Room 20 Sink	Sink	<.001
BTE-1-CF-4	Room 30 Sink Near Bathroom	Sink	<.001
BTE-1-CF-5	Room 30 Sink	Sink	0.002
BTE-1-CF-6	Room 40 Sink Near Bathroom	Sink	0.012
BTE-1-CF-7	Room 40 Sink	Sink	<.001
BTE-1-CF-8	Room 50 Sink Near Bathroom	Sink	0.002
BTE-1-CF-9	Room 50 Sink	Sink	0.009
BTE-1-CF-10	Room 60 Sink Near Bathroom	Sink	0.002
BTE-1-CF-11	Room 60 Sink	Sink	0.008
BTE-1-CF-12	Room 70 Sink Near Bathroom	Sink	0.002
BTE-1-CF-13	Room 70 Sink	Sink	0.013
BTE-1-CF-14	Room 80 Sink Near Bathroom	Sink	0.002

Bell Top Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
BTE-1-CF-15	Room 80 Sink	Sink	0.010
BTE-1-CF-16	Room 90 Sink Near Bathroom	Sink	0.009
BTE-1-CF-17	Room 90 Sink	Sink	0.016
BTE-1-CF-18	Room 100 Sink	Sink	0.018
BTE-1-BF-3	Nurse Bathroom Room 110	Sink	<.001
BTE-0-BF-19	Room 120 Sink	Sink	0.008
BTE-0-BF-20	Room 120 Sink Near Bathroom	Sink	0.002
BTE-1-BF-4	Men's Room Main Office	Sink	0.007
BTE-1-BF-5	Women's Room Main Office	Sink	0.002
BTE-1-CF-21	Room 240 Sink	Sink	0.004
BTE-1-CF-22	Room 250 Sink	Sink	0.004
BTE-1-CF-23	Room 260 Sink	Sink	0.004
BTE-1-CF-24	Room 270 Sink	Sink	0.002
BTE-1-CF-25	Room 280 Sink	Sink	0.001
BTE-1-CF-26	Room 290 Sink	Sink	0.004
BTE-1-CF-27	Room 300 Sink	Sink	0.006
BTE-1-CF-28	Room 310 Sink	Sink	0.002
BTE-1-CF-29	Room 350 Sink	Sink	<.001
BTE-0-CF-30	Room 370 Bathroom	Sink	<.001
BTE-0-CF-31	Room 370 Print Sink	Sink	0.008
BTE-0-CF-32	Room 370 Sink	Sink	0.001
BTE-0-CF-33	Library Office Sink	Sink	0.017
BTE-0-BF-6	Library Boys Room Left	Sink	0.003
BTE-0-BF-7	Library Boys Room Right	Sink	0.003
BTE-0-BF-8	Library Girls Room Left	Sink	0.002
BTE-0-BF-9	Library Girls Room Right	Sink	<.001

Columbia High School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
CH - O - FC - 1	Custodial Break Room	Sink	<.001
CH - 1 - DW - 2	Athletic Hall of Fame	Fountain	<.001
CH - 1 - WC - 3	Weight Room Left	Fountain	<.001
CH - 1 - WC - 4	Weight Room Right	Fountain	<.001
CH - 1 - WC - 5	Outside Boys Locker Room Left	Fountain	<.001
CH - 1 - WC - 6	Outside Boys Locker Room Right	Fountain	<.001
CH - 1 - FC - 7	Athletic Training Room	Sink	<.001
CH - 1 - IC - 8	Ice Machine	Ice	<.001
CH - 1 - WC - 39	Outside Gym by Girls Locker Rm	Fountain	<.001
CH - 1 - WC - 40	Girls Locker Room Right	Fountain	<.001
CH - 1 - DW - 9	Gym A101A Left	Fountain	<.001
CH - 1 - DW - 10	Gym A101A Right	Fountain	<.001
CH - 1 - DW 12	Gym A10B Right	Fountain	<.001
CH - 1 - DW - 14	Gym A101C Right	Fountain	<.001
CH - 1 - EC - 15	Home Ec. Room C107	Sink	<.001
CH - 1 - EC - 16	Home Ec. Room C107	Sink	<.001
CH - 1 - EC - 17	Home Ec. Room C107	Sink	<.001
CH - 1 - EC - 18	Home Ec. Room C107	Sink	<.001
CH - 1 - EC - 19	Home Ec. Room C107	Sink	<.001
CH - 1 - FC - 20	N108 Faculty Lounge	Sink	<.001
CH - 1 - FC - 21	C105 - N. Office Guidance	Sink	<.001
CH - 1 - FC - 22	C101D - Main Office	Sink	<.001
CH - 1 - NC - 23	C102A - Nurse	Sink	<.001
CH - 1 - NC - 24	C102F - Nurse	Sink	<.001
CH - 1 - WC - 25	Elevator S113	Fountain	<.001
CH - 1 - WC - 26	Across Room S118	Fountain	<.001
CH - 3 - WC - 27	Outside Faculty Room S323	Fountain	>.001
CH - 3 - FC - 28	S323A Pantry	Sink	<.001
CH - 3 - WC - 29	Across from S310	Fountain	<.001
CH - 2 - WC - 30	Elevator S223	Fountain	<.001
CH - 2 - WC - 31	Across from S211	Fountain	<.001
CH - 2 - FC - 32	Faculty Room S222	Sink	<.001
CH - 2 - FC - 33	Library Room C201G	Sink	<.001
CH - 2 - WC - 34	Elevator N223	Fountain	<.001
CH - 2 - WC - 35	Across Room N211	Fountain	<.001
CH - 3 - WC - 36	Across Room N303	Fountain	<.001
CH - 3 - FC - 37	Faculty Room N323	Sink	<.001
CH - 3 - WC - 38	Across Room N310	Fountain	<.001
CH - 2 - FC - 41	Faculty Room N222	Sink	<.001
CH - 1 - KC - 42	Café Prep Sink left (in serving line)	Sink	.002
CH - 1 - KC - 43	Café Prep Right	Sink	.001
CH - 1 - IM - 44	Café Ice Maker	Ice	<.001
CH - 1 - KC - 45	Kitchen Prep Sink w/disposal	Sink	.006
CH - 1 - KC - 46	Braiser	Sink	<.001

Columbia High School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
CH - 1 - KC - 47	Sink Center	Sink	.002
CH - 1 - KC - 48	Sink Left	Sink	.001
CH - 1 - KC - 49	Concession cold	Sink	<.001
CH - 1 - DW - 50	Tennis Courts & Football sports	Fountain	<.001
CH - 1 - DW - 51	Fountain next to Concession	Fountain	<.001
CH - 1 - DW - 52	Fountain by Concession Handicap	Fountain	<.001
CH - 1 - BF - 1	Boy's by Stair 4 L	Sink	.003
CH - 1 - BF - 2	Boy's by Stair Mid.	Sink	<.001
CH - 1 - BF - 3	Boy's by Stair R	Sink	<.001
CH - 1 - BF - 4	Girl's by Stair by door	Sink	.002
CH - 1 - BF - 5	Girl's by Stair Mid.	Sink	.002
CH - 1 - BF - 6	Girl's by Stair Far	Sink	.002
CH - 1 - BF - 7	Gender Bath by A111 on Right	Sink	.019
CH - 1 - BF - 8	Gender Bath by A111 on Right	Sink	.002
CH - 1 - BF - 9	Gender Bath by A111 on Right	Sink	.015
CH - 1 - BF - 10	Gender Bath by A111 on Right	Sink	.010
CH - 1 - BF - 11	Gender Bath by A111 on Left	Sink	.013
BF - 1 - BF - 12	Gender Bath by A111 on Left	Sink	.002
CH - 1 - BF - 14	Gender Bath by A111 on Left	Sink	.008
CH - 1 - BF - 15	Girl's Locker Room L	Sink	.001
CH - 1 - BF - 16	Girl's Locker Room Mid	Sink	.001
CH - 1 - BF - 17	Girl's Locker Room R	Sink	.001
CH - 1 - BF - 19	Women's Athletic Office A107	Sink	.002
CH - 1 - BF - 20	Athletic Office by Lockers	Sink	.004
CH - 1 - BF - 21	Men's Athletic Office A106	Sink	.005
CH - 1 - BF - 22	Men's Athletic Office A106C by lockers	Sink	.003
CH - 1 - BF - 23	Boy's Locker Room Left	Sink	.004
CH - 1 - BF - 24	Boy's Locker Room Left	Sink	.004
CH - 1 - BF - 25	Boy's Locker Room Left	Sink	.002
CH - 1 - BF - 26	Boy's Locker Room Right	Sink	.001
CH - 1 - CF - 27	Band Left Room P112	Sink	.002
CH - 1 - CF - 28	Band Right Room	Sink	.002
CH - 1 - BF - 29	Stage Bathroom	Sink	.009
CH - 1 - BF - 30	Team Room Left	Sink	<.001
CH - 0 - BF - 31	Team Room Right	Sink	<.001
CH - 1 - BF - 32	Handicap Girls by Aud.	Sink	.002
CH - 1 - BF - 33	Handicap Boys by Aud.	Sink	.004
CH - 1 - BF - 34	Gender Bathroom Right Side by Aud.	Sink	.002
CH - 1 - BF - 35	Gender Bathroom Right Side by Aud.	Sink	.001
CH - 1 - BF - 36	Gender Bathroom Right Side by Aud.	Sink	.003
CH - 1 - BF - 37	Gender Bathroom Left Side by Aud.	Sink	.002
CH - 1 - BF - 38	Gender Bathroom Left Side by Aud.	Sink	.002
CH - 1 - BF - 39	Gender Bathroom Left Side by Aud.	Sink	.003
CH - 1 - BF - 40	Boy's Bathroom West Lobby Left	Sink	.003

Columbia High School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
CH - 1 - BF - 41	Boy's Bathroom West Lobby Left	Sink	.002
CH - 1 - BF - 42	Boy's Bathroom West Lobby Right	Sink	.001
CH - 1 - BF - 43	Girl's Bathroom West Lobby Left	Sink	.002
CH - 1 - BF - 44	Girl's Bathroom West Lobby Mid	Sink	.002
CH - 1 - BF - 45	Girl's Bathroom West Lobby Right	Sink	.002
CH - 1 - CF - 46	C112 Dark Room	Sink	.001
CH - 1 - CF - 47	C112 Dark Room	Sink	.002
CH - 1 - CF - 48	C113 Art Room Left	Sink	<.001
CH - 1 - CF - 49	C113 Art Room Right	Sink	.001
CH - 1 - CF - 50	C114 Art Room Left	Sink	.001
CH - 1 - CF - 51	C114 Art Room Right	Sink	.002
CH - 1 - CF - 52	N115 Career & Tech Ed. Office	Sink	.007
CH - 1 - CF - 53	N107 Shop Metal	Sink	<.001
CH - 1 - CF - 54	N106 Wood Shop	Sink	<.001
CH - 1 - CF - 55	N106 Varnish Room	Sink	.007
CH - 1 - CF - 56	107A Wood Shop Mechanical	Sink	.007
CH - 1 - BF - 57	N108 Men's Faculty	Sink	.003
CH - 1 - BF -- 58	N108 Women's	Sink	.001
CH - 1 0 BF - 59	C105 - N. Office Men's	Sink	.004
CH - 1 - BF - 60	C105 - N. Office Women's	Sink	.001
CH - 1 - BF - 61	Main Office Bathroom Men's	Sink	.001
CH - 1 - BF - 62	Main Office Bathroom Women's	Sink	<.001
CH - 1 - BF - 63	C102 Health Office Boys	Sink	.003
CH - 1 - BF - 64	C102 Health Office Girls	Sink	.002
CH - 1 - BF - 65	S102 Girls Bath Across L	Sink	.002
CH - 1 - BF - 66	S102 Girls Bath Across R	Sink	.002
CH - 1 - BF - 67	S118 Boys Bath Across L	Sink	.003
CH - 1 - BF - 68	S118 Boys Bath Across R	Sink	.003
CH - 3 - BF - 69	S304 Women's Across L	Sink	.005
CH - 3 - BF - 70	S304 Women's Across R	Sink	.002
CH - 3 - BF - 71	S311 Boy's Across L	Sink	.002
CH -3 - BF - 72	S311 Boy's Across R	Sink	.002
CH - 3 - BF - 73	S312 Gender Bath Across L	Sink	.002
CH - 3 - BF - 74	S312 Gender Bath Across R	Sink	.004
CH - 2 - BF - 75	S205 Girls Room Across L	Sink	<.001
CH - 2 - BF - 76	S205 Girls Room Across R	Sink	.002
CH - 2 - BF - 77	S212 Boys Bath L	Sink	.001
CH - 2 - BF - 78	S212 Boys Bath R	Sink	.002
CH - 2 - CF - 80	Science Room S213 Back L	Sink	.006
CH - 2 - CF - 81	Science Room S213 Back R	Sink	.001
CH - 2 - CF - 82	Science Room S213 Left on Right Wall	Sink	.009
CH - 2 - CF - 83	Science Room S213 Right on Right Wall	Sink	.002
CH - 2 - CF - 84	S213A Prep Room	Sink	.003
CH - 2 - CF - 85	S214 Left	Sink	.027

Columbia High School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
CH - 2 - CF - 86	S214	Sink	.011
CH - 2 - CF - 87	S214	Sink	.004
CH - 2 - CF - 88	S214 Right	Sink	.006
CH - 2 - CF - 89	Science S215 L	Sink	.019
CH - 2 - CF - 90	Science S215	Sink	.002
CH - 2 - CF - 91	Science S215	Sink	<.001
CH - 2 - CF - 92	Science S202 Left	Sink	.008
CH - 2 - CF - 93	Science S202 Left	Sink	.010
CH - 2 - CF - 94	Science S202 Left	Sink	.031
CH - 2 - CF - 96	Science S202 Left	Sink	.008
CH - 2 - CF - 97	Science S202 Left	Sink	.022
CH - 2 - CF - 98	Science S202 Right	Sink	.022
CH - 2 - CF - 99	ScienceS201A Prep	Sink	<.001
CH - 2 - CF - 100	Science S201 L	Sink	.004
CH - 2 - CF - 101	Science S201 L	Sink	.008
CH - 2 - CF - 102	Science S201 L	Sink	.004
CH - 2 - CF - 103	Science S201 L	Sink	.006
CH - 2 - CF - 104	Science S201 L	Sink	.009
CH - 2 - CF - 105	Science S201 Right	Sink	.011
CH - 2 - BF - 106	Library - Men's	Sink	.004
CH - 2 - BF - 107	Library - Women's	Sink	.002
CH - 2 - CF - 108	Science C214 - Left	Sink	.038
CH - 2 - CF - 109	Science C214 - Teacher	Sink	.043
CH - 2 - CF - 110	Science C214 - Right	Sink	.034
CH - 2 - CF - 111	Science C213 - By Door	Sink	.010
CH - 2 - CF - 112	Science C213 - Middle	Sink	.003
CH - 2 - CF - 113	Science C213 - 3rd Bench	Sink	.005
CH - 2 - CF - 114	Science C213 - Side	Sink	.003
CH - 2 - CF - 115	C212 - Left (by Window)	Sink	.004
CH - 2 - CF - 116	C212 - Right	Sink	.002
CH - 2 - BF - 117	C212 - Boys Room - L	Sink	.002
CH - 2 - BF - 118	C212 - Boys Room -Mid.	Sink	.004
CH - 2 - BF - 119	C212 - Boys Room - R	Sink	.002
CH - 2 - BF - 120	Girls by C212 - L	Sink	.002
CH - 2 - BF - 121	Girls by C212 - Mid.	Sink	.002
CH - 2 - BF - 122	Girls by C212 - R	Sink	.002
CH - 2 - CF - 123	Science C209 Prep Room	Sink	.006
CH - 2 - CF - 124	Science C208 - Left	Sink	.004
CH - 2 - CF - 125	Science C208 - Teacher	Sink	.003
CH - 2 - CF - 126	Science C208 - by Window	Sink	.003
CH - 2 - CF - 127	Science C207 - by left door	Sink	<.001
CH - 2 - CF - 128	Science C207 1st Island	Sink	<.001
CH - 2 - CF - 129	Science C207 Mid Island	Sink	.002
CH - 2 - CF - 130	Science C207 3rd Island	Sink	.001

Columbia High School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
CH - 2 - CF - 131	Science C207 by Window	Sink	.001
CH - 2 - CF - 132	Science C206 Teacher	Sink	.027
CH - 2 - CF - 133	Science C206 - Right	Sink	.006
CH - 2 - CF - 134	Science C206 - Window	Sink	.002
CH - 2 - CF - 135	Science N201 Teacher	Sink	.023
CH - 2 - CF - 136	Science N201 - Window R	Sink	.001
CH - 2 - CF - 137	Science N201 - Window L	Sink	.003
CH - 2 - CF - 138	Science N201 - Back R	Sink	.003
CH - 2 - CF - 139	Science N201 - Back L	Sink	.003
CH - 2 - CF - 141	Science N201 - Left Wall - Left	Sink	.002
CH - 2 - CF - 142	Science N201A Prep	Sink	.004
CH - 2 - CF - 143	Science N202 - Teacher	Sink	.016
CH - 2 - CF - 144	Science N202 - L Window	Sink	.004
CH - 2 - CF - 145	Science N202 - R Window	Sink	.010
CH - 2 - CF - 146	Science N202 - L - Back Wall	Sink	.014
CH - 2 - CF - 147	Science N202 - R - Back Wall	Sink	.023
CH - 2 - CF - 148	Science N202 - L - Right Wall	Sink	.038
CH - 2 - CF - 149	Science N202 - R - Right Wall	Sink	.053
CH - 2 - BF - 150	Girls Room by N205 - L	Sink	.002
CH - 2 - BF - 151	Girls Room by N205 - R	Sink	<.001
CH - 2 - BF - 152	Boys Room By N212 - L	Sink	.002
CH - 2 - BF - 153	Boys Room By N212 -R	Sink	<.001
CH - 3 - BF - 154	Boys Room - North - L	Sink	.001
CH - 3 - BF - 155	Boys Room - North -R	Sink	<.001
CH - 3 - BF - 156	Girls Room N304 - R	Sink	<.001
CH - 3 - BF - 157	Girls Room N304 - L	Sink	<.001
CH - 3 - BF - 158	Faculty Bath - North Forum - L	Sink	<.001
CH - 3 - BF - 159	Faculty Bath - North Forum -R	Sink	.003
CH - 2 - CF - 160	Science N216 - Left	Sink	.006
CH - 2 - CF - 162	Science N216 - Right	Sink	.051
CH - 2 - CF - 163	Science N209 - Health L	Sink	.004
CH - 2 - CF - 164	Science N209 - Health R	Sink	.012
CH - 2 - CF - 165	Science N214 Wall - L	Sink	.005
CH - 2 - CF - 166	Science N214 Wall -R	Sink	.004
CH - 2 - CF - 167	Science N214 Window - L	Sink	.008
CH - 2 - CF - 168	Science N214 Window - R	Sink	.008
CH - 2 - CF - 169	Science N214 A - Prep	Sink	.007
CH - 2 - CF - 170	Science Room N215 - Window - L	Sink	.007
CH - 2 - CF - 171	Science Room N215 - Window -R	Sink	.008
CH - 2 - CF - 172	Science Room N215 - Wall - L	Sink	.014
CH - 2 - CF - 173	Science Room N215 - Wall - R	Sink	.014

Donald P. Sutherland Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
DPS-0-DW-1	Outside - Gym	Fountain	0.004
DPS-1-DW-2	Room 64	Fountain	0.007
DPS-1-DW-3	Room 65	Fountain	0.006
DPS-1-DW-4	Room 62	Fountain	0.008
DPS-1-DW-5	Room 63	Fountain	0.008
DPS-1-DW-6	Room 60	Fountain	0.014
DPS-1-DW-7	Room 61	Fountain	0.025
DPS-1-DW-8	Outside Gym by Room 61	Fountain	0.004
DPS-1-DW-9	Nurse Cold Faucet	Fountain	0.007
DPS-1-DW-12	Room 34	Fountain	0.011
DPS-1-DW-13	Room 35	Fountain	0.008
DPS-1-DW-14	Room 36	Fountain	0.012
DPS-1-DW-15	Room 37	Fountain	0.009
DPS-1-WC-16	Room 40	Fountain	0.002
DPS-1-WC-17	Room 44	Fountain	0.002
DPS-1-EC-18	Food Lab Cold	Sink	0.027
DPS-1-IM-20	Food Lab Ice Maker	Ice Maker	0.001
DPS-1-DW-21	Room 26	Fountain	0.006
DPS-1-KC-22	Kitchen Cold Faucet	Sink	<.001
DPS-1-FC-24	Faculty Room Cold Faucet	Sink	0.007
DPS-1-IM-26	Faculty Room Ice Maker	Ice Maker	0.004
DPS-1-DW-27	Outside Main Office	Fountain	0.008
DPS-1-DW-28	Music Room	Fountain	0.022
DPS-1-DW-29	Outside Library	Fountain	0.003
DPS-1-FC-30	Library Sink Cold	Sink	0.042
DPS-1-BF-31	Girls Room across/Library	Sink	<.001
DPS-1-BF-32	Girls Room across/Library	Sink	0.019
DPS-1-BF-33	Girls Room across/Library	Sink	0.012
DPS-1-BF-34	Girls Room across/Library	Sink	0.011
DPS-1-BF-35	Boys Room across/Music Rm	Sink	0.008
DPS-1-BF-36	Boys Room across/Music Rm	Sink	0.006
DPS-1-CF-38	Music Room Sink Left	Sink	0.013
DPS-1-CF-39	Music Room Sink Right	Sink	0.007
DPS-1-CF-40	Band Room Opposite Music Rm	Sink	0.014
DPS-1-CF-41	Conference Rm Main Entrance	Sink	0.012
DPS-1-CF-42	Room 26 Sink	Sink	0.014
DPS-1-CF-43	Room 26 Small Sink	Sink	0.013
DPS-1-CF-44	Room 29 Art Room Plastic Tub	Sink	0.017
DPS-1-CF-45	Room 29 Art Room SS Sink	Sink	0.033
DPS-1-CF-46	Room 40 Small Sink	Sink	0.002
DPS-1-CF-47	Room 40 Large Sink	Sink	0.002
DPS-1-CF-48	Room 41 Small	Sink	0.008
DPS-1-CF-49	Room 41 Large	Sink	0.006
DPS-1-CF-50	Room 42 Small	Sink	0.008

Donald P. Sutherland Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
DPS-1-CF-51	Room 42 Large	Sink	0.002
DPS-1-CF-52	Room 43 Small	Sink	0.005
DPS-1-CF-53	Room 43 Large	Sink	0.004
DPS-1-CF-54	Room 44 Small	Sink	0.005
DPS-1-CF-55	Room 44 Large	Sink	0.008
DPS-1-CF-56	Room 37 Small	Sink	0.003
DPS-1-CF-57	Room 37 Large	Sink	0.013
DPS-1-CF-58	Room 36 Small	Sink	0.005
DPS-1-CF-59	Room 36 Large	Sink	0.013
DPS-1-CF-60	Room 35 Small	Sink	0.002
DPS-1-CF-61	Room 35 Large	Sink	0.016
DPS-1-CF-62	Room 34 Small	Sink	0.009
DPS-1-CF-63	Room 34 Large	Sink	0.014
DPS-1-CF-64	Room 32 Sink	Sink	0.010
DPS-1-CF-65	Nurse's Bathroom Room 30	Sink	0.007
DPS-1-CF-66	Boys Room by Gym	Sink	0.031
DPS-1-CF-67	Girls Room by Gym	Sink	0.005
DPS-1-CF-68	Room 61 Sink	Sink	0.005
DPS-1-CF-69	Room 60 Sink	Sink	0.015
DPS-1-CF-70	Room 63 Sink	Sink	0.012
DPS-1-CF-71	Room 62 Sink	Sink	0.012
DPS-1-CF-72	Room 65 Sink	Sink	0.002
DPS-1-CF-73	Room 64 Sink	Sink	0.002
DPS-1-CF-74	Girls Locker Room Sink	Sink	0.004
DPS-1-CF-75	Boys Locker Room Sink	Sink	0.008
DPS-1-CF-76	Main Office Sink	Sink	0.007

Citizen Genet Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GE-1-FC-1	Admin Kitchen Cold	Sink	<.001
GE-1-IM-2	Admin Kitchen Ice	Ice	<.001
GE-2-DW-3	Outside Admin Conf Rm 413	Fountain	0.027
GE-2-FC-4	Admin 2nd Floor Ladies RM	Sink	<.001
GE-2-DW-6	Outside Room 226	Fountain	0.002
GE-2-FC-7	Staff Room 226 Sink Cold	Sink	<.001
GE-2-DW-8	Outside Room 244	Fountain	0.018
GE-2-DW-9	Outside Library	Fountain	0.002
GE-1-WC-10	Cafeteria	Fountain	0.002
GE-1-DW-11	Across from Room 123	Fountain	0.004
GE-1-FC-13	Keurig Line Room 117	Sink	0.002
GE-1-IM-14	Room 117 Ice Maker	Ice	<.001
GE-1-DW-15	Across from Main Office	Fountain	0.002
GE-1-DW-16	Back of Gym-Stairwell	Fountain	0.004
GE-1-DW-17	Gym other side	Fountain	0.012
GE-1-EC-18	Food Lab	Sink	<.001
GE - 1-DW-20	Near Room 176	Fountain	0.059
GE - 1-NC-22	Nurse Bathroom Cold	Sink	<.001
GE -1-KC-24	Kitchen Prep near door	Sink	<.001
GE -1-KC-25	Kitchen Large Sink Left	Sink	<.001
GE -1-KC-26	Kitchen Large Sink Right	Sink	0.002
GE -1-KC-27	Kitchen Sink near office	Sink	<.001
GE-2-DW-5	Near Room 209	Fountain	0.005
GE-1-FC-12	Staff Room 117	Sink	<.001
GE-1-DW-21	Outside Room 115	Fountain	0.010
GE-1-FC-23	Main Office	Sink	<.001
GE-1-BF-28	Girls next to Room 149	Sink	0.003
GE-1-BF-29	Girls next to Room 149	Sink	0.003
GE-1-BF-30	Men's Room Main Lobby	Sink	0.009
GE-1-BF-31	Men's Room Main Lobby	Sink	0.007
GE-1-BF-32	Women's across from 114	Sink	0.002
GE-1-BF-33	Women's across from 114	Sink	0.006
GE-1-BF-34	Women's across from 114	Sink	0.014
GE-1-BF-35	Boys Room by Room 112	Sink	0.002
GE-1-BF-36	Boys Room by Room 112	Sink	0.003
GE-1-BF-37	Back of stage by Room 103	Sink	0.010
GE-1-CF-38	ART Room	Sink	<.001
GE-1-CF-39	ART Room	Sink	<.001
GE-1-CF-40	Room 125	Sink	<.001
GE-1-CF-41	Room 128	Sink	0.001
GE-1-CF-42	Room 126	Sink	0.001
GE-1-CF-43	Room 149	Sink	0.005
GE-1-CF-44	Health Office Bathroom Sink	Sink	<.001
GE-1-CF-45	Room 171 small	Sink	0.003

Citizen Genet Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GE-1-CF-46	Room 171 large	Sink	<.001
GE-1-CF-47	Room 174 small	Sink	<.001
GE-1-CF-48	Room 174 large	Sink	0.001
GE-1-BF-49	Room 177 Bathroom Sink	Sink	0.037
GE-1-CF-50	Room 177 Classroom Sink	Sink	<.001
GE-1-CF-51	Room 179 small	Sink	<.001
GE-1-CF-52	Room 179 large	Sink	0.005
GE-1-CF-53	Room 178 Small	Sink	<.001
GE-1-CF-54	Room 178 Large	Sink	0.006
GE-1-CF-55	Room 176 Small	Sink	<.001
GE-1-CF-56	Room 176 large	Sink	0.001
GE-2-CF-57	Room 227	Sink	<.001
GE-2-CF-58	Room 229	Sink	<.001
GE-2-BF-59	Room 231 bathroom sink	Sink	0.006
GE-2-CF-60	Room 231 Classroom sink	Sink	<.001
GE-2-BF-61	Room 241 Science Lab	Sink	<.001
GE-2-BF-62	Girls bathroom next Room 241	Sink	0.002
GE-2-BF-63	Girls bathroom next Room 241	Sink	0.001
GE-2-CF-64	Room 245	Sink	<.001
GE-2-CF-65	Room 248	Sink	0.001
GE-2-CF-66	Room 246	Sink	<.001
GE-2-CF-67	Room 244	Sink	0.001
GE-2-CF-68	Room 242	Sink	0.002
GE-2-BF-69	Boys Bathroom next to RM 242	Sink	0.002
GE-2-BF-70	Boys Bathroom next to RM 242	Sink	0.002
GE-2-CF-71	Room 238	Sink	0.002
GE-2-CF-72	Room 234	Sink	0.001
GE-2-CF-73	Room 214	Sink	0.003
GE-2-CF-74	Room 216	Sink	0.001
GE-2-CF-75	Room 218	Sink	0.004
GE-2-CF-76	Room 220	Sink	0.001
GE-2-CF-77	Room 217	Sink	<.001
GE-2-CF-78	Room 209	Sink	<.001
GE-2-BF-79	Boys Bathroom by RM 205	Sink	0.011
GE-2-BF-80	Boys Bathroom by RM 205	Sink	0.001
GE-2-BF-81	Boys Bathroom by RM 205	Sink	0.002
GE-2-CF-82	Room 205	Sink	0.002
GE-2-CF-83	Room 203	Sink	<.001
GE-2-CF-84	Room 201	Sink	0.045
GE-2-BF-85	Girls Room next to Room 204	Sink	0.004
GE-2-BF-86	Girls Room next to Room 204	Sink	0.005
GE-2-BF-87	Girls Room next to Room 204	Sink	0.007
GE-2-CF-88	Room 200	Sink	<.001
GE-2-BF-89	Admin Men's Room	Sink	0.006

Citizen Genet Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GE-2-BF-90	Women's Rm Admin next to 307	Sink	0.002
GE-2-BF-91	Men's Rm Admin next to 307	Sink	<.001
GE-2-BF-92	Girls bathroom next Room 100	Sink	0.005
GE-2-BF-93	Girls bathroom next Room 100	Sink	0.002
GE-2-BF-94	Girls bathroom next Room 100	Sink	0.010

Howard L. Goff Middle School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GM - 1 WC - 5	Gym - middle	Fountain	<.001
GM - 1 - NC - 11	Nurse	Sink	<.001
GM - 1 - WC - 12	Cafeteria	Fountain	.002
GM - 1 - KC - 14	Kitchen	Sink	<.001
GM - 1 - KC - 15	Kitchen	Sink	<.001
GM - 1 - KC - 16	Kitchen	Sink	.002
GM - 1 - WC - 1	Main Lobby	Fountain	<.001
GM - 1 - WC - 2	Green House	Fountain	.021
GM - 1 - WC - 3	Library Hall	Fountain	<.001
GM - 1 - WC - 7	Red House	Fountain	<.001
GM - 1 - WC - 8	Music (outside 151)	Fountain	<.001
GM - 1 - WC - 9	Blue House	Fountain	<.001
GM - 1 - FC - 10	Main Office	Fountain	.002
GM - 1 - ICE - 13	Ice Machine	Ice	<.001
GM - 2 - WC - 17	Blue House	Fountain	<.001
GM - 2 - WC - 18	Green House	Fountain	.021
GM - 2 - WC - 19	Between Rm 217-219	Fountain	<.001
GM - 2 - EC - 20	Home Ec Room	Sink	<.001
GM - 2 - EC - 21	Home Ec Room	Sink	.007
DM - 2 - EC - 22	Home Ec Room	Sink	<.001
GM - 2 - EC - 23	Home Ec Room	Sink	<.001
GM - 2 - EC - 24	Home Ec Room	Sink	.005
GM - 1 - CF - 1	Guidance - Green House	Sink	.003
GM - 1 - BF - 2	Boys Room - Green House	Sink	.003
GM - 1 - BF - 3	Boys Room - Green House	Sink	.002
GM - 1 - BF - 4	Boys Room - Green House	Sink	.002
GM - 1 - BF - 5	Boys Room - Green House	Sink	.002
GM - 1 - BF - 6	Girls Bathroom - Green House	Sink	.002
GM - 1 - BF - 7	Girls Bathroom - Green House	Sink	.002
GM - 1 - BF - 8	Girls Bathroom - Green House	Sink	.002
GM - 1 - BF - 9	Girls Bathroom - Green House	Sink	.006
GM - 1 - CF - 10	Science Room 109	Sink	.011
GM - 1 - CF - 11	Science Room 109	Sink	.015
GM - 1 - CF - 12	Science Room 109	Sink	.009
GM - 1 - CF - 13	Science Room 109	Teacher	.040
GM - 1 - CF - 14	Science Office 109	Sink	.049
GM - 1 - BF - 15	Main Office Bathroom	Sink	.002
GM - 1 - CF - 16	Main Office - Kitchen	Sink	.003
GM - 1 - BF - 17	Staff Room Men's Room	Sink	.003
GM - 1 - BF - 18	Staff Room Ladies Room	Sink	.004
GM - 1 - BF - 19	Staff Room Ladies Room	Sink	.002
GM - 1 - BF - 20	Girls Room - Main Hall	Sink	.005
GM - 1 - BF - 21	Boys Room across from kitchen	Sink	.001
GM - 1 - BF - 22	Boys Room across from kitchen	Sink	.006

Howard L. Goff Middle School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GM - 1 - BF - 24	Kitchen Bath	Sink	.001
GM - 1 - KF - 25	Kitchen Hand Wash	Sink	<.001
GM - 1 - BF - 26	Girls Locker Room	Sink	.002
GM - 1 - BF - 27	Girls Locker Room	Sink	.002
GM - 1 - BF - 28	Coaches Room (179)	Sink	.002
GM - 1 - BF - 29	Boys Locker Room	Sink	.003
GM - 1 - BF - 31	Coaches Room (Boys)	Sink	.002
GM - 1 - CF - 32	Music/Band Room	Sink	.002
GM - 1 - CF - 33	Music/Band Room	Sink	.002
GM - 1 - BF - 34	Blue House Girls Room	Sink	.004
GM - 1 - BF - 35	Blue House Girls Room	Sink	.001
GM - 1 - BF - 36	Blue House Girls Room	Sink	.005
GM - 1 - BF - 37	Blue House Girls Room	Sink	.002
GM - 1 - BF - 38	Blue House Boys Room	Sink	.004
GM - 1 - BF - 39	Blue House Boys Room	Sink	.006
GM - 1 - BF - 40	Blue House Boys Room	Sink	.002
GM - 1 - BF - 41	Blue House Boys Room	Sink	.002
GM - 1 - BF - 42	Taylor House Office	Sink	.002
GM - 1 - CF - 43	Science Room 167	Sink	.016
GM - 1 - CF - 44	Science Room 167	Sink	.013
GM - 1 - CF - 45	Science Room 167	Sink	.008
GM - 1 - CF - 46	Science Room 167	Sink	.010
GM - 1 - CF - 47	Science Office 167	Sink	.004
GM - 2 - BF - 48	Blue House Girls Room	Sink	.002
GM - 2 - BF - 49	Blue House Girls Room	Sink	.001
GM - 2 - BF - 50	Blue House Girls Room	Sink	.001
GM - 2 - BF - 51	Blue House Girls Room	Sink	.002
GM - 2 - BF - 52	Blue House Boys Room	Sink	<.001
GM - 2 - BF - 53	Blue House Boys Room	Sink	.003
GM - 2 - BF - 54	Blue House Boys Room	Sink	.005
GM - 2 - BF - 55	Blue House Boys Room	Sink	.003
GM - 2 - CF - 56	Science Room 267	Sink	.010
GM - 2 - CF - 57	Science Room 267	Sink	.009
GM - 2 - CF - 58	Science Room 267	Sink	.006
GM - 2 - CF - 59	Science 267 Teacher Station	Sink	.006
GM - 2 - CF - 60	Science 267 Office	Sink	.004
GM - 2 - CF - 61	Science Room 273	Sink	.024
GM - 2 - CF - 62	Science Room 273	Sink	.006
GM - 2 - CF - 63	Science Room 273	Sink	.008
GM - 1 - CF - 65	Tech. Room - 142-144	Sink	.002
GM - 1 - CF - 66	Tech. Room - 142-144	Sink	.002
GM - 1 - CF - 67	Tech. Room - 142-144	Sink	.003
GM - 1 - CF - 68	Tech. Room - 146-148	Sink	.003
GM - 1 - CF - 69	Tech. Room - 146-148	Sink	.003

Howard L. Goff Middle School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GM - 1 - CF - 70	Tech. Room - 146-148	Sink	.009
GM - 1 - BF - 71	Red House - Office	Sink	.001
GM - 1 - BF - 73	Red House - Girls	Sink	.002
GM - 1 - BF - 74	Red House - Girls	Sink	.002
GM - 1 - BF - 75	Red House - Girls	Sink	<.001
GM - 1 - BF - 76	Red House - Boys	Sink	<.001
GM - 1 - BF - 77	Red House - Boys	Sink	.002
GM - 1 - BF - 78	Red House - Boys	Sink	<.001
GM - 1 - BF - 79	Red House - large	Sink	.003
GM - 1 - CF - 80	Science Room 131	Sink	.012
GM - 1 - CF - 81	Science Room 131	Sink	.021
GM - 1 - CF - 82	Science Room 131	Sink	.013
GM - 1 - CF - 84	Science Office 131	Sink	.013
GM - 1 - CF - 85	Room 132 - Questar by door	Sink	.003
GM - 2 - BF - 86	Red House - Boys	Sink	.001
GM - 2 - BF - 87	Red House - Boys	Sink	.002
GM - 2 - BF - 88	Red House - Boys	Sink	.003
GM - 2 - BF - 89	Red House - Boys - Far	Sink	.023
GM - 2 - BF - 90	Red House - Girls	Sink	<.001
GM - 2 - BF - 91	Red House - Girls	Sink	.002
GM - 2 - BF - 92	Red House - Girls	Sink	.002
GM - 2 - BF - 93	Red House - Girls	Sink	.002
GM - 2 - CF - 94	Science Room 231	Sink	.015
GM - 2 - CF - 95	Science Room 231	Sink	.049
GM - 2 - CF - 96	Science Room 231	Sink	.018
GM - 2 - CF - 97	Science 231 Teacher Station	Sink	.019
GM - 2 - CF - 98	Science Room 235	Sink	.017
GM - 2 - CF - 99	Science Room 235	Sink	.030
GM - 2 - CF - 100	Science Room 235	Sink	.007
GM - 2 - CF - 101	Room 236	Sink	.039
GM - 2 - CF - 102	Room 221	Sink	.003
GM - 2 - CF - 103	Room 212 - Art	Sink	.003
GM - 2 - CF - 104	Room 212 - Art	Sink	.003
GM - 2 - CF - 105	Room 208 - Art	Sink	<.001
GM - 2 - CF - 106	Room 208 - Art	Sink	<.001
GM - 2 - BF - 107	Boys Bath - Green House	Sink	.001
GM - 2 - BF - 108	Boys Bath - Green House	Sink	.001
GM - 2 - BF - 109	Boys Bath - Green House	Sink	.001
GM - 2 - BF - 110	Boys Bath - Green House	Sink	.002
GM - 2 - CF - 111	Room 211	Sink	.073
GM - 2 - BF - 112	Girls Room - Green House	Sink	<.001
GM - 2 - BF - 113	Girls Room - Green House	Sink	.001
GM - 2 - BF - 114	Girls Room - Green House	Sink	<.001
GM - 2 - BF - 115	Girls Room - Green House	Sink	.004

Howard L. Goff Middle School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GM - 2 - CF - 116	Science Room 209	Sink	.017
GM - 2 - CF - 117	Science Room 209	Sink	.020
GM - 2 - CF - 118	Science Room 209	Sink	.32
GM - 2 - CF - 119	Science 209 Teacher Station	Sink	.043
GM - 2 - CF - 120	Science 209 Office	Sink	.027
GM - 2 - CF - 121	Science Room 203	Sink	.008
GM - 2 - CF - 122	Science Room 203	Sink	.017
GM - 2 - CF - 123	Science Room 203 Window	Sink	.097
GM - 2 - CF - 124	Science 203 Teacher Station	Sink	.008
GM - 2 - CF - 125	Science 203 Office	Sink	.007
GM - 1 - CF - 126	Library	Sink	<.001

Green Meadow Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GME-1-DW-1	Room 7	Fountain	0.008
GME-1-DW-2	Room 9	Fountain	0.021
GME-1-DW-3	Room 8	Fountain	0.016
GME-1-DW-4	Room 11	Fountain	0.017
GME-1-DW-5	Room 10	Fountain	0.004
GME-1-DW-6	Room 10	Fountain	0.008
GME-1-NC-7	Nurse Cold	Fountain	0.001
GME-1-DW-8	Outside Gym Near Office	Fountain	0.005
GME-1-DW-9	Outside Gym Near Storage	Fountain	0.002
GME-1-FC-10	Faculty Room 111	Sink	0.003
GME-1-KC-11	Prep Kitchen Cold	Sink	0.004
GME-1-KC-12	Cafeteria	Sink	0.001
GME-1-DW-13	Outside Cafeteria	Fountain	0.006
GME-1-EC-14	Food Lab	Sink	0.002
GME-1-DW-15	Outside Library	Fountain	0.008
GME-1-DW-16	Room 38	Fountain	0.005
GME-1-DW-17	Room 39	Fountain	0.019
GME-1-DW-18	Room 37	Fountain	0.008
GME-1-DW-19	Room 36	Fountain	0.008
GME-1-DW-20	Room 35	Fountain	0.017
GME-1-DW-21	Room 34	Fountain	0.015
GME-1-DW-22	Room 33	Fountain	0.009
GME-1-DW-23	Room 32	Fountain	0.004
GME-1-DW-24	Room 31	Fountain	0.004
GME-1-DW-26	Room 29	Fountain	0.006
GME-1-DW-27	Room 28	Fountain	0.004
GME-1-DW-30	Room 24	Fountain	0.002
GME-1-DW-31	Room 25	Fountain	0.003
GME-1-DW-32	Room 23	Fountain	0.004
GME-1-DW-33	Room 22	Fountain	0.006
GME-1-BF-34	Boys Room by Cafeteria Right	Sink	0.003
GME-1-BF-35	Boys Room by Cafeteria Left	Sink	0.017
GME-1-BF-36	Girls Room by Cafeteria Right	Sink	0.017
GME-1-BF-37	Girls Room by Cafeteria Left	Sink	0.005
GME-1-CF-38	Art Room Left	Sink	0.002
GME-1-CF-39	Art Room Right	Sink	0.001
GME-1-CF-40	Library Office Reading	Sink	<.001
GME-1-CF-41	Room 23	Sink	0.003
GME-1-CF-42	Room 22	Sink	0.007
GME-1-CF-43	Room 25	Sink	0.010
GME-1-CF-44	Room 24	Sink	0.003
GME-1-BF-45	Faculty Room across from RM 24	Sink	0.020
GME-1-CF-46	Room 26	Sink	0.016
GME-1-DW-47	Room 26 Bubbler	Fountain	0.017

Green Meadow Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GME-1-CF-48	Room 28	Sink	0.004
GME-1-CF-49	Room 29	Sink	0.015
GME-1-CF-50	Room 30	Sink	0.002
GME-1-DW-51	Room 30 Bubbler	Fountain	0.006
GME-1-CF-52	Room 31	Sink	0.008
GME-1-CF-53	Room 32	Sink	0.001
GME-1-CF-54	Room 33	Sink	0.010
GME-1-CF-55	Room 34	Sink	0.016
GME-1-CF-56	Room 35	Sink	0.006
GME-1-CF-57	Room 36	Sink	0.007
GME-1-CF-58	Room 37	Sink	0.007
GME-1-CF-59	Room 39	Sink	0.003
GME-1-CF-60	Room 38	Sink	<.001
GME-1-KF-61	Kitchen Little Sink by refrigerator	Sink	<.001
GME-1-KF-62	Kitchen Dish Clean Left	Sink	<.001
GME-1-KF-63	Kitchen Dish Clean Right	Sink	<.001
GME-1-KF-64	Kitchen BR	Sink	0.002
GME-1-BF-65	Men's Room Across Main	Sink	<.001
GME-1-BF-66	Women's Room Across Main	Sink	<.001
GME-1-BF-67	Nurses Bathroom	Sink	0.003
GME-1-CF-68	Room 10	Sink	0.011
GME-1-CF-69	Room 10 Corner	Sink	0.002
GME-1-CF-70	Room 11	Sink	0.012
GME-1-CF-71	Room 11 Corner	Sink	0.004
GME-1-CF-72	Room 8	Sink	0.004
GME-1-CF-73	Room 8 Corner	Sink	0.003
GME-1-CF-74	Room 9	Sink	0.015
GME-1-CF-75	Room 9 Corner	Sink	0.017
GME-1-CF-76	Room 6 Music	Sink	0.008
GME-1-CF-77	Room 7 Corner	Sink	<.001
GME-1-CF-78	Room 7	Sink	0.006
GME-1-CF-79	Room 5 Left	Sink	0.002
GME-1-CF-80	Room 5 Right	Sink	0.004
GME-1-CF-81	Room 4 by BR	Sink	0.011
GME-1-CF-82	Room 4	Sink	0.007
GME-1-CF-83	Room 3 by BR	Sink	0.015
GME-1-CF-84	Room 3	Sink	0.024
GME-1-CF-85	Room 2 by BR	Sink	0.016
GME-1-CF-86	Room 2	Sink	0.020
GME-1-CF-87	Room 1 by BR	Sink	0.043
GME-1-CF-88	Room 1	Sink	0.001
GME-1-CF-89	Boys Locker Room	Sink	0.016
GME-1-CF-90	Girls Locker Room	Sink	0.007

Red Mill Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
RME-1-DW-2	Outside Room 14	Fountain	<.001
RME-1-DW-4	Room 16	Fountain	0.004
RME-1-DW-5	Room 17 b (bubbler removed)	Fountain	0.060
RME-1-DW-6	Room 18	Fountain	0.003
RME-1-DW-8	Room 20	Fountain	0.010
RME-1-DW-9	Room 21	Fountain	0.002
RME-1-DW-10	Room 24	Fountain	0.001
RME-0-WC-11	Outside Room 24	Fountain	<.001
RME-0-DW-12	Room 25	Fountain	0.002
RME-0-DW-13	Room 26	Fountain	0.003
RME-0-DW-14	Room 27	Fountain	0.010
RME-0-DW-15	Room 28	Fountain	0.008
RME-0-DW-17	Room 30	Fountain	0.003
RME-0-DW-18	Room 31	Fountain	0.002
RME-0-DW-19	Outside Room 31	Fountain	0.001
RME-0-DW-20	Room 32	Fountain	<.001
RME-0-DW-21	Room 33 (bubbler removed)	Fountain	0.024
RME-0-DW-22	Room 34	Fountain	0.001
RME-1-FC-23	Faculty Room Cold	Sink	0.002
RME-1-FH-24	Faculty Room Hot	Sink	0.002
RME-1-FC-25	Suits Cold	Sink	0.001
RME-1-FH-26	Suits Hot	Sink	<.001
RME-1-DFC27	Copy Room Cold	Sink	0.008
RME-1-FH-28	Copy Room Hot	Sink	0.002
RME-1-NC-29	Nurse Cold	Sink	0.002
RME-1-NH-30	Nurse Hot	Sink	<.001
RME-1-EC-31	Food Lab Cold	Sink	0.005
RME-1-EH-32	Food Lab Hot	Sink	0.002
RME-1-DW-33	Room 9	Fountain	0.022
RME-1-DW-34	Room 8	Fountain	0.024
RME-1-DW-35	Room 7	Fountain	0.028
RME-1-DW-37	Room 4	Fountain	0.020
RME-1-DW-38	Room 3	Fountain	<.001
RME-1-DW-39	Room 2	Fountain	0.003
RME-1-DW-40	Room 1	Fountain	<.001
RME-1-DW-41	Outside Kitchen Left	Fountain	0.028
RME-1-DW-42	Outside Kitchen Right	Fountain	0.036
RME-1-KC-43	Kitchen Prep Cold	Sink	0.001
RME-1-KH-44	Kitchen Prep Hot	Sink	0.002
RME-1-KC-45	Kitchen Left Cold	Sink	0.001
RME-1-KH-46	Kitchen Left Hot	Sink	<.001
RME-1-KC-47	Kitchen Right Cold	Sink	0.007
RME-1-KH-48	Kitchen Right Hot	Sink	<.001
RME-1-DW-49	Outside Gym Left	Fountain	<.001

Red Mill Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
RME-1-WC-51	Front Lobby Left	Fountain	0.002
RME-1-WC-52	Front Lobby Right	Fountain	0.004
RME-1-NBF-53	Nurse BR Faucet	Sink	0.011
RME-1-CF-54	Room 9 by Bubbler	Sink	0.013
RME-1-CF-55	Room 9	Sink	0.006
RME-1-CF-56	Room 8 by Bubbler	Sink	0.012
RME-1-CF-57	Room 8	Sink	0.010
RME-1-CF-58	Room 7 by Bubbler	Sink	0.004
RME-1-CF-59	Room 7	Sink	0.007
RME-1-CF-60	Room 6 by Bubbler	Sink	0.011
RME-1-CF-61	Room 6 by Bubbler	Sink	0.007
RME-1-CF-62	Room 5 by Bubbler	Sink	0.006
RME-1-CF-63	Room 5 Center	Sink	0.014
RME-1-CF-64	Room 4 by Bubbler	Sink	0.006
RME-1-CF-65	Room 4	Sink	0.009
RME-1-CF-66	Room 3 by Bubbler	Sink	0.003
RME-1-CF-67	Room 3	Sink	0.030
RME-1-CF-68	Room 2 by Bubbler	Sink	0.006
RME-1-BF-69	Room 2 by Bathroom	Sink	0.004
RME-1-CF-70	Room 1 by bubbler	Sink	0.009
RME-1-BF-71	Room 1 by Bathroom	Sink	0.008
RME-1-BF-72	Boys Bathroom by Custodial L	Sink	0.027
RME-1-BF-73	Boys Bathroom by Custodial R	Sink	0.017
RME-1-KF-74	Kitchen	Sink	<.001
RME-1-KF-75	Kitchen	Sink	<.001
RME-1-KF-76	Kitchen	Sink	<.001
RME-1-KF-77	Kitchen	Sink	<.001
RME-1-BF-78	Girls Bathroom by Custodial L	Sink	0.027
RME-1-BF-79	Girls Bathroom by Custodial R	Sink	0.028
RME-1-CF-80	Band Room Left	Sink	0.003
RME-1-CF-81	Band Room Right	Sink	0.023
RME-1-BF-82	Coach Mens	Sink	0.004
RME-1-BF-83	Coach Womens	Sink	0.003
RME-1-CF-84	Office by Gym Lockers	Sink	0.016
RME-1-BF-85	Room 13 Bathroom	Sink	0.012
RME-1-CF-86	Room 13	Sink	0.014
RME-1-BF-87	Amy's Bathroom	Sink	0.003
RME-1-CF-88	Art Left	Sink	0.005
RME-1-CF-89	Art Right	Sink	0.002
RME-1-BF-90	Faculty Bathroom across Café	Sink	0.001
RME-1-BF-91	Womens BR across faculty Rm L	Sink	0.005
RME-1-BF-92	Womens BR across faculty Rm R	Sink	0.028
RME-1-BF-93	Mens Room L	Sink	0.004
RME-1-BF-94	Mens Room R	Sink	0.009

Red Mill Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
RME-1-CF-95	Office between Fac & Lib	Sink	0.017
RME-1-CF-96	Lib Off	Sink	0.004
RME-1-CF-97	Room 20 BR	Sink	0.006
RME-1-CF-98	Room 20	Sink	0.009
RME-1-BF-99	Room 19 BR	Sink	0.004
RME-1-CF-100	Room 19 by Bubbler	Sink	0.004
RME-1-CF-101	Room 18 Sink	Sink	0.003
RME-1-CF-102	Room 17b Sink	Sink	0.032
RME-1-CF-103	Room 16	Sink	0.025
RME-1-CF-104	Room 15	Sink	0.017
RME-1-CF-105	Room 14	Sink	0.057
RME-1-BF-106	Room 13 L	Sink	0.024
RME-1-BF-107	Room 13	Sink	0.011
RME-1-BF-108	Room 13	Sink	0.008
RME-0-CF-109	Room 24	Sink	0.054
RME-0-CF-110	Room 25	Sink	0.013
RME-0-CF-111	Room 26	Sink	0.007
RME-0-CF-112	Room 27	Sink	0.050
RME-0-CF-113	Room 28	Sink	0.009
RME-0-CF-114	Room 29 not a classroom	Sink	0.020
RME-0-BF-115	Girls BR Left	Sink	0.002
RME-0-BF-116	Girls BR Mid	Sink	0.057
RME-0-BF-117	Girls BR Right	Sink	0.009
RME-0-BF-118	Room 30	Sink	0.007
RME-0-CF-119	Room 31	Sink	0.032
RME-0-CF-120	Room 32	Sink	0.031
RME-0-CF-121	Room 33	Sink	0.110
RME-0-CF-122	Room 34	Sink	0.010