



Needham Risk Management Resource Group, LLC

Competence ▫ Ethics ▫ Integrity ▫ Results

January 6, 2017

Mr. Jeffrey P. Simons, Superintendent
East Greenbush Central School District
29 Englewood Avenue
East Greenbush, NY 12061

RE: Citizen Genet Elementary Lead-in-Water Testing Results

Dear Mr. Simons,

Needham Risk Management has performed lead sample collection for all potable water sources in the East Greenbush Central School District according to the New York State Department of Health (NYSDOH) School Potable Water Testing and Standards. The samples were collected at all five elementary schools by the deadline of September 30, 2016, and at Howard L. Goff Middle School and Columbia High School by their deadline of October 31, 2016.

Listed below are the test results for Citizen Genet Elementary School. Of the 93 samples taken, 5 were above the NYSDOH action level of 15 parts per billion. The District's analytical results have been reported to the Rensselaer County Department of Health, as required by the standard. Prior to returning any outlet to service, a confirmation sample will be performed to ensure the effectiveness of the corrective action that was taken.

If you have any questions, please do not hesitate to contact me.

Sincerely,

Michael Needham, CSP, CFPS, RES, CET
Safety & Health Consultant

Attachments

573 Columbia Turnpike, Suite 3
East Greenbush, NY 12061
Telephone: (518) 860-1758 Fax: (518) 860-1759
Email: team@theneedhamgroup.com
www.theneedhamgroup.com

Citizen Genet Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GE-1-FC-1	Admin Kitchen Cold	Sink	<.001
GE-1-IM-2	Admin Kitchen Ice	Ice	<.001
GE-2-DW-3	Outside Admin Conf Rm 413	Fountain	0.027
GE-2-FC-4	Admin 2nd Floor Ladies RM	Sink	<.001
GE-2-DW-6	Outside Room 226	Fountain	0.002
GE-2-FC-7	Staff Room 226 Sink Cold	Sink	<.001
GE-2-DW-8	Outside Room 244	Fountain	0.018
GE-2-DW-9	Outside Library	Fountain	0.002
GE-1-WC-10	Cafeteria	Fountain	0.002
GE-1-DW-11	Across from Room 123	Fountain	0.004
GE-1-FC-13	Keurig Line Room 117	Sink	0.002
GE-1-IM-14	Room 117 Ice Maker	Ice	<.001
GE-1-DW-15	Across from Main Office	Fountain	0.002
GE-1-DW-16	Back of Gym-Stairwell	Fountain	0.004
GE-1-DW-17	Gym other side	Fountain	0.012
GE-1-EC-18	Food Lab	Sink	<.001
GE - 1-DW-20	Near Room 176	Fountain	0.059
GE - 1-NC-22	Nurse Bathroom Cold	Sink	<.001
GE -1-KC-24	Kitchen Prep near door	Sink	<.001
GE -1-KC-25	Kitchen Large Sink Left	Sink	<.001
GE -1-KC-26	Kitchen Large Sink Right	Sink	0.002
GE -1-KC-27	Kitchen Sink near office	Sink	<.001
GE-2-DW-5	Near Room 209	Fountain	0.005
GE-1-FC-12	Staff Room 117	Sink	<.001
GE-1-DW-21	Outside Room 115	Fountain	0.010
GE-1-FC-23	Main Office	Sink	<.001
GE-1-BF-28	Girls next to Room 149	Sink	0.003
GE-1-BF-29	Girls next to Room 149	Sink	0.003
GE-1-BF-30	Men's Room Main Lobby	Sink	0.009
GE-1-BF-31	Men's Room Main Lobby	Sink	0.007
GE-1-BF-32	Women's across from 114	Sink	0.002
GE-1-BF-33	Women's across from 114	Sink	0.006
GE-1-BF-34	Women's across from 114	Sink	0.014
GE-1-BF-35	Boys Room by Room 112	Sink	0.002
GE-1-BF-36	Boys Room by Room 112	Sink	0.003
GE-1-BF-37	Back of stage by Room 103	Sink	0.010
GE-1-CF-38	ART Room	Sink	<.001
GE-1-CF-39	ART Room	Sink	<.001
GE-1-CF-40	Room 125	Sink	<.001
GE-1-CF-41	Room 128	Sink	0.001
GE-1-CF-42	Room 126	Sink	0.001
GE-1-CF-43	Room 149	Sink	0.005
GE-1-CF-44	Health Office Bathroom Sink	Sink	<.001
GE-1-CF-45	Room 171 small	Sink	0.003

Citizen Genet Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GE-1-CF-46	Room 171 large	Sink	<.001
GE-1-CF-47	Room 174 small	Sink	<.001
GE-1-CF-48	Room 174 large	Sink	0.001
GE-1-BF-49	Room 177 Bathroom Sink	Sink	0.037
GE-1-CF-50	Room 177 Classroom Sink	Sink	<.001
GE-1-CF-51	Room 179 small	Sink	<.001
GE-1-CF-52	Room 179 large	Sink	0.005
GE-1-CF-53	Room 178 Small	Sink	<.001
GE-1-CF-54	Room 178 Large	Sink	0.006
GE-1-CF-55	Room 176 Small	Sink	<.001
GE-1-CF-56	Room 176 large	Sink	0.001
GE-2-CF-57	Room 227	Sink	<.001
GE-2-CF-58	Room 229	Sink	<.001
GE-2-BF-59	Room 231 bathroom sink	Sink	0.006
GE-2-CF-60	Room 231 Classroom sink	Sink	<.001
GE-2-BF-61	Room 241 Science Lab	Sink	<.001
GE-2-BF-62	Girls bathroom next Room 241	Sink	0.002
GE-2-BF-63	Girls bathroom next Room 241	Sink	0.001
GE-2-CF-64	Room 245	Sink	<.001
GE-2-CF-65	Room 248	Sink	0.001
GE-2-CF-66	Room 246	Sink	<.001
GE-2-CF-67	Room 244	Sink	0.001
GE-2-CF-68	Room 242	Sink	0.002
GE-2-BF-69	Boys Bathroom next to RM 242	Sink	0.002
GE-2-BF-70	Boys Bathroom next to RM 242	Sink	0.002
GE-2-CF-71	Room 238	Sink	0.002
GE-2-CF-72	Room 234	Sink	0.001
GE-2-CF-73	Room 214	Sink	0.003
GE-2-CF-74	Room 216	Sink	0.001
GE-2-CF-75	Room 218	Sink	0.004
GE-2-CF-76	Room 220	Sink	0.001
GE-2-CF-77	Room 217	Sink	<.001
GE-2-CF-78	Room 209	Sink	<.001
GE-2-BF-79	Boys Bathroom by RM 205	Sink	0.011
GE-2-BF-80	Boys Bathroom by RM 205	Sink	0.001
GE-2-BF-81	Boys Bathroom by RM 205	Sink	0.002
GE-2-CF-82	Room 205	Sink	0.002
GE-2-CF-83	Room 203	Sink	<.001
GE-2-CF-84	Room 201	Sink	0.045
GE-2-BF-85	Girls Room next to Room 204	Sink	0.004
GE-2-BF-86	Girls Room next to Room 204	Sink	0.005
GE-2-BF-87	Girls Room next to Room 204	Sink	0.007
GE-2-CF-88	Room 200	Sink	<.001
GE-2-BF-89	Admin Men's Room	Sink	0.006

Citizen Genet Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GE-2-BF-90	Women's Rm Admin next to 307	Sink	0.002
GE-2-BF-91	Men's Rm Admin next to 307	Sink	<.001
GE-2-BF-92	Girls bathroom next Room 100	Sink	0.005
GE-2-BF-93	Girls bathroom next Room 100	Sink	0.002
GE-2-BF-94	Girls bathroom next Room 100	Sink	0.010