



Needham Risk Management Resource Group, LLC

Competence ▫ Ethics ▫ Integrity ▫ Results

January 6, 2017

Mr. Jeffrey P. Simons, Superintendent
East Greenbush Central School District
29 Englewood Avenue
East Greenbush, NY 12061

RE: Green Meadow Elementary Lead-in-Water Testing Results

Dear Mr. Simons,

Needham Risk Management has performed lead sample collection for all potable water sources in the East Greenbush Central School District according to the New York State Department of Health (NYSDOH) School Potable Water Testing and Standards. The samples were collected at all five elementary schools by the deadline of September 30, 2016, and at Howard L. Goff Middle School and Columbia High School by their deadline of October 31, 2016.

Listed below are the test results for Green Meadow Elementary School. Of the 87 samples taken, 17 were above the NYSDOH action level of 15 parts per billion. The District's analytical results have been reported to the Rensselaer County Department of Health, as required by the standard. Prior to returning any outlet to service, a confirmation sample will be performed to ensure the effectiveness of the corrective action that was taken.

If you have any questions, please do not hesitate to contact me.

Sincerely,

Michael Needham, CSP, CFPS, RES, CET
Safety & Health Consultant

Attachments

573 Columbia Turnpike, Suite 3
East Greenbush, NY 12061
Telephone: (518) 860-1758 Fax: (518) 860-1759
Email: team@theneedhamgroup.com
www.theneedhamgroup.com

Green Meadow Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GME-1-DW-1	Room 7	Fountain	0.008
GME-1-DW-2	Room 9	Fountain	0.021
GME-1-DW-3	Room 8	Fountain	0.016
GME-1-DW-4	Room 11	Fountain	0.017
GME-1-DW-5	Room 10	Fountain	0.004
GME-1-DW-6	Room 10	Fountain	0.008
GME-1-NC-7	Nurse Cold	Fountain	0.001
GME-1-DW-8	Outside Gym Near Office	Fountain	0.005
GME-1-DW-9	Outside Gym Near Storage	Fountain	0.002
GME-1-FC-10	Faculty Room 111	Sink	0.003
GME-1-KC-11	Prep Kitchen Cold	Sink	0.004
GME-1-KC-12	Cafeteria	Sink	0.001
GME-1-DW-13	Outside Cafeteria	Fountain	0.006
GME-1-EC-14	Food Lab	Sink	0.002
GME-1-DW-15	Outside Library	Fountain	0.008
GME-1-DW-16	Room 38	Fountain	0.005
GME-1-DW-17	Room 39	Fountain	0.019
GME-1-DW-18	Room 37	Fountain	0.008
GME-1-DW-19	Room 36	Fountain	0.008
GME-1-DW-20	Room 35	Fountain	0.017
GME-1-DW-21	Room 34	Fountain	0.015
GME-1-DW-22	Room 33	Fountain	0.009
GME-1-DW-23	Room 32	Fountain	0.004
GME-1-DW-24	Room 31	Fountain	0.004
GME-1-DW-26	Room 29	Fountain	0.006
GME-1-DW-27	Room 28	Fountain	0.004
GME-1-DW-30	Room 24	Fountain	0.002
GME-1-DW-31	Room 25	Fountain	0.003
GME-1-DW-32	Room 23	Fountain	0.004
GME-1-DW-33	Room 22	Fountain	0.006
GME-1-BF-34	Boys Room by Cafeteria Right	Sink	0.003
GME-1-BF-35	Boys Room by Cafeteria Left	Sink	0.017
GME-1-BF-36	Girls Room by Cafeteria Right	Sink	0.017
GME-1-BF-37	Girls Room by Cafeteria Left	Sink	0.005
GME-1-CF-38	Art Room Left	Sink	0.002
GME-1-CF-39	Art Room Right	Sink	0.001
GME-1-CF-40	Library Office Reading	Sink	<.001
GME-1-CF-41	Room 23	Sink	0.003
GME-1-CF-42	Room 22	Sink	0.007
GME-1-CF-43	Room 25	Sink	0.010
GME-1-CF-44	Room 24	Sink	0.003
GME-1-BF-45	Faculty Room across from RM 24	Sink	0.020
GME-1-CF-46	Room 26	Sink	0.016
GME-1-DW-47	Room 26 Bubblers	Fountain	0.017

Green Meadow Elementary School

<u>Sample #</u>	<u>Sample Location</u>	<u>Source</u>	<u>(ppb)</u>
GME-1-CF-48	Room 28	Sink	0.004
GME-1-CF-49	Room 29	Sink	0.015
GME-1-CF-50	Room 30	Sink	0.002
GME-1-DW-51	Room 30 Bubbler	Fountain	0.006
GME-1-CF-52	Room 31	Sink	0.008
GME-1-CF-53	Room 32	Sink	0.001
GME-1-CF-54	Room 33	Sink	0.010
GME-1-CF-55	Room 34	Sink	0.016
GME-1-CF-56	Room 35	Sink	0.006
GME-1-CF-57	Room 36	Sink	0.007
GME-1-CF-58	Room 37	Sink	0.007
GME-1-CF-59	Room 39	Sink	0.003
GME-1-CF-60	Room 38	Sink	<.001
GME-1-KF-61	Kitchen Little Sink by refrigerator	Sink	<.001
GME-1-KF-62	Kitchen Dish Clean Left	Sink	<.001
GME-1-KF-63	Kitchen Dish Clean Right	Sink	<.001
GME-1-KF-64	Kitchen BR	Sink	0.002
GME-1-BF-65	Men's Room Across Main	Sink	<.001
GME-1-BF-66	Women's Room Across Main	Sink	<.001
GME-1-BF-67	Nurses Bathroom	Sink	0.003
GME-1-CF-68	Room 10	Sink	0.011
GME-1-CF-69	Room 10 Corner	Sink	0.002
GME-1-CF-70	Room 11	Sink	0.012
GME-1-CF-71	Room 11 Corner	Sink	0.004
GME-1-CF-72	Room 8	Sink	0.004
GME-1-CF-73	Room 8 Corner	Sink	0.003
GME-1-CF-74	Room 9	Sink	0.015
GME-1-CF-75	Room 9 Corner	Sink	0.017
GME-1-CF-76	Room 6 Music	Sink	0.008
GME-1-CF-77	Room 7 Corner	Sink	<.001
GME-1-CF-78	Room 7	Sink	0.006
GME-1-CF-79	Room 5 Left	Sink	0.002
GME-1-CF-80	Room 5 Right	Sink	0.004
GME-1-CF-81	Room 4 by BR	Sink	0.011
GME-1-CF-82	Room 4	Sink	0.007
GME-1-CF-83	Room 3 by BR	Sink	0.015
GME-1-CF-84	Room 3	Sink	0.024
GME-1-CF-85	Room 2 by BR	Sink	0.016
GME-1-CF-86	Room 2	Sink	0.020
GME-1-CF-87	Room 1 by BR	Sink	0.043
GME-1-CF-88	Room 1	Sink	0.001
GME-1-CF-89	Boys Locker Room	Sink	0.016
GME-1-CF-90	Girls Locker Room	Sink	0.007