

| Sample Identification # | Location | Outlet Description | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | NYSDOH Action Level | Units | Remediation Actions |
|-------------------------|---|-----------------------|---------------------|--------------------|--------------|---------|---------|---------------------|-------|---------------------|
| CHS-01-BF-P-01 | Boy's Room by S118 - R | Bathroom Faucet | 4/1/2021 05:07 | 4/12/2021 14:37 | 70167859001 | Lead | 4.6 | 15 | ug/L | |
| CHS-01-BF-P-02 | Boy's Room by S118 - L | Bathroom Faucet | 4/1/2021 05:07 | 4/12/2021 14:41 | 70167859002 | Lead | 3.1 | 15 | ug/L | |
| CHS-01-DW-P-03 | Fountain by Boy's Room S118 | Water Fountain | 4/1/2021 05:09 | 4/12/2021 14:42 | 70167859003 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-04 | Girl's Room by S102 - L | Bathroom Faucet | 4/1/2021 05:10 | 4/12/2021 14:43 | 70167859004 | Lead | 1.7 | 15 | ug/L | |
| CHS-01-BF-P-05 | Girl's Room by S102 - R | Bathroom Faucet | 4/1/2021 05:10 | 4/12/2021 14:44 | 70167859005 | Lead | 3.1 | 15 | ug/L | |
| CHS-01-DW-P-06 | Fountain by Women's Room by S102 | Water Fountain | 4/1/2021 05:11 | 4/12/2021 14:46 | 70167859006 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-SF-P-07 | Main Office Suite Break Room | Sink Faucet | 4/1/2021 05:13 | 4/12/2021 14:47 | 70167859007 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-08 | Main Office Suite Women's Room | Bathroom Faucet | 4/1/2021 05:13 | 4/12/2021 14:48 | 70167859008 | Lead | 6.4 | 15 | ug/L | |
| CHS-01-BF-P-09 | Main Office Suite Men's Room | Bathroom Faucet | 4/1/2021 05:13 | 4/12/2021 14:49 | 70167859009 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-NF-P-10 | Health Office - C102A First Aid Room | Sink Faucet | 4/1/2021 05:13 | 4/12/2021 14:50 | 70167859010 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-NF-P-11 | Health Office - C102F Exam Room | Sink Faucet | 4/1/2021 05:15 | 4/12/2021 14:51 | 70167859011 | Lead | 2.9 | 15 | ug/L | |
| CHS-01-BF-P-12 | Health Office - Girl's Room | Bathroom Faucet | 4/1/2021 05:15 | 4/12/2021 14:54 | 70167859012 | Lead | 1.3 | 15 | ug/L | |
| CHS-01-BF-P-13 | Health Office - Boy's Room | Bathroom Faucet | 4/1/2021 05:15 | 4/12/2021 14:55 | 70167859013 | Lead | 1.3 | 15 | ug/L | |
| CHS-01-SF-P-14 | Guidance Suite - Kitchen | Sink Faucet | 4/1/2021 05:21 | 4/12/2021 18:07 | 70167859142 | Lead | 2.6 | 15 | ug/L | |
| CHS-01-BF-P-15 | Guidance Suite - Men's Room | Bathroom Faucet | 4/1/2021 05:21 | 4/12/2021 18:07 | 70167859143 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-16 | Guidance Suite - Women's Room | Bathroom Faucet | 4/1/2021 05:21 | 4/12/2021 18:10 | 70167859144 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-CF-P-17 | N115 | Classroom Sink Faucet | 4/1/2021 05:23 | 4/12/2021 14:58 | 70167859014 | Lead | 1.2 | 15 | ug/L | |
| CHS-01-CF-P-18 | N106 | Classroom Sink Faucet | 4/1/2021 05:24 | 4/12/2021 14:59 | 70167859015 | Lead | 4.7 | 15 | ug/L | |
| CHS-01-CF-P-19 | N107 | Classroom Sink Faucet | 4/1/2021 05:25 | 4/12/2021 15:00 | 70167859016 | Lead | 6.9 | 15 | ug/L | |
| CHS-01-SF-P-21 | N108 - Faculty | Sink Faucet | 4/1/2021 05:27 | 4/12/2021 15:01 | 70167859017 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-22 | N108 - Faculty - Men's Room | Bathroom Faucet | 4/1/2021 05:28 | 4/12/2021 15:02 | 70167859018 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-23 | N108 - Faculty - Women's Room | Bathroom Faucet | 4/1/2021 05:28 | 4/12/2021 15:02 | 70167859019 | Lead | 1.6 | 15 | ug/L | |
| CHS-01-BF-P-24 | Kitchen - Men's Room | Bathroom Faucet | 4/1/2021 05:30 | 4/12/2021 15:03 | 70167859020 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-25 | Kitchen - Women's Room | Bathroom Faucet | 4/1/2021 05:30 | 4/12/2021 15:06 | 70167859021 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-26 | Kitchen - Kettle | Kitchen Faucet | 4/1/2021 05:32 | 4/12/2021 15:11 | 70167859022 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-27 | Kitchen - Tilt Skillet | Kitchen Faucet | 4/1/2021 05:32 | 4/12/2021 15:12 | 70167859023 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-28 | Kitchen - Food Prep Center | Kitchen Faucet | 4/1/2021 05:32 | 4/12/2021 15:13 | 70167859024 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-29 | Kitchen - Handwash Center | Kitchen Faucet | 4/1/2021 05:32 | 4/12/2021 15:14 | 70167859025 | Lead | 2.2 | 15 | ug/L | |
| CHS-01-KF-P-30 | Cafeteria - Handwash Center Back | Kitchen Faucet | 4/1/2021 05:35 | 4/12/2021 15:15 | 70167859026 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-31 | Cafeteria - Sink Center Back by Handwash | Kitchen Faucet | 4/1/2021 05:35 | 4/12/2021 15:16 | 70167859027 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-32 | Cafeteria - Steam Table Dishwash Rm Side | Kitchen Faucet | 4/1/2021 05:35 | 4/12/2021 15:17 | 70167859028 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-33 | Cafeteria - Dishwash Room - Handwash | Kitchen Faucet | 4/1/2021 05:35 | 4/12/2021 15:18 | 70167859029 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-34 | Cafeteria - Sink - Left Side | Kitchen Faucet | 4/1/2021 05:35 | 4/12/2021 15:20 | 70167859030 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-35 | Cafeteria - Steam Table - Left Side | Kitchen Faucet | 4/1/2021 05:35 | 4/12/2021 15:21 | 70167859031 | Lead | 1.5 | 15 | ug/L | |
| CHS-01-IM-P-36 | Cafeteria - Ice Machine | Ice Machine | 4/1/2021 05:38 | 4/12/2021 15:24 | 70167859032 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-KF-P-37 | Cafeteria - Handwash - Left Side | Kitchen Faucet | 4/1/2021 05:35 | 4/12/2021 15:25 | 70167859033 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-38 | Boy's Room by Kitchen - L | Bathroom Faucet | 4/1/2021 05:47 | 4/12/2021 15:26 | 70167859034 | Lead | 2.1 | 15 | ug/L | |
| CHS-01-BF-P-39 | Boy's Room by Kitchen - C | Bathroom Faucet | 4/1/2021 05:43 | 4/12/2021 15:27 | 70167859035 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-40 | Boy's Room by Kitchen - R | Bathroom Faucet | 4/1/2021 05:43 | 4/12/2021 15:28 | 70167859036 | Lead | 1.1 | 15 | ug/L | |
| CHS-01-BF-P-41 | Girl's Room by Kitchen - L | Bathroom Faucet | 4/1/2021 05:45 | 4/12/2021 15:29 | 70167859037 | Lead | 2.8 | 15 | ug/L | |
| CHS-01-BF-P-42 | Girl's Room by Kitchen - C | Bathroom Faucet | 4/1/2021 05:45 | 4/12/2021 15:32 | 70167859038 | Lead | 3.7 | 15 | ug/L | |
| CHS-01-BF-P-43 | Girl's Room by Kitchen - R | Bathroom Faucet | 4/1/2021 05:45 | 4/12/2021 15:33 | 70167859039 | Lead | 1.6 | 15 | ug/L | |
| CHS-01-SF-P-43A | Kitchen - Snack Shack | Sink Faucet | 4/1/2021 05:38 | 4/12/2021 18:04 | 70167859141 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-45 | Gym Fountains Right Section - Right Fountain | Water Fountain | 4/1/2021 05:47 | 4/12/2021 15:34 | 70167859040 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-47 | Gym Fountains Center Section - Right Fountain | Water Fountain | 4/1/2021 05:48 | 4/12/2021 15:36 | 70167859041 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-48 | Gym Fountains Left Section - Left Fountain | Water Fountain | 4/1/2021 05:49 | 4/12/2021 15:39 | 70167859042 | Lead | <1.0 | 15 | ug/L | |

| Sample Identification # | Location | Outlet Description | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | NYSDOH Action Level | Units | Remediation Actions |
|-------------------------|---|-----------------------|---------------------|--------------------|--------------|---------|---------|---------------------|-------|--|
| CHS-01-DW-P-49 | Gym Fountains Left Section - Right Fountain | Water Fountain | 4/1/2021 05:49 | 4/12/2021 15:40 | 70167859043 | Lead | <1.0 | 15 | ug/L | |
| CHS-B-BF-P-50 | Team Room/Locker Room P010A - L | Bathroom Faucet | 4/1/2021 05:52 | 4/12/2021 15:43 | 70167859044 | Lead | <1.0 | 15 | ug/L | |
| CHS-B-BF-P-51 | Team Room/Locker Room P010A - R | Bathroom Faucet | 4/1/2021 05:57 | 4/12/2021 15:44 | 70167859045 | Lead | <1.0 | 15 | ug/L | |
| CHS-B-SF-P-52 | Maintenance Break Room Sink | Sink Faucet | 4/1/2021 05:53 | 4/12/2021 15:45 | 70167859046 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-CF-P-53 | C107 - South Wall Left | Classroom Sink Faucet | 4/1/2021 05:05 | 4/12/2021 15:46 | 70167859047 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-CF-P-54 | C107 - South Wall Right | Classroom Sink Faucet | 4/1/2021 05:05 | 4/12/2021 15:47 | 70167859048 | Lead | 1.6 | 15 | ug/L | |
| CHS-01-CF-P-55 | C107 - Center | Classroom Sink Faucet | 4/1/2021 05:05 | 4/12/2021 15:48 | 70167859049 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-CF-P-56 | C107 - North/Corridor Wall Left | Classroom Sink Faucet | 4/1/2021 05:05 | 4/12/2021 15:49 | 70167859050 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-CF-P-57 | C107 - North/Corridor Wall Right | Classroom Sink Faucet | 4/1/2021 05:05 | 4/12/2021 15:50 | 70167859051 | Lead | 1.1 | 15 | ug/L | |
| CHS-01-BF-P-58 | 1st Fl C-Wing Girl's - L | Bathroom Faucet | 4/1/2021 05:09 | 4/12/2021 15:54 | 70167859052 | Lead | 1.9 | 15 | ug/L | |
| CHS-01-BF-P-59 | 1st Fl C-Wing Girl's - C | Bathroom Faucet | 4/1/2021 05:09 | 4/12/2021 15:55 | 70167859053 | Lead | 4.3 | 15 | ug/L | |
| CHS-01-BF-P-60 | 1st Fl C-Wing Girl's - R | Bathroom Faucet | 4/1/2021 05:09 | 4/12/2021 15:56 | 70167859054 | Lead | 8.5 | 15 | ug/L | |
| CHS-01-BF-P-61 | 1st Fl C-Wing Boy's - L | Bathroom Faucet | 4/1/2021 05:10 | 4/12/2021 15:57 | 70167859055 | Lead | 9.6 | 15 | ug/L | |
| CHS-01-BF-P-62 | 1st Fl C-Wing Boy's - C | Bathroom Faucet | 4/1/2021 05:10 | 4/12/2021 15:58 | 70167859056 | Lead | 5.1 | 15 | ug/L | |
| CHS-01-BF-P-63 | 1st Fl C-Wing Boy's - R | Bathroom Faucet | 4/1/2021 05:10 | 4/12/2021 15:59 | 70167859057 | Lead | 2.6 | 15 | ug/L | |
| CHS-01-BF-P-64 | Gender Neutral by Boy's Aud | Bathroom Faucet | 4/1/2021 05:11 | 4/12/2021 16:00 | 70167859058 | Lead | 2.9 | 15 | ug/L | |
| CHS-01-BF-P-65 | Boy's Room Aud - L | Bathroom Faucet | 4/1/2021 05:14 | 4/12/2021 16:01 | 70167859059 | Lead | 3.7 | 15 | ug/L | |
| CHS-01-BF-P-66 | Boy's Room Aud - C | Bathroom Faucet | 4/1/2021 05:14 | 4/12/2021 16:02 | 70167859060 | Lead | 1.7 | 15 | ug/L | |
| CHS-01-BF-P-67 | Boy's Room Aud - R | Bathroom Faucet | 4/1/2021 05:14 | 4/12/2021 16:06 | 70167859061 | Lead | 10.4 | 15 | ug/L | |
| CHS-01-BF-P-68 | Girl's Room Aud - L | Bathroom Faucet | 4/1/2021 05:16 | 4/12/2021 16:09 | 70167859062 | Lead | 185 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-69 | Girl's Room Aud - C | Bathroom Faucet | 4/1/2021 05:16 | 4/12/2021 16:10 | 70167859063 | Lead | 34.6 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-70 | Girl's Room Aud - R | Bathroom Faucet | 4/1/2021 05:16 | 4/12/2021 16:11 | 70167859064 | Lead | 283 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-71 | Gender Neutral by Girl's Aud | Bathroom Faucet | 4/1/2021 05:17 | 4/12/2021 16:12 | 70167859065 | Lead | 5.3 | 15 | ug/L | |
| CHS-01-DW-P-72 | Fountain - Gym Hall Corner | Bathroom Faucet | 4/1/2021 05:18 | 4/12/2021 16:13 | 70167859066 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-73 | Stage Bathroom | Bathroom Faucet | 4/1/2021 05:19 | 4/12/2021 16:14 | 70167859067 | Lead | 2.9 | 15 | ug/L | |
| CHS-01-CF-P-74 | P112 - L | Classroom Sink Faucet | 4/1/2021 05:20 | 4/12/2021 16:17 | 70167859068 | Lead | 4.3 | 15 | ug/L | |
| CHS-01-CF-P-75 | P112 - R | Classroom Sink Faucet | 4/1/2021 05:20 | 4/12/2021 16:18 | 70167859069 | Lead | 2.0 | 15 | ug/L | |
| CHS-01-DW-P-76 | Fountain by A102 - L | Water Fountain | 4/1/2021 05:22 | 4/12/2021 16:19 | 70167859070 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-77 | Bottle Filler by A102 | Bottle Filler | 4/1/2021 05:23 | 4/12/2021 16:20 | 70167859071 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-77A | Fountain by A102 - R | Water Fountain | 4/1/2021 05:23 | 4/12/2021 18:00 | 70167859139 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-SF-P-78 | Trainer's Room Sink | Sink Faucet | 4/1/2021 05:27 | 4/12/2021 16:22 | 70167859072 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-IM-P-79 | Training Room Ice Machine | Ice Machine | 4/1/2021 05:27 | 4/12/2021 16:23 | 70167859073 | Lead | <1.0 | 15 | ug/L | |

| Sample Identification # | Location | Outlet Description | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | NYSDOH Action Level | Units | Remediation Actions |
|-------------------------|-------------------------------------|--------------------|---------------------|--------------------|--------------|---------|---------|---------------------|-------|--|
| CHS-01-BF-P-80 | Boy's Locker Bathroom - Far L | Bathroom Faucet | 4/1/2021 05:29 | 4/12/2021 16:24 | 70167859074 | Lead | 7.3 | 15 | ug/L | |
| CHS-01-BF-P-81 | Boy's Locker Bathroom - L Center | Bathroom Faucet | 4/1/2021 05:29 | 4/12/2021 16:25 | 70167859075 | Lead | 5.6 | 15 | ug/L | |
| CHS-01-BF-P-82 | Boy's Locker Bathroom - R Center | Bathroom Faucet | 4/1/2021 05:29 | 4/12/2021 16:28 | 70167859076 | Lead | 2.6 | 15 | ug/L | |
| CHS-01-BF-P-83 | Boy's Locker Bathroom - Far R | Bathroom Faucet | 4/1/2021 05:29 | 4/12/2021 16:29 | 70167859077 | Lead | 1.4 | 15 | ug/L | |
| CHS-01-DW-P-84 | L Fountain by Boy's Locker | Water Fountain | 4/1/2021 05:31 | 4/12/2021 16:30 | 70167859078 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-85 | R Fountain by Boy's Locker | Water Fountain | 4/1/2021 05:31 | 4/12/2021 16:31 | 70167859079 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-86 | Boy's PE Office Bathroom | Bathroom Faucet | 4/1/2021 05:32 | 4/12/2021 16:32 | 70167859080 | Lead | 9.6 | 15 | ug/L | |
| CHS-01-BF-P-87 | Boy's Coaches Room | Bathroom Faucet | 4/1/2021 05:32 | 4/12/2021 16:35 | 70167859081 | Lead | 2.0 | 15 | ug/L | |
| CHS-01-BF-P-88 | Girl's PE Office Bathroom | Bathroom Faucet | 4/1/2021 05:34 | 4/12/2021 16:39 | 70167859082 | Lead | 15.3 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-89 | Girl's Coaches Room | Bathroom Faucet | 4/1/2021 05:34 | 4/12/2021 16:40 | 70167859083 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-90 | L - Fountain by Girl's Locker | Water Fountain | 4/1/2021 05:35 | 4/12/2021 16:41 | 70167859084 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-DW-P-91 | R - Fountain by Girl's Locker | Water Fountain | 4/1/2021 05:35 | 4/12/2021 16:42 | 70167859085 | Lead | <1.0 | 15 | ug/L | |
| CHS-01-BF-P-92 | Girl's Locker Bathroom - Far L | Bathroom Faucet | 4/1/2021 05:37 | 4/12/2021 16:43 | 70167859086 | Lead | 3.7 | 15 | ug/L | |
| CHS-01-BF-P-93 | Girl's Locker Bathroom - L Center | Bathroom Faucet | 4/1/2021 05:37 | 4/12/2021 16:44 | 70167859087 | Lead | 11.3 | 15 | ug/L | |
| CHS-01-BF-P-94 | Girl's Locker Bathroom - R Center | Bathroom Faucet | 4/1/2021 05:37 | 4/12/2021 16:45 | 70167859088 | Lead | 4.3 | 15 | ug/L | |
| CHS-01-BF-P-95 | Girl's Locker Bathroom - Far R | Bathroom Faucet | 4/1/2021 05:37 | 4/12/2021 16:46 | 70167859089 | Lead | 29.3 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-96 | Varsity Officials Men's/Women's - L | Bathroom Faucet | 4/1/2021 05:40 | 4/12/2021 16:47 | 70167859090 | Lead | 5.3 | 15 | ug/L | |
| CHS-01-BF-P-97 | Varsity Officials Men's/Women's - C | Bathroom Faucet | 4/1/2021 05:40 | 4/12/2021 16:48 | 70167859091 | Lead | 5.5 | 15 | ug/L | |
| CHS-01-BF-P-98 | Varsity Officials Men's/Women's - R | Bathroom Faucet | 4/1/2021 05:40 | 4/12/2021 16:53 | 70167859092 | Lead | 57.4 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-99 | JV Officials Men's/Women's - L | Bathroom Faucet | 4/1/2021 05:40 | 4/12/2021 16:53 | 70167859093 | Lead | 21.5 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-100 | JV Officials Men's/Women's - 2nd | Bathroom Faucet | 4/1/2021 05:40 | 4/12/2021 16:54 | 70167859094 | Lead | 20.0 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-01-BF-P-101 | JV Officials Men's/Women's - 3rd | Bathroom Faucet | 4/1/2021 05:41 | 4/12/2021 16:55 | 70167859095 | Lead | 9.4 | 15 | ug/L | |

| Sample Identification # | Location | Outlet Description | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | NYSDOH Action Level | Units | Remediation Actions |
|-------------------------|-------------------------------------|--------------------|---------------------|--------------------|--------------|---------|---------|---------------------|-------|--|
| CHS-01-BF-P-102 | JV Officials Men's/Women's - 4th | Bathroom Faucet | 4/1/2021 05:41 | 4/12/2021 16:56 | 70167859096 | Lead | 8.8 | 15 | ug/L | |
| CHS-01-BF-P-103 | JV Officials Men's/Women's - 5th | Bathroom Faucet | 4/1/2021 05:41 | 4/12/2021 16:57 | 70167859097 | Lead | 19.2 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-02-BF-P-104 | Boy's Room by S212 - L | Bathroom Faucet | 4/1/2021 05:07 | 4/12/2021 16:58 | 70167859098 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-BF-P-105 | Boy's Room by S212 - R | Bathroom Faucet | 4/1/2021 05:07 | 4/12/2021 16:59 | 70167859099 | Lead | 2.4 | 15 | ug/L | |
| CHS-02-DW-P-106 | Fountain by S211 | Water Fountain | 4/1/2021 05:09 | 4/12/2021 17:02 | 70167859100 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-SF-P-107 | S222 - Faculty - Sink | Sink Faucet | 4/1/2021 05:11 | 4/12/2021 17:05 | 70167859101 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-DW-P-108 | Fountain by S203A | Water Fountain | 4/1/2021 05:12 | 4/12/2021 17:08 | 70167859102 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-BF-P-109 | Girl's Room by S205 - L | Bathroom Faucet | 4/1/2021 05:13 | 4/12/2021 17:09 | 70167859103 | Lead | 1.1 | 15 | ug/L | |
| CHS-02-BF-P-110 | Girl's Room by S205 - R | Bathroom Faucet | 4/1/2021 05:13 | 4/12/2021 17:10 | 70167859104 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-BF-P-112 | Boy's Room by S311 - L | Bathroom Faucet | 4/1/2021 05:15 | 4/12/2021 17:11 | 70167859105 | Lead | 5.4 | 15 | ug/L | |
| CHS-03-BF-P-113 | Boy's Room by S311 - R | Bathroom Faucet | 4/1/2021 05:15 | 4/12/2021 17:13 | 70167859106 | Lead | 38.6 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-03-DW-P-114 | Fountain by S310 | Water Fountain | 4/1/2021 05:16 | 4/12/2021 17:14 | 70167859107 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-BF-P-115 | Left Faculty Restroom by S312 | Bathroom Faucet | 4/1/2021 05:17 | 4/12/2021 17:15 | 70167859108 | Lead | 1.6 | 15 | ug/L | |
| CHS-03-BF-P-116 | Right Faculty Restroom by S312 | Bathroom Faucet | 4/1/2021 05:18 | 4/12/2021 17:16 | 70167859109 | Lead | 1.2 | 15 | ug/L | |
| CHS-03-SF-P-117 | 3rd Fl Faculty Area Pantry Sink | Sink Faucet | 4/1/2021 05:19 | 4/12/2021 17:17 | 70167859110 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-DW-P-118 | Fountain by S303 | Water Fountain | 4/1/2021 05:21 | 4/12/2021 17:18 | 70167859111 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-BF-P-119 | Women's Room by S304 - L | Bathroom Faucet | 4/1/2021 05:21 | 4/12/2021 17:21 | 70167859112 | Lead | 3.2 | 15 | ug/L | |
| CHS-03-BF-P-120 | Women's Room by S304 - R | Bathroom Faucet | 4/1/2021 05:22 | 4/12/2021 17:22 | 70167859113 | Lead | 3.1 | 15 | ug/L | |
| CHS-02-SF-P-121 | Library Work Room Sink | Sink Faucet | 4/1/2021 05:23 | 4/12/2021 17:25 | 70167859114 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-SF-P-122 | Library Work Room Women's Rm | Bathroom Faucet | 4/1/2021 05:24 | 4/12/2021 17:26 | 70167859115 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-SF-P-123 | Library Work Room Men's Room | Bathroom Faucet | 4/1/2021 05:24 | 4/12/2021 17:27 | 70167859116 | Lead | 1.4 | 15 | ug/L | |
| CHS-02-DW-P-125 | N222 Faculty Sink | Sink Faucet | 4/1/2021 05:27 | 4/12/2021 17:28 | 70167859117 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-BF-P-126 | Boy's Room by N213 - L | Bathroom Faucet | 4/1/2021 05:29 | 4/12/2021 17:29 | 70167859118 | Lead | 6.0 | 15 | ug/L | |
| CHS-02-BF-P-127 | Boy's Room by N213 - R | Bathroom Faucet | 4/1/2021 05:29 | 4/12/2021 17:30 | 70167859119 | Lead | 1.9 | 15 | ug/L | |
| CHS-02-DW-P-128 | Fountain by N211 | Water Fountain | 4/1/2021 05:30 | 4/12/2021 17:30 | 70167859120 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-BF-P-129 | Girl's Room by N205 - L | Bathroom Faucet | 4/1/2021 05:32 | 4/12/2021 17:33 | 70167859121 | Lead | 1.6 | 15 | ug/L | |
| CHS-02-BF-P-130 | Girl's Room by N205 - R | Bathroom Faucet | 4/1/2021 05:32 | 4/12/2021 17:38 | 70167859122 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-BF-P-131 | Fountain by N203 | Water Fountain | 4/1/2021 05:33 | 4/12/2021 17:39 | 70167859123 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-BF-P-132 | 3rd Fl North Left Faculty Bathroom | Bathroom Faucet | 4/1/2021 05:35 | 4/12/2021 17:40 | 70167859124 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-BF-P-133 | 3rd Fl North Right Faculty Bathroom | Bathroom Faucet | 4/1/2021 05:36 | 4/12/2021 17:41 | 70167859125 | Lead | 1.8 | 15 | ug/L | |
| CHS-03-BF-P-134 | Boy's Room by N311 - L | Bathroom Faucet | 4/1/2021 05:37 | 4/12/2021 17:42 | 70167859126 | Lead | 140 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |

| Sample Identification # | Location | Outlet Description | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | NYSDOH Action Level | Units | Remediation Actions |
|-------------------------|-------------------------------------|-----------------------|---------------------|--------------------|--------------|---------|---------|---------------------|-------|--|
| CHS-03-BF-P-135 | Boy's Room by N311 - R | Bathroom Faucet | 4/1/2021 05:37 | 4/12/2021 17:43 | 70167859127 | Lead | 37.3 | 15 | ug/L | Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.) |
| CHS-03-BF-P-136 | Fountain by N310 | Water Fountain | 4/1/2021 05:38 | 4/12/2021 17:44 | 70167859128 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-SF-P-137 | 3rd Floor North Faculty Pantry Sink | Sink Faucet | 4/1/2021 05:42 | 4/12/2021 17:45 | 70167859129 | Lead | <1.0 | 15 | ug/L | |
| CHS-03-BF-P-138 | Girl's Room by N304 - L | Bathroom Faucet | 4/1/2021 05:39 | 4/12/2021 17:47 | 70167859130 | Lead | 2.2 | 15 | ug/L | |
| CHS-03-BF-P-139 | Girl's Room by N304 - R | Bathroom Faucet | 4/1/2021 05:39 | 4/12/2021 17:48 | 70167859131 | Lead | 5.8 | 15 | ug/L | |
| CHS-03-DW-P-140 | Fountain by N303 | Water Fountain | 4/1/2021 05:40 | 4/12/2021 17:51 | 70167859132 | Lead | <1.0 | 15 | ug/L | |
| CHS-02-BF-P-141 | 2nd Floor C-Wing Girl's Rm - L | Bathroom Faucet | 4/1/2021 05:45 | 4/12/2021 17:52 | 70167859133 | Lead | 1.2 | 15 | ug/L | |
| CHS-02-BF-P-142 | 2nd Floor C-Wing Girl's Rm - C | Bathroom Faucet | 4/1/2021 05:45 | 4/12/2021 17:53 | 70167859134 | Lead | 3.2 | 15 | ug/L | |
| CHS-02-BF-P-143 | 2nd Floor C-Wing Girl's Rm - R | Bathroom Faucet | 4/1/2021 05:45 | 4/12/2021 17:54 | 70167859135 | Lead | 7.7 | 15 | ug/L | |
| CHS-02-BF-P-144 | 2nd Floor C-Wing Boy's Rm - L | Bathroom Faucet | 4/1/2021 05:47 | 4/12/2021 17:55 | 70167859136 | Lead | 6.8 | 15 | ug/L | |
| CHS-02-BF-P-145 | 2nd Floor C-Wing Boy's Rm - C | Bathroom Faucet | 4/1/2021 05:47 | 4/12/2021 17:56 | 70167859137 | Lead | 6.1 | 15 | ug/L | |
| CHS-02-BF-P-146 | 2nd Floor C-Wing Boy's Rm - R | Bathroom Faucet | 4/1/2021 05:47 | 4/12/2021 17:59 | 70167859138 | Lead | 1.1 | 15 | ug/L | |
| CHS-01-SF-P-147 | Room C112 | Classroom Sink Faucet | 4/1/2021 05:55 | 4/12/2021 18:01 | 70167859140 | Lead | <1.0 | 15 | ug/L | |

NYSDOH Action Level for Lead of 15 ppb