

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
BT-02-BF-P-01	Womens Room Main Office	Bathroom Faucet	3/5/2021 05:34	3/11/2021 16:48	70164872001	Lead	2.4	15	ug/L	
BT-02-BF-P-02	Mens Room Main Office	Bathroom Faucet	3/5/2021 05:35	3/11/2021 16:49	70164872002	Lead	7.9	15	ug/L	
BT-02-CF-P-03	240	Classroom Sink Faucet	3/5/2021 05:36	3/11/2021 16:50	70164872003	Lead	3.3	15	ug/L	
BT-02-CF-P-05	260	Classroom Sink Faucet	3/5/2021 05:38	3/11/2021 16:51	70164872004	Lead	4.4	15	ug/L	
BT-02-CF-P-07	280	Classroom Sink Faucet	3/5/2021 05:40	3/11/2021 16:54	70164872005	Lead	1.1	15	ug/L	
BT-02-CF-P-09	300	Classroom Sink Faucet	3/5/2021 05:42	3/11/2021 16:55	70164872006	Lead	3.0	15	ug/L	
BT-02-CF-P-11	310	Classroom Sink Faucet	3/5/2021 05:42	3/11/2021 16:56	70164872007	Lead	2.8	15	ug/L	
BT-02-CF-P-13	290	Classroom Sink Faucet	3/5/2021 05:42	3/11/2021 16:57	70164872008	Lead	3.2	15	ug/L	
BT-02-CF-P-15	270	Classroom Sink Faucet	3/5/2021 05:38	3/11/2021 17:00	70164872009	Lead	1.9	15	ug/L	
BT-02-CF-P-17	250	Classroom Sink Faucet	3/5/2021 05:37	3/11/2021 17:01	70164872010	Lead	3.6	15	ug/L	
BT-02-BF-P-20	370	Bathroom Faucet	3/5/2021 05:47	3/11/2021 17:02	70164872011	Lead	<1.0	15	ug/L	
BT-02-CF-P-21	350	Classroom Sink Faucet	3/5/2021 05:47	3/11/2021 17:03	70164872012	Lead	<1.0	15	ug/L	
BT-02-CF-P-23	330	Classroom Sink Faucet	3/5/2021 05:45	3/11/2021 17:06	70164872013	Lead	4.4	15	ug/L	
BT-02-BF-P-24	Girls Room by Library L	Bathroom Faucet	3/5/2021 05:50	3/11/2021 17:07	70164872014	Lead	3.9	15	ug/L	
BT-02-BF-P-25	Girls Room by Library R	Bathroom Faucet	3/5/2021 05:50	3/11/2021 17:08	70164872015	Lead	<1.0	15	ug/L	
BT-02-BF-P-27	Boys Room by Library L	Bathroom Faucet	3/5/2021 05:52	3/11/2021 17:09	70164872016	Lead	4.4	15	ug/L	
BT-02-BF-P-28	Boys Room by Library R	Bathroom Faucet	3/5/2021 05:52	3/11/2021 17:10	70164872017	Lead	5.1	15	ug/L	
BT-02-SF-P-29	Library Office	Sink Faucet	3/5/2021 05:53	3/11/2021 17:12	70164872018	Lead	<1.0	15	ug/L	
BT-02-SF-P-30	160	Sink Faucet	3/5/2021 05:55	3/11/2021 17:17	70164872019	Lead	<1.0	15	ug/L	
BT-02-KF-P-31	Kitchen - Hand Washing	Kitchen Faucet	3/5/2021 05:56	3/11/2021 17:18	70164872020	Lead	<1.0	15	ug/L	
BT-02-KF-P-32	Kitchen - Food Prep	Kitchen Faucet	3/5/2021 05:56	3/11/2021 17:19	70164872021	Lead	<1.0	15	ug/L	
BT-02-KF-P-33	Kitchen - Steam Table	Kitchen Faucet	3/5/2021 05:57	3/11/2021 17:20	70164872022	Lead	<1.0	15	ug/L	
BT-02-DW-P-34	Water Fountain by Kitchen	Water Fountain	3/5/2021 06:00	3/11/2021 17:21	70164872023	Lead	1.6	15	ug/L	
BT-02-CF-P-35	120 - by Hallway Door	Classroom Sink Faucet	3/5/2021 06:03	3/11/2021 17:22	70164872024	Lead	5.2	15	ug/L	
BT-02-CF-P-36	120 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:03	3/11/2021 17:23	70164872025	Lead	2.8	15	ug/L	
BT-02-CF-P-37	90 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:12	3/11/2021 17:24	70164872026	Lead	10.0	15	ug/L	
BT-02-CF-P-39	90	Classroom Sink Faucet	3/5/2021 06:12	3/11/2021 17:25	70164872027	Lead	2.4	15	ug/L	
BT-02-CF-P-40	70 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:15	3/11/2021 17:26	70164872028	Lead	3.2	15	ug/L	
BT-02-CF-P-42	70	Classroom Sink Faucet	3/5/2021 06:15	3/11/2021 17:30	70164872029	Lead	11.1	15	ug/L	
BT-02-CF-P-43	50 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:18	3/11/2021 17:31	70164872030	Lead	<1.0	15	ug/L	
BT-02-CF-P-45	50	Classroom Sink Faucet	3/5/2021 06:18	3/11/2021 17:32	70164872031	Lead	8.7	15	ug/L	
BT-02-BF-P-46	Boys Room by Gym	Bathroom Faucet	3/5/2021 06:30	3/11/2021 17:33	70164872032	Lead	<1.0	15	ug/L	
BT-02-BF-P-49	Girls room by Gym	Bathroom Faucet	3/5/2021 06:29	3/11/2021 17:34	70164872033	Lead	<1.0	15	ug/L	
BT-02-CF-P-50	20 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:29	3/11/2021 17:35	70164872034	Lead	<1.0	15	ug/L	
BT-02-CF-P-51	20	Classroom Sink Faucet	3/5/2021 06:28	3/11/2021 17:36	70164872035	Lead	<1.0	15	ug/L	
BT-02-DW-P-52	20/40 Hallway Fountain	Water Fountain	3/5/2021 06:24	3/11/2021 17:37	70164872036	Lead	<1.0	15	ug/L	
BT-02-CF-P-53	40 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:21	3/11/2021 17:40	70164872037	Lead	<1.0	15	ug/L	
BT-02-CF-P-54	40	Classroom Sink Faucet	3/5/2021 06:27	3/11/2021 17:43	70164872038	Lead	1.3	15	ug/L	
BT-02-CF-P-55	41 - Food Lab	Classroom Sink Faucet	3/5/2021 06:23	3/11/2021 17:46	70164872039	Lead	1.3	15	ug/L	
BT-02-CF-P-56	60 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:19	3/11/2021 17:47	70164872040	Lead	2.8	15	ug/L	
BT-02-CF-P-58	60	Classroom Sink Faucet	3/5/2021 06:20	3/11/2021 17:48	70164872041	Lead	2.5	15	ug/L	
BT-02-CF-P-59	80 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:16	3/11/2021 17:49	70164872042	Lead	1.4	15	ug/L	
BT-02-CF-P-60	80	Classroom Sink Faucet	3/5/2021 06:17	3/11/2021 17:51	70164872043	Lead	3.3	15	ug/L	
BT-02-CF-P-61	100	Sink Faucet	3/5/2021 06:14	3/11/2021 17:53	70164872044	Lead	2.1	15	ug/L	
BT-02-BF-P-62	Nurses Office - Bathroom	Bathroom Faucet	3/5/2021 06:10	3/11/2021 17:53	70164872045	Lead	<1.0	15	ug/L	
BT-02-CF-P-63	Nurses Office	Sink Faucet	3/5/2021 06:10	3/11/2021 17:54	70164872046	Lead	<1.0	15	ug/L	
BT-02-DW-P-64	Nurses Office - Ice	Ice Machine	3/5/2021 06:11	3/11/2021 17:55	70164872047	Lead	1.6	15	ug/L	
BT-02-KF-P-35	Kitchen - Steamer Pot	Kitchen Faucet	3/5/2021 05:59	3/11/2021 17:56	70164872048	Lead	<1.0	15	ug/L	
BT-02-KF-P-66	Kitchen Sink - Left	Kitchen Faucet	3/5/2021 06:08	3/11/2021 17:59	70164872049	Lead	<1.0	15	ug/L	
BT-02-KF-P-67	Kitchen Sink - Right	Kitchen Faucet	3/5/2021 06:08	3/11/2021 18:00	70164872050	Lead	<1.0	15	ug/L	
BT-02-CF-P-68	30 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:26	3/11/2021 18:03	70164872051	Lead	<1.0	15	ug/L	
BT-02-CF-P-69	30 - Sink	Classroom Sink Faucet	3/5/2021 06:26	3/11/2021 18:04	70164872052	Lead	2.7	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
-------------------------	----------	--------------------	---------------------	--------------------	--------------	---------	---------	---------------------	-------	---------------------

NYSDOH Action Level for Lead of 15 ppb