

March 12, 2021

Paul Bickel  
East Greenbush Central School District  
29 Englewood Avenue  
East Greenbush, NY 12061

RE: Project: EAST GREENBUSH CSD  
Pace Project No.: 70164872

Dear Paul Bickel:

Enclosed are the analytical results for sample(s) received by the laboratory on March 05, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari  
nicolette.lovari@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Sam Beardsley, East Greenbush Central School District  
Paul Swieton, Rensselaer-Columbia-Greene Counties and  
BOCES



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

---

### **Pace Analytical Services Long Island**

Delaware Certification # NY10478

Virginia Certification # 460302

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

<b>Sample: BT-02-BF-P-01</b>		<b>Lab ID: 70164872001</b>	Collected: 03/05/21 05:34	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		03/11/21 16:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-BF-P-02		Lab ID: 70164872002	Collected: 03/05/21 05:35	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>7.9</b>	ug/L	1.0	1		03/11/21 16:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-03		Lab ID: 70164872003	Collected: 03/05/21 05:36	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.3</b>	ug/L	1.0	1		03/11/21 16:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-CF-P-05      Lab ID: 70164872004      Collected: 03/05/21 05:38      Received: 03/05/21 19:03      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>4.4</b>	ug/L	1.0	1		03/11/21 16:51	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD  
Pace Project No.: 70164872

Sample: BT-02-CF-P-07		Lab ID: 70164872005	Collected: 03/05/21 05:40	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		03/11/21 16:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-09		Lab ID: 70164872006	Collected: 03/05/21 05:42	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.0</b>	ug/L	1.0	1		03/11/21 16:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: <b>BT-02-CF-P-11</b>	Lab ID: <b>70164872007</b>	Collected: 03/05/21 05:42	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.8</b>	ug/L	1.0	1		03/11/21 16:56	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-CF-P-13</b>								
<b>Lab ID: 70164872008</b>								
Collected: 03/05/21 05:42 Received: 03/05/21 19:03 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>3.2</b>	ug/L	1.0	1		03/11/21 16:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: <b>BT-02-CF-P-15</b>	Lab ID: <b>70164872009</b>	Collected: 03/05/21 05:38	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		03/11/21 17:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-CF-P-17</b>								
<b>Lab ID: 70164872010</b>								
Collected: 03/05/21 05:37								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>3.6</b>	ug/L	1.0	1		03/11/21 17:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-BF-P-20		Lab ID: 70164872011	Collected: 03/05/21 05:47	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-21	Lab ID: 70164872012	Collected: 03/05/21 05:47	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		03/11/21 17:03	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: <b>BT-02-CF-P-23</b>	Lab ID: <b>70164872013</b>	Collected: 03/05/21 05:45	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.4</b>	ug/L	1.0	1		03/11/21 17:06	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-BF-P-24	Lab ID: 70164872014	Collected: 03/05/21 05:50	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>3.9</b>	ug/L	1.0	1		03/11/21 17:07	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-BF-P-25		Lab ID: 70164872015	Collected: 03/05/21 05:50	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: <b>BT-02-BF-P-27</b>	Lab ID: <b>70164872016</b>	Collected: 03/05/21 05:52	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.4</b>	ug/L	1.0	1		03/11/21 17:09	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-BF-P-28		Lab ID: 70164872017	Collected: 03/05/21 05:52	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.1</b>	ug/L	1.0	1		03/11/21 17:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-SF-P-29		Lab ID: 70164872018	Collected: 03/05/21 05:53	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-SF-P-30		Lab ID: 70164872019		Collected: 03/05/21 05:55		Received: 03/05/21 19:03		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/11/21 17:17	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-KF-P-31		Lab ID: 70164872020	Collected: 03/05/21 05:56	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

<b>Sample: BT-02-KF-P-32</b>		<b>Lab ID: 70164872021</b>	Collected: 03/05/21 05:56	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-KF-P-33		Lab ID: 70164872022	Collected: 03/05/21 05:57	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-DW-P-34		Lab ID: 70164872023	Collected: 03/05/21 06:00	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.6</b>	ug/L	1.0	1		03/11/21 17:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-CF-P-35</b>								
<b>Lab ID: 70164872024</b>								
Collected: 03/05/21 06:03    Received: 03/05/21 19:03    Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>5.2</b>	ug/L	1.0	1		03/11/21 17:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-36		Lab ID: 70164872025	Collected: 03/05/21 06:03	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.8</b>	ug/L	1.0	1		03/11/21 17:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-37		Lab ID: 70164872026	Collected: 03/05/21 06:12	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>10.0</b>	ug/L	1.0	1		03/11/21 17:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

<b>Sample: BT-02-CF-P-39</b>		<b>Lab ID: 70164872027</b>	Collected: 03/05/21 06:12	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		03/11/21 17:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-40		Lab ID: 70164872028	Collected: 03/05/21 06:15	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.2</b>	ug/L	1.0	1		03/11/21 17:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-42		Lab ID: 70164872029	Collected: 03/05/21 06:15	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	11.1	ug/L	1.0	1		03/11/21 17:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-43		Lab ID: 70164872030	Collected: 03/05/21 06:18	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-45		Lab ID: 70164872031	Collected: 03/05/21 06:18	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>8.7</b>	ug/L	1.0	1		03/11/21 17:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-BF-P-46</b>								
<b>Lab ID: 70164872032</b>								
Collected: 03/05/21 06:30								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		03/11/21 17:33	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-BF-P-49		Lab ID: 70164872033	Collected: 03/05/21 06:29	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-50		Lab ID: 70164872034	Collected: 03/05/21 06:29	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: <b>BT-02-CF-P-51</b>	Lab ID: <b>70164872035</b>	Collected: 03/05/21 06:28	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		03/11/21 17:36	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-DW-P-52		Lab ID: 70164872036	Collected: 03/05/21 06:24	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-53	Lab ID: 70164872037	Collected: 03/05/21 06:21	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/11/21 17:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-54	Lab ID: 70164872038	Collected: 03/05/21 06:27	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	1.3	ug/L	1.0	1		03/11/21 17:43	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-55		Lab ID: 70164872039	Collected: 03/05/21 06:23	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		03/11/21 17:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-56	Lab ID: 70164872040	Collected: 03/05/21 06:19	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>2.8</b>	ug/L	1.0	1		03/11/21 17:47	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-58	Lab ID: 70164872041	Collected: 03/05/21 06:20	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>2.5</b>	ug/L	1.0	1		03/11/21 17:48	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-CF-P-59</b>								
<b>Lab ID: 70164872042</b>								
Collected: 03/05/21 06:16								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.4	ug/L	1.0	1		03/11/21 17:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-60		Lab ID: 70164872043	Collected: 03/05/21 06:17	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.3</b>	ug/L	1.0	1		03/11/21 17:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-CF-P-61</b>								
<b>Lab ID: 70164872044</b>								
Collected: 03/05/21 06:14 Received: 03/05/21 19:03 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		03/11/21 17:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-BF-P-62		Lab ID: 70164872045	Collected: 03/05/21 06:10	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-63		Lab ID: 70164872046	Collected: 03/05/21 06:10	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 17:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: <b>BT-02-DW-P-64</b>	Lab ID: <b>70164872047</b>	Collected: 03/05/21 06:11	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.6</b>	ug/L	1.0	1		03/11/21 17:55	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-KF-P-35</b>								
<b>Lab ID: 70164872048</b>								
Collected: 03/05/21 05:59								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		03/11/21 17:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: <b>BT-02-KF-P-66</b>	Lab ID: <b>70164872049</b>	Collected: 03/05/21 06:08	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>&lt;1.0</b>	ug/L	1.0	1		03/11/21 17:59	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BT-02-KF-P-67      Lab ID: 70164872050      Collected: 03/05/21 06:08      Received: 03/05/21 19:03      Matrix: Drinking Water</b>								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		03/11/21 18:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-68		Lab ID: 70164872051	Collected: 03/05/21 06:26	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/11/21 18:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Sample: BT-02-CF-P-69		Lab ID: 70164872052	Collected: 03/05/21 06:26	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.7</b>	ug/L	1.0	1		03/11/21 18:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: EAST GREENBUSH CSD  
Pace Project No.: 70164872

QC Batch:	199797	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70164872001, 70164872002, 70164872003, 70164872004, 70164872005, 70164872006, 70164872007, 70164872008, 70164872009, 70164872010, 70164872011, 70164872012, 70164872013, 70164872014, 70164872015, 70164872016, 70164872017

METHOD BLANK: 982628 Matrix: Water  
Associated Lab Samples: 70164872001, 70164872002, 70164872003, 70164872004, 70164872005, 70164872006, 70164872007, 70164872008, 70164872009, 70164872010, 70164872011, 70164872012, 70164872013, 70164872014, 70164872015, 70164872016, 70164872017

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/11/21 16:40	

LABORATORY CONTROL SAMPLE: 982629

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.2	104	85-115	

MATRIX SPIKE SAMPLE: 982631

Parameter	Units	70164870061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.0	50	61.6	119	70-130	

MATRIX SPIKE SAMPLE: 982633

Parameter	Units	70164872008 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.2	50	60.5	114	70-130	

SAMPLE DUPLICATE: 982630

Parameter	Units	70164870061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.0	2.0	1	

SAMPLE DUPLICATE: 982632

Parameter	Units	70164872008 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.2	3.2	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA

Project: EAST GREENBUSH CSD  
Pace Project No.: 70164872

QC Batch:	199799	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70164872018, 70164872019, 70164872020, 70164872021, 70164872022, 70164872023, 70164872024, 70164872025, 70164872026, 70164872027, 70164872028, 70164872029, 70164872030, 70164872031, 70164872032, 70164872033, 70164872034, 70164872035, 70164872036, 70164872037

METHOD BLANK: 982635 Matrix: Water  
Associated Lab Samples: 70164872018, 70164872019, 70164872020, 70164872021, 70164872022, 70164872023, 70164872024, 70164872025, 70164872026, 70164872027, 70164872028, 70164872029, 70164872030, 70164872031, 70164872032, 70164872033, 70164872034, 70164872035, 70164872036, 70164872037

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/11/21 17:10	

LABORATORY CONTROL SAMPLE: 982636

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.2	104	85-115	

MATRIX SPIKE SAMPLE: 982638

Parameter	Units	70164872018 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.2	113	70-130	

MATRIX SPIKE SAMPLE: 982640

Parameter	Units	70164872028 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.2	50	59.5	113	70-130	

SAMPLE DUPLICATE: 982637

Parameter	Units	70164872018 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 982639

Parameter	Units	70164872028 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.2	3.3	4	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: EAST GREENBUSH CSD  
Pace Project No.: 70164872

QC Batch: 199800      Analysis Method: EPA 200.8  
QC Batch Method: EPA 200.8      Analysis Description: 200.8 MET No Prep Drinking Water  
Laboratory: Pace Analytical Services - Melville  
Associated Lab Samples: 70164872038, 70164872039, 70164872040, 70164872041, 70164872042, 70164872043, 70164872044, 70164872045, 70164872046, 70164872047, 70164872048, 70164872049, 70164872050, 70164872051, 70164872052

METHOD BLANK: 982642      Matrix: Water  
Associated Lab Samples: 70164872038, 70164872039, 70164872040, 70164872041, 70164872042, 70164872043, 70164872044, 70164872045, 70164872046, 70164872047, 70164872048, 70164872049, 70164872050, 70164872051, 70164872052

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/11/21 17:41	

LABORATORY CONTROL SAMPLE: 982643

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	53.0	106	85-115	

MATRIX SPIKE SAMPLE: 982645

Parameter	Units	70164872038 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.3	50	58.7	115	70-130	

MATRIX SPIKE SAMPLE: 982647

Parameter	Units	70164872048 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.8	115	70-130	

SAMPLE DUPLICATE: 982644

Parameter	Units	70164872038 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.3	1.3	1	

SAMPLE DUPLICATE: 982646

Parameter	Units	70164872048 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALIFIERS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70164872001	BT-02-BF-P-01	EPA 200.8	199797		
70164872002	BT-02-BF-P-02	EPA 200.8	199797		
70164872003	BT-02-CF-P-03	EPA 200.8	199797		
70164872004	BT-02-CF-P-05	EPA 200.8	199797		
70164872005	BT-02-CF-P-07	EPA 200.8	199797		
70164872006	BT-02-CF-P-09	EPA 200.8	199797		
70164872007	BT-02-CF-P-11	EPA 200.8	199797		
70164872008	BT-02-CF-P-13	EPA 200.8	199797		
70164872009	BT-02-CF-P-15	EPA 200.8	199797		
70164872010	BT-02-CF-P-17	EPA 200.8	199797		
70164872011	BT-02-BF-P-20	EPA 200.8	199797		
70164872012	BT-02-CF-P-21	EPA 200.8	199797		
70164872013	BT-02-CF-P-23	EPA 200.8	199797		
70164872014	BT-02-BF-P-24	EPA 200.8	199797		
70164872015	BT-02-BF-P-25	EPA 200.8	199797		
70164872016	BT-02-BF-P-27	EPA 200.8	199797		
70164872017	BT-02-BF-P-28	EPA 200.8	199797		
70164872018	BT-02-SF-P-29	EPA 200.8	199799		
70164872019	BT-02-SF-P-30	EPA 200.8	199799		
70164872020	BT-02-KF-P-31	EPA 200.8	199799		
70164872021	BT-02-KF-P-32	EPA 200.8	199799		
70164872022	BT-02-KF-P-33	EPA 200.8	199799		
70164872023	BT-02-DW-P-34	EPA 200.8	199799		
70164872024	BT-02-CF-P-35	EPA 200.8	199799		
70164872025	BT-02-CF-P-36	EPA 200.8	199799		
70164872026	BT-02-CF-P-37	EPA 200.8	199799		
70164872027	BT-02-CF-P-39	EPA 200.8	199799		
70164872028	BT-02-CF-P-40	EPA 200.8	199799		
70164872029	BT-02-CF-P-42	EPA 200.8	199799		
70164872030	BT-02-CF-P-43	EPA 200.8	199799		
70164872031	BT-02-CF-P-45	EPA 200.8	199799		
70164872032	BT-02-BF-P-46	EPA 200.8	199799		
70164872033	BT-02-BF-P-49	EPA 200.8	199799		
70164872034	BT-02-CF-P-50	EPA 200.8	199799		
70164872035	BT-02-CF-P-51	EPA 200.8	199799		
70164872036	BT-02-DW-P-52	EPA 200.8	199799		
70164872037	BT-02-CF-P-53	EPA 200.8	199799		
70164872038	BT-02-CF-P-54	EPA 200.8	199800		
70164872039	BT-02-CF-P-55	EPA 200.8	199800		
70164872040	BT-02-CF-P-56	EPA 200.8	199800		
70164872041	BT-02-CF-P-58	EPA 200.8	199800		
70164872042	BT-02-CF-P-59	EPA 200.8	199800		
70164872043	BT-02-CF-P-60	EPA 200.8	199800		
70164872044	BT-02-CF-P-61	EPA 200.8	199800		
70164872045	BT-02-BF-P-62	EPA 200.8	199800		
70164872046	BT-02-CF-P-63	EPA 200.8	199800		
70164872047	BT-02-DW-P-64	EPA 200.8	199800		
70164872048	BT-02-KF-P-35	EPA 200.8	199800		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: EAST GREENBUSH CSD

Pace Project No.: 70164872

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70164872049	BT-02-KF-P-66	EPA 200.8	199800		
70164872050	BT-02-KF-P-67	EPA 200.8	199800		
70164872051	BT-02-CF-P-68	EPA 200.8	199800		
70164872052	BT-02-CF-P-69	EPA 200.8	199800		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMATION

Name: East Greenbush Central School District  
 Address: 29 Englewood Avenue, East Greenbush, NY 12061  
 Client Rep: Paul Bickel 518-207-2521

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Bell Top Elementary School  
 BLDG ADDRESS: 39 Reynolds Road, Troy, NY 12180  
 CONTACT NAME & NUMBERS: Paul Bickel 518-207-2521

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

Date of Sampling: 3/4/2020  
 Samples Taken By: Tracey Catalfamo  
 District Staff: Rir

WO#: 70164872



SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Information										
				Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)	
1	BT-02-BF-P-01	Womens Room Main Office	Bathroom Faucet			X	5:34							
2	BT-02-BF-P-02	Mens Room Main Office	Bathroom Faucet			X	5:35							
3	BT-02-CF-P-03	240	Classroom Sink Faucet			X	5:36							
4	BT-02-DW-P-04	240	Water Fountain	Shut off - COVID		X								
5	BT-02-CF-P-05	260	Classroom Sink Faucet			X	5:38							
6	BT-02-DW-P-06	260	Water Fountain	Shut off - COVID		X								
7	BT-02-CF-P-07	280	Classroom Sink Faucet			X	5:40							
8	BT-02-DW-P-08	280	Water Fountain	Shut off - COVID		X								
9	BT-02-CF-P-09	300	Classroom Sink Faucet			X	5:42							
10	BT-02-DW-P-10	300	Water Fountain	Shut off - COVID		X								
11	BT-02-CF-P-11	310	Classroom Sink Faucet			X	5:42							
12	BT-02-DW-P-12	310	Water Fountain	Shut off - COVID		X								
13	BT-02-CF-P-13	290	Classroom Sink Faucet			X	5:42							
14	BT-02-DW-P-14	290	Water Fountain	Shut off - COVID		X								
15	BT-02-CF-P-15	270	Classroom Sink Faucet			X	5:38							
16	BT-02-DW-P-16	270	Water Fountain	Shut off - COVID		X								
17	BT-02-CF-P-17	250	Classroom Sink Faucet			X	5:37							
18	BT-02-DW-P-18	250	Water Fountain	Shut off - COVID		X								
19	BT-01-DW-P-19	370	Water Fountain	Shut off - COVID		X								
20	BT-01-BF-P-20	370	Bathroom Faucet			X	5:47							
21	BT-01-CF-P-21	350	Classroom Sink Faucet			X	5:47							
22	BT-01-DW-P-22	350	Water Fountain	Shut off - COVID		X								
23	BT-01-CF-P-23	330	Classroom Sink Faucet			X	5:45							
24	BT-01-BF-P-24	Girls Room by Library L	Bathroom Faucet			X	5:50							
25	BT-01-BF-P-25	Girls Room by Library R	Bathroom Faucet			X	5:50							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: <i>[Signature]</i>	Received By: <i>[Signature]</i> age	Time: 9:00	Date: 3/4/21
		12:00	3/5/21
		14:03	3/5/21

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services  
 1570 Helderberg Ave.  
 Rotterdam, NY 12306

Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: East Greenbush Central School District  
 Address: 29 Englewood Avenue, East Greenbush, NY 12061  
 Client Rep: Paul Bickel 518-207-2521

Date of Sampling: 3/4/2020  
 Samples Taken By: Tracey Catalfamo  
 District Staff: Rick Cotrona

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Bell Top Elementary School  
 BLDG ADDRESS: 39 Reynolds Road, Troy, NY 12180  
 CONTACT NAME & NUMBERS: Paul Bickel 518-207-2521

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
26	BT-01-DW-P-26	Water Fountain by Library	Water Fountain	Shut off - COVID		X							
27	BT-01-BF-P-27	Boys Room by Library L	Bathroom Faucet			X	5:52						
28	BT-01-BF-P-28	Boys Room by Library R	Bathroom Faucet			X	5:52						
29	BT-01-SF-P-29	Library Office	Sink Faucet			X	5:53						
30	BT-02-SF-P-30	160	Sink Faucet			X	5:53						
31	BT-02-KF-P-31	Kitchen - Hand Washing	Kitchen Faucet			X	5:56						
32	BT-02-KF-P-32	Kitchen - Food Prep	Kitchen Faucet			X	5:56						
33	BT-02-KF-P-33	Kitchen - Steam Table	Kitchen Faucet			X	5:57						
34	BT-02-DW-P-34	Water Fountain by Kitchen	Water Fountain			X	6:00						
35	BT-01-CF-P-35	120 - by Hallway Door	Classroom Sink Faucet			X	6:03						
36	BT-01-CF-P-36	120 - Outside Bathroom	Classroom Sink Faucet			X	6:03						
37	BT-02-CF-P-37	90 - Outside Bathroom	Classroom Sink Faucet			X	6:12						
38	BT-02-DW-P-38	90	Water Fountain	Shut off - COVID		X							
39	BT-02-CF-P-39	90	Classroom Sink Faucet			X	6:12						
40	BT-02-CF-P-40	70 - Outside Bathroom	Classroom Sink Faucet			X	6:15						
41	BT-02-DW-P-41	70	Water Fountain	Shut off - COVID		X							
42	BT-02-CF-P-42	70	Classroom Sink Faucet			X	6:15						
43	BT-02-CF-P-43	50 - Outside Bathroom	Classroom Sink Faucet			X	6:18						
44	BT-02-DW-P-44	50	Water Fountain	Shut off - COVID		X							
45	BT-02-CF-P-45	50	Classroom Sink Faucet			X	6:18						
46	BT-02-BF-P-46	Boys Room by Gym	Bathroom Faucet			X	6:30						
47	BT-02-DW-P-47	Fountain Boys Room Side	Water Fountain	Shut off - COVID		X							
48	BT-02-DW-P-48	Fountain Girls Room Side	Water Fountain	Shut off - COVID		X							
49	BT-02-BF-P-49	Girls room by Gym	Bathroom Faucet			X	6:24						
50	BT-02-CF-P-50	20 - Outside Bathroom	Classroom Sink Faucet			X	6:24						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: 	Received By:  PALZ	Time: 09:03	to Date: 3/5/21
		12:00	3/5/21

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services  
 1570 Helderberg Ave.  
 Rotterdam, NY 12306  
 Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com  
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: East Greenbush Central School District  
 Address: 29 Englewood Avenue, East Greenbush, NY 12061  
 Client Rep: Paul Bickel 518-207-2521

Date of Sampling: 3/4/2020  
 Samples Taken By: Tracey Catalfamo  
 District Staff: Rick Cotrona

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Bell Top Elementary School  
 BLDG ADDRESS: 39 Reynolds Road, Troy, NY 12180  
 CONTACT NAME & NUMBERS: Paul Bickel 518-207-2521



(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Information										
				Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)	
51	BT-02-CF-P-51	20	Classroom Sink Faucet			X	6:28							
52	BT-02-DW-P-52	20/40 Hallway Fountain	Water Fountain			X	6:27							
53	BT-02-CF-P-53	40 - Outside Bathroom	Classroom Sink Faucet			X	6:21							
54	BT-02-CF-P-54	40	Classroom Sink Faucet			X	6:27							
55	BT-02-CF-P-55	41 - Food Lab	Classroom Sink Faucet			X	6:23							
56	BT-02-CF-P-56	60 - Outside Bathroom	Classroom Sink Faucet			X	6:19							
57	BT-02-DW-P-57	60	Water Fountain	Shut off - COVID		X								
58	BT-02-CF-P-58	60	Classroom Sink Faucet			X	6:20							
59	BT-02-CF-P-59	80 - Outside Bathroom	Classroom Sink Faucet			X	6:16							
60	BT-02-CF-P-60	80	Classroom Sink Faucet			X	6:17							
61	BT-02-CF-P-61	100	Sink Faucet			X	6:14							
62	BT-02-BF-P-62	Nurses Office - Bathroom	Bathroom Faucet			X	6:10							
63	BT-02-CF-P-63	Nurses Office	Sink Faucet			X	6:10							
64	BT-02-DW-P-64	Nurses Office - Ice	Ice Machine			X	6:11							
65	BT-02-KF-P-35	Kitchen - Steamer Pot	Kitchen Faucet			X	5:59							
66	BT-02-KF-P-66	Kitchen Sink (left)	Kitchen Faucet			X	6:08							
67	BT-02-KF-P-67	Kitchen Sink (right)	Kitchen Faucet			X	6:08							
68	BT-02-CF-P-68	30 - Outside bathroom	Classroom Sink Faucet			X	6:26							
69	BT-02-CF-P-69	30 - sink	Classroom Sink Faucet			X	6:26							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: 	Received By:  PACE	Time: 4:12	Date: 3/5/20
		19:03	3/5/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services  
 1570 Helderberg Ave.  
 Rotterdam, NY 12306  
 Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com  
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



# Sample Condition Upon Rec

# WO#: 70164872

Client Name: \_\_\_\_\_

Project: \_\_\_\_\_

PM: NML

Due Date: 03/22/21

CLIENT: QUESTAR

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  OtherTracking #: \_\_\_\_\_ *N/A*Custody Seal on Cooler/Box Present:  Yes  No    Seals intact:  Yes  NoPacking Material:  Bubble Wrap  Bubble Bags  Ziploc  None  OtherThermometer Used: TH091    Correction Factor: +0.0Cooler Temperature(°C): 17.7    Cooler Temperature Corrected(°C): 17.7

Temp should be above freezing to 6.0°C

USDA Regulated Soil {  N/A, water sample }Temperature Blank Present:  Yes  NoType of Ice: Wet Blue None Samples on ice, cooling process has begun

Date/Time 5035A kits placed in freezer \_\_\_\_\_

Date and Initials of person examining contents: KW 3/5/21Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  NoDid samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID, Matrix: <u>SL WT OIL</u>		
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>HCO25486</u>		Sample # <u>64</u> spiked with 2ml of HNO <sub>3</sub>
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis		Initial when completed: <u>MN</u> Lot # of added preservative: <u>171939</u> Date/Time preservative added: <u>3/6/21 17:58</u>
Samples checked for dechlorination: KI starch test strips Lot #	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #		
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____		

Client Notification/ Resolution: \_\_\_\_\_

Field Data Required? \_\_\_\_\_

Y / N

Person Contacted: \_\_\_\_\_

Date/Time: \_\_\_\_\_

Comments/ Resolution: \_\_\_\_\_