

March 16, 2021

Paul Bickel
East Greenbush Central School District
29 Englewood Avenue
East Greenbush, NY 12061

RE: Project: EAST GREENBUSH CSD
Pace Project No.: 70164875

Dear Paul Bickel:

Enclosed are the analytical results for sample(s) received by the laboratory on March 05, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari
nicolette.lovari@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Sam Beardsley, East Greenbush Central School District
Paul Swieton, Rensselaer-Columbia-Greene Counties and
BOCES



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Pace Analytical Services Long Island

Delaware Certification # NY10478

Virginia Certification # 460302

Delaware Certification # NY10478

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-01		Lab ID: 70164875001	Collected: 03/05/21 05:34	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	19.8	ug/L	1.0	1		03/15/21 11:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD
Pace Project No.: 70164875

Sample: DPS-01-SF-P-03	Lab ID: 70164875002	Collected: 03/05/21 05:37	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	10.4	ug/L	1.0	1		03/15/21 11:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD
Pace Project No.: 70164875

Sample: DPS-01-BF-P-04		Lab ID: 70164875003	Collected: 03/05/21 05:44	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.3	ug/L	1.0	1		03/15/21 11:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-05	Lab ID: 70164875004	Collected: 03/05/21 05:44	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	7.9	ug/L	1.0	1		03/15/21 11:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-06	Lab ID: 70164875005	Collected: 03/05/21 05:45	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.5	ug/L	1.0	1		03/15/21 11:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-07	Lab ID: 70164875006	Collected: 03/05/21 05:50	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	10.5	ug/L	1.0	1		03/15/21 11:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-08		Lab ID: 70164875007	Collected: 03/05/21 05:50	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	26.9	ug/L	1.0	1		03/15/21 11:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-BF-P-10								
Lab ID: 70164875008								
Collected: 03/05/21 05:50								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	9.0	ug/L	1.0	1		03/15/21 12:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-SF-P-11	Lab ID: 70164875009	Collected: 03/05/21 05:54	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	7.9	ug/L	1.0	1		03/15/21 12:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-14								
Lab ID: 70164875010								
Collected: 03/05/21 05:57								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	8.5	ug/L	1.0	1		03/15/21 12:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-15	Lab ID: 70164875011	Collected: 03/05/21 05:57	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	19.5	ug/L	1.0	1		03/15/21 12:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-BF-P-16								
Lab ID: 70164875012								
Collected: 03/05/21 05:59								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	12.5	ug/L	1.0	1		03/15/21 12:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-BF-P-17								
Lab ID: 70164875013								
Collected: 03/05/21 05:59								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	22.0	ug/L	1.0	1		03/15/21 12:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-BF-P-18								
Lab ID: 70164875014								
Collected: 03/05/21 05:59								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	22.8	ug/L	1.0	1		03/15/21 12:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-SF-P-19								
Lab ID: 70164875015								
Collected: 03/05/21 06:01								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	4.7	ug/L	1.0	1		03/15/21 12:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-KF-P-20								
Lab ID: 70164875016								
Collected: 03/05/21 06:03								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.2	ug/L	1.0	1		03/15/21 12:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-KF-P-21	Lab ID: 70164875017	Collected: 03/05/21 06:03	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/15/21 12:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-22	Lab ID: 70164875018	Collected: 03/05/21 06:17	Received: 03/05/21 19:03	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	135	ug/L	1.0	1		03/15/21 12:14	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-24								
Lab ID: 70164875019								
Collected: 03/05/21 06:17								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	13.7	ug/L	1.0	1		03/15/21 12:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-25								
Lab ID: 70164875020								
Collected: 03/05/21 06:19								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.1	ug/L	1.0	1		03/15/21 12:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-30	Lab ID: 70164875021	Collected: 03/05/21 06:23	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	30.0	ug/L	1.0	1		03/15/21 12:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-28								
Lab ID: 70164875022								
Collected: 03/05/21 06:23 Received: 03/05/21 19:03 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	10.4	ug/L	1.0	1		03/15/21 12:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-27	Lab ID: 70164875023	Collected: 03/05/21 06:27	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.6	ug/L	1.0	1		03/15/21 12:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-31 Lab ID: 70164875024 Collected: 03/05/21 06:32 Received: 03/05/21 19:03 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.6	ug/L	1.0	1		03/15/21 12:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-32								
Lab ID: 70164875025								
Collected: 03/05/21 06:32								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	12.6	ug/L	1.0	1		03/15/21 12:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-33	Lab ID: 70164875026	Collected: 03/05/21 06:34	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.7	ug/L	1.0	1		03/15/21 12:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-35								
Lab ID: 70164875027								
Collected: 03/05/21 06:34								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	26.0	ug/L	1.0	1		03/15/21 12:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-36								
Lab ID: 70164875028								
Collected: 03/05/21 06:36								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.6	ug/L	1.0	1		03/15/21 12:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-38								
Lab ID: 70164875029								
Collected: 03/05/21 06:36								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	22.3	ug/L	1.0	1		03/15/21 12:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-39								
Lab ID: 70164875030								
Collected: 03/05/21 06:39								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.3	ug/L	1.0	1		03/15/21 12:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-40								
Lab ID: 70164875031								
Collected: 03/05/21 06:39								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	13.2	ug/L	1.0	1		03/15/21 12:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-42	Lab ID: 70164875032	Collected: 03/05/21 06:40	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.1	ug/L	1.0	1		03/15/21 12:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-43	Lab ID: 70164875033	Collected: 03/05/21 06:40	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.9	ug/L	1.0	1		03/15/21 12:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD
Pace Project No.: 70164875

Sample: DPS-01-CF-P-44		Lab ID: 70164875034	Collected: 03/05/21 06:43	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.4	ug/L	1.0	1		03/15/21 12:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-45								
Lab ID: 70164875035								
Collected: 03/05/21 06:45								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	12.0	ug/L	1.0	1		03/15/21 12:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-46 Lab ID: 70164875036 Collected: 03/05/21 06:45 Received: 03/05/21 19:03 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		03/15/21 12:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-47								
Lab ID: 70164875037								
Collected: 03/05/21 06:45 Received: 03/05/21 19:03 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.5	ug/L	1.0	1		03/15/21 12:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-49								
Lab ID: 70164875038								
Collected: 03/05/21 06:47								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.3	ug/L	1.0	1		03/15/21 12:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD
Pace Project No.: 70164875

Sample: DPS-01-CF-P-50	Lab ID: 70164875039	Collected: 03/05/21 06:47	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	21.8	ug/L	1.0	1		03/15/21 12:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-SF-P-51	Lab ID: 70164875040	Collected: 03/05/21 06:50	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	18.4	ug/L	1.0	1		03/15/21 12:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-52		Lab ID: 70164875041	Collected: 03/05/21 06:50	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.6	ug/L	1.0	1		03/15/21 12:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-53	Lab ID: 70164875042	Collected: 03/05/21 06:52	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.6	ug/L	1.0	1		03/15/21 12:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-BF-P-54								
Lab ID: 70164875043								
Collected: 03/05/21 06:52								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	11.2	ug/L	1.0	1		03/15/21 12:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-BF-P-56								
Lab ID: 70164875044								
Collected: 03/05/21 06:58								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	6.1	ug/L	1.0	1		03/15/21 12:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-BF-P-57		Lab ID: 70164875045	Collected: 03/05/21 06:58	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.3	ug/L	1.0	1		03/15/21 12:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-59								
Lab ID: 70164875046								
Collected: 03/05/21 07:00								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.1	ug/L	1.0	1		03/15/21 12:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-61		Lab ID: 70164875047	Collected: 03/05/21 07:01	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	34.4	ug/L	1.0	1		03/15/21 12:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-CF-P-63								
Lab ID: 70164875048								
Collected: 03/05/21 07:03								
Received: 03/05/21 19:03								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	14.0	ug/L	1.0	1		03/15/21 13:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-65		Lab ID: 70164875049	Collected: 03/05/21 07:03	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.0	ug/L	1.0	1		03/15/21 13:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-67	Lab ID: 70164875050	Collected: 03/05/21 07:05	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.2	ug/L	1.0	1		03/15/21 13:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-CF-P-69	Lab ID: 70164875051	Collected: 03/05/21 07:06	Received: 03/05/21 19:03	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		03/15/21 13:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: DPS-01-KF-P-70								
Lab ID: 70164875052								
Collected: 03/05/21 06:14 Received: 03/05/21 19:03 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	8.1	ug/L	1.0	1		03/15/21 13:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-KF-P-21A		Lab ID: 70164875053	Collected: 03/05/21 06:05	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.4	ug/L	1.0	1		03/15/21 13:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Sample: DPS-01-KF-P-21B		Lab ID: 70164875054	Collected: 03/05/21 06:05	Received: 03/05/21 19:03	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		03/15/21 13:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

QC Batch: 199962

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70164875001, 70164875002, 70164875003, 70164875004, 70164875005, 70164875006, 70164875007, 70164875008, 70164875009, 70164875010, 70164875011, 70164875012, 70164875013, 70164875014, 70164875015, 70164875016, 70164875017, 70164875018, 70164875019, 70164875020

METHOD BLANK: 983488

Matrix: Water

Associated Lab Samples: 70164875001, 70164875002, 70164875003, 70164875004, 70164875005, 70164875006, 70164875007, 70164875008, 70164875009, 70164875010, 70164875011, 70164875012, 70164875013, 70164875014, 70164875015, 70164875016, 70164875017, 70164875018, 70164875019, 70164875020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/15/21 11:47	

LABORATORY CONTROL SAMPLE: 983489

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.3	99	85-115	

MATRIX SPIKE SAMPLE: 983492

Parameter	Units	70164875001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	19.8	50	73.6	107	70-130	

MATRIX SPIKE SAMPLE: 983494

Parameter	Units	70164875010 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.5	50	62.1	107	70-130	

SAMPLE DUPLICATE: 983491

Parameter	Units	70164875001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	19.8	19.7	1	

SAMPLE DUPLICATE: 983493

Parameter	Units	70164875010 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	8.5	8.4	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: EAST GREENBUSH CSD
Pace Project No.: 70164875

QC Batch:	199965	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70164875021, 70164875022, 70164875023, 70164875024, 70164875025, 70164875026, 70164875027, 70164875028, 70164875029, 70164875030, 70164875031, 70164875032, 70164875033, 70164875034, 70164875035, 70164875036, 70164875037, 70164875038, 70164875039, 70164875040

METHOD BLANK: 983501 Matrix: Water

Associated Lab Samples: 70164875021, 70164875022, 70164875023, 70164875024, 70164875025, 70164875026, 70164875027, 70164875028, 70164875029, 70164875030, 70164875031, 70164875032, 70164875033, 70164875034, 70164875035, 70164875036, 70164875037, 70164875038, 70164875039, 70164875040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/15/21 12:17	

LABORATORY CONTROL SAMPLE: 983502

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.2	98	85-115	

MATRIX SPIKE SAMPLE: 983504

Parameter	Units	70164875021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	30.0	50	83.4	107	70-130	

MATRIX SPIKE SAMPLE: 983506

Parameter	Units	70164875031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	13.2	50	67.4	108	70-130	

SAMPLE DUPLICATE: 983503

Parameter	Units	70164875021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	30.0	30.0	0	

SAMPLE DUPLICATE: 983505

Parameter	Units	70164875031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	13.2	13.2	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: EAST GREENBUSH CSD
Pace Project No.: 70164875

QC Batch:	199966	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70164875041, 70164875042, 70164875043, 70164875044, 70164875045, 70164875046, 70164875047, 70164875048, 70164875049, 70164875050, 70164875051, 70164875052, 70164875053, 70164875054

METHOD BLANK: 983507 Matrix: Water
Associated Lab Samples: 70164875041, 70164875042, 70164875043, 70164875044, 70164875045, 70164875046, 70164875047, 70164875048, 70164875049, 70164875050, 70164875051, 70164875052, 70164875053, 70164875054

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/15/21 12:47	

LABORATORY CONTROL SAMPLE: 983508

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.3	99	85-115	

MATRIX SPIKE SAMPLE: 983510

Parameter	Units	70164875041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.6	50	63.2	111	70-130	

MATRIX SPIKE SAMPLE: 983512

Parameter	Units	70164875051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.4	50	57.6	109	70-130	

SAMPLE DUPLICATE: 983509

Parameter	Units	70164875041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.6	7.8	2	

SAMPLE DUPLICATE: 983511

Parameter	Units	70164875051 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.4	3.3	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70164875001	DPS-01-CF-P-01	EPA 200.8	199962		
70164875002	DPS-01-SF-P-03	EPA 200.8	199962		
70164875003	DPS-01-BF-P-04	EPA 200.8	199962		
70164875004	DPS-01-BF-P-05	EPA 200.8	199962		
70164875005	DPS-01-BF-P-06	EPA 200.8	199962		
70164875006	DPS-01-BF-P-07	EPA 200.8	199962		
70164875007	DPS-01-BF-P-08	EPA 200.8	199962		
70164875008	DPS-01-BF-P-10	EPA 200.8	199962		
70164875009	DPS-01-SF-P-11	EPA 200.8	199962		
70164875010	DPS-01-CF-P-14	EPA 200.8	199962		
70164875011	DPS-01-CF-P-15	EPA 200.8	199962		
70164875012	DPS-01-BF-P-16	EPA 200.8	199962		
70164875013	DPS-01-BF-P-17	EPA 200.8	199962		
70164875014	DPS-01-BF-P-18	EPA 200.8	199962		
70164875015	DPS-01-SF-P-19	EPA 200.8	199962		
70164875016	DPS-01-KF-P-20	EPA 200.8	199962		
70164875017	DPS-01-KF-P-21	EPA 200.8	199962		
70164875018	DPS-01-BF-P-22	EPA 200.8	199962		
70164875019	DPS-01-CF-P-24	EPA 200.8	199962		
70164875020	DPS-01-CF-P-25	EPA 200.8	199962		
70164875021	DPS-01-CF-P-30	EPA 200.8	199965		
70164875022	DPS-01-CF-P-28	EPA 200.8	199965		
70164875023	DPS-01-CF-P-27	EPA 200.8	199965		
70164875024	DPS-01-CF-P-31	EPA 200.8	199965		
70164875025	DPS-01-CF-P-32	EPA 200.8	199965		
70164875026	DPS-01-CF-P-33	EPA 200.8	199965		
70164875027	DPS-01-CF-P-35	EPA 200.8	199965		
70164875028	DPS-01-CF-P-36	EPA 200.8	199965		
70164875029	DPS-01-CF-P-38	EPA 200.8	199965		
70164875030	DPS-01-CF-P-39	EPA 200.8	199965		
70164875031	DPS-01-CF-P-40	EPA 200.8	199965		
70164875032	DPS-01-CF-P-42	EPA 200.8	199965		
70164875033	DPS-01-CF-P-43	EPA 200.8	199965		
70164875034	DPS-01-CF-P-44	EPA 200.8	199965		
70164875035	DPS-01-CF-P-45	EPA 200.8	199965		
70164875036	DPS-01-CF-P-46	EPA 200.8	199965		
70164875037	DPS-01-CF-P-47	EPA 200.8	199965		
70164875038	DPS-01-CF-P-49	EPA 200.8	199965		
70164875039	DPS-01-CF-P-50	EPA 200.8	199965		
70164875040	DPS-01-SF-P-51	EPA 200.8	199965		
70164875041	DPS-01-BF-P-52	EPA 200.8	199966		
70164875042	DPS-01-BF-P-53	EPA 200.8	199966		
70164875043	DPS-01-BF-P-54	EPA 200.8	199966		
70164875044	DPS-01-BF-P-56	EPA 200.8	199966		
70164875045	DPS-01-BF-P-57	EPA 200.8	199966		
70164875046	DPS-01-CF-P-59	EPA 200.8	199966		
70164875047	DPS-01-CF-P-61	EPA 200.8	199966		
70164875048	DPS-01-CF-P-63	EPA 200.8	199966		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: EAST GREENBUSH CSD

Pace Project No.: 70164875

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70164875049	DPS-01-CF-P-65	EPA 200.8	199966		
70164875050	DPS-01-CF-P-67	EPA 200.8	199966		
70164875051	DPS-01-CF-P-69	EPA 200.8	199966		
70164875052	DPS-01-KF-P-70	EPA 200.8	199966		
70164875053	DPS-01-KF-P-21A	EPA 200.8	199966		
70164875054	DPS-01-KF-P-21B	EPA 200.8	199966		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMATION

Name: East Greenbush Central School District
 Address: 29 Englewood Avenue, East Greenbush, NY 12061
 Client Rep: Paul Bickel 518-207-2521

Date of Sampling: 3/5/2020
 Samples Taken By: Paul Swieton
 District Staff: Frank Cramer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Donald P Sutherland Elementary School
 BLDG ADDRESS: 4 John Street, Nassau, NY 12123
 CONTACT NAME & NUMBERS: Paul Bickel 518-207-2521

(1) Yr. Built: (2) Yr 1st Add: (3) Yr 2nd Add: (4) Yr 1st Mod: (5) Yr. 2nd Mod:

WO#: 70164875



SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Collection (24hr)	Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
1	DPS-01-CF-P-01	6 - Conference Room	Sink Faucet			X	0534						
2	DPS-01-DW-P-02	Fountain by Stage Door	Water Fountain			X							
3	DPS-01-SF-P-03	Library	Sink Faucet			X	0537						
4	DPS-01-BF-P-04	Girls Room - L	Bathroom Faucet			X	0544						
5	DPS-01-BF-P-05	Girls Room - R	Bathroom Faucet			X	0544						
6	DPS-01-BF-P-06	Mens Room	Bathroom Faucet			X	0545						
7	DPS-01-BF-P-07	Girls Boys Room - Far Left	Bathroom Faucet			X	0550						
8	DPS-01-BF-P-08	Girls Boys Room - Second	Bathroom Faucet			X	0550						
9	DPS-01-BF-P-09	Girls Boys Room - Third	Bathroom Faucet			X	OFF						
10	DPS-01-BF-P-10	Girls Boys Room - Fourth	Bathroom Faucet			X	0550						
11	DPS-01-SF-P-11	Main Office Book Room	Sink Faucet			X	0554						
12	DPS-01-DW-P-12	Fountain by Center Hallway	Water Fountain			X							
13	DPS-01-DW-P-13	18	Fountain			X	OFF						
14	DPS-01-CF-P-14	18 - L Faucet	Classroom Sink Faucet			X	0557						
15	DPS-01-CF-P-15	18 - R Faucet	Classroom Sink Faucet			X	0557						
16	DPS-01-BF-P-16	Boys Room by 13 - L	Bathroom Faucet			X	0559						
17	DPS-01-BF-P-17	Boys Room by 13 - C	Bathroom Faucet			X	0559						
18	DPS-01-BF-P-18	Boys Room by 13 - R	Bathroom Faucet			X	0559						
19	DPS-01-SF-P-19	Faculty Room	Sink Faucet			X	0601						
20	DPS-01-KF-P-20	Kitchen - Handwashing by Cooler	Kitchen Faucet			X	0603						
21	DPS-01-KF-P-21	Kitchen - Food Prep	Kitchen Faucet			X	0603						
22	DPS-01-BF-P-22	26 - Outside Bathroom	Classroom Sink Faucet			X	0617						
23	DPS-01-DW-P-23	26	Water Fountain			X							
24	DPS-01-CF-P-24	26	Classroom Sink Faucet			X	0617						
25	DPS-01-CF-P-25	28 - Food Lab	Classroom Sink Faucet			X	0619						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: [Signature] Received By: [Signature] PACE
 Time: 12:03 Date: 3/5/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services
 1570 Helderberg Ave.
 Rotterdam, NY 12306
 Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: East Greenbush Central School District
 Address: 29 Englewood Avenue, East Greenbush, NY 12061
 Client Rep: Paul Bickel 518-207-2521

Date of Sampling: 3/5/2020
 Samples Taken By: Paul Swieton
 District Staff: Frank Cramer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Donald P Sutherland Elementary School
 BLDG ADDRESS: 4 John Street, Nassau, NY 12123
 CONTACT NAME & NUMBERS: Paul Bickel 518-207-2521

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Information										
				Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)	
26	DPS-01-DW-P-26	32	Water Fountain			X								
27 30	DPS-01-CF-P- 27 30	32	Classroom Sink Faucet			X		0623						
28	DPS-01-CF-P-28	34 - Outside Bathroom	Classroom Sink Faucet			X		0623						
29	DPS-01-DW-P-29	34	Water Fountain			X								
27 27	DPS-01-CF-P- 27 27	34	Classroom Sink Faucet			X		0627						
31	DPS-01-CF-P-31	35 - Outside Bathroom	Classroom Sink Faucet			X		0632						
32	DPS-01-CF-P-32	35	Classroom Sink Faucet			X		0632						
33	DPS-01-CF-P-33	36 - Outside Bathroom	Classroom Sink Faucet			X		0634						
34	DPS-01-DW-P-34	36	Water Fountain			X								
35	DPS-01-CF-P-35	36	Classroom Sink Faucet			X		0634						
36	DPS-01-CF-P-36	37 - Outside Bathroom	Classroom Sink Faucet			X		0636						
37	DPS-01-DW-P-37	37	Water Fountain			X								
38	DPS-01-CF-P-38	37	Classroom Sink Faucet			X		0636						
39	DPS-01-CF-P-39	44 - Outside Bathroom	Classroom Sink Faucet			X		0639						
40	DPS-01-CF-P-40	44	Classroom Sink Faucet			X		0639						
41	DPS-01-DW-P-41	Fountain by 43/44	Water Fountain			X								
42	DPS-01-CF-P-42	43 - Outside Bathroom	Classroom Sink Faucet			X		0640						
43	DPS-01-CF-P-43	43	Classroom Sink Faucet			X		0640						
44	DPS-01-CF-P-44	42 - Outside Bathroom	Classroom Sink Faucet			X		0643						
45	DPS-01-CF-P-45	42	Classroom Sink Faucet			X		0643						
46	DPS-01-CF-P-46	41 - Outside Bathroom	Classroom Sink Faucet			X		0645						
47	DPS-01-CF-P-47	41	Classroom Sink Faucet			X		0645						
48	DPS-01-DW-P-48	Fountain by 41/40	Water Fountain			X								
49	DPS-01-CF-P-49	40 - Outside Bathroom	Classroom Sink Faucet			X		0647						
50	DPS-01-CF-P-50	40	Classroom Sink Faucet			X		0647						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: <i>[Signature]</i>	Received By: <i>[Signature]</i>	Time: 12:00	Date: 3/5/20
		12:03	3/5/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services
 1570 Helderberg Ave.
 Rotterdam, NY 12306
 Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name: East Greenbush Central School District
 Address: 29 Englewood Avenue, East Greenbush, NY 12061
 Client Rep: Paul Bickel 518-207-2521

Date of Sampling: 3/5/2020
 Samples Taken By: Paul Swieton
 District Staff: Frank Cramer

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Donald P Sutherland Elementary School
 BLDG ADDRESS: 4 John Street, Nassau, NY 12123
 CONTACT NAME & NUMBERS: Paul Bickel 518-207-2521

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
51	DPS-01-SF-P-51	30 - Nurse	Slnk Faucet			X	0650						
52	DPS-01-BF-P-52	30 - Nurse	Bathroom Faucet			X	0650						
53	DPS-01-BF-P-53	Boys Room Gym Corridor	Bathroom Faucet			X	0652						
54	DPS-01-BF-P-54	Girls Room Gym Corridor	Bathroom Faucet			X	0652						
55	DPS-01-DW-P-55	Fountain Gym Corridor	Water Fountain			X							
56	DPS-01-BF-P-56	Girls Locker Room	Bathroom Faucet			X	0658						
57	DPS-01-BF-P-57	Boys Locker Room	Bathroom Faucet			X	0658						
58	DPS-01-DW-P-58	61	Water Fountain			X							
59	DPS-01-CF-P-59	61	Classroom Slnk Faucet			X	0700						
60	DPS-01-DW-P-60	60	Water Fountain			X							
61	DPS-01-CF-P-61	60	Classroom Slnk Faucet			X	0701						
62	DPS-01-DW-P-62	63	Water Fountain			X							
63	DPS-01-CF-P-63	63	Classroom Slnk Faucet			X	0703						
64	DPS-01-DW-P-64	62	Water Fountain			X							
65	DPS-01-CF-P-65	62	Classroom Slnk Faucet			X	0703						
66	DPS-01-DW-P-66	65	Water Fountain			X							
67	DPS-01-CF-P-67	65	Classroom Slnk Faucet			X	0705						
68	DPS-01-DW-P-68	64	Water Fountain			X							
69	DPS-01-CF-P-69	64	Classroom Slnk Faucet			X	0706						
70	DPS-01-KF-P-70	Kitchen - Steam Table	Kitchen Faucet			X	0614						
21A	DPS-01-KF-P-21A	Kitchen - Handwashin by Door	Kitchen Faucet			X	0605						
21B	DPS-01-KF-P-21B	Kitchen Sink	Kitchen Faucet			X	0605						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By: 	Received By:  p 307	Time: 4:16	Date: 3/5/20
		12:11	3/5/20

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead

Lab: Pace Analytical Services
 1570 Helderberg Ave.
 Rotterdam, NY 12306
 Contact: Matthew Broker 518-573-8385 matthew.broker@pacelabs.com
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



Sample Condition Upon Receipt

WO#: 70164875

Client Name: QUESTAR

PM: NML Due Date: 03/22/21
CLIENT: QUESTAR

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: _____ Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Thermometer Used: TH091 Correction Factor: +0.0
Cooler Temperature(°C): 17.7 Cooler Temperature Corrected(°C): 17.7

Temperature Blank Present: Yes No
Type of Ice: Wet Blue None
 Samples on ice, cooling process has begun
Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C
USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: KW 3/5/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No
Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No
If Yes to either question, fill out a Regulated Soil Checklist [F-LI-C-010] and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12.
-Includes date/time/ID, Matrix: <u>SLURRY OIL</u>				
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13.
pH paper Lot # <u>HCO25486</u>				
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NaOH > 12 Cyanide)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis				Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	14.
KI starch test strips Lot # _____				
Residual chlorine strips Lot # _____				Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	15.
Lead Acetate Strips Lot # _____				
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable): _____				

Client Notification/ Resolution: _____ Field Data Required? Y / N
Person Contacted: _____ Date/Time: _____
Comments/ Resolution: _____

* PM (Project Manager) review is documented electronically in LIMS.