

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GM-01-SF-P-02	Girl's Locker Room	Sink Faucet	3/5/2021 05:33	3/11/2021 15:13	70164870001	Lead	2.0	15	ug/L	
GM-01-SF-P-03	Boy's Locker Room	Sink Faucet	3/5/2021 05:34	3/11/2021 15:17	70164870002	Lead	<1.0	15	ug/L	
GM-01-BF-P-04	Men's Room by Main Office	Bathroom Faucet	3/5/2021 05:34	3/11/2021 15:18	70164870003	Lead	1.6	15	ug/L	
GM-01-BF-P-05	Women's Room by Main Office	Bathroom Faucet	3/5/2021 05:35	3/11/2021 15:19	70164870004	Lead	3.6	15	ug/L	
GM-01-BF-P-06	Nurses Office	Bathroom Faucet	3/5/2021 05:36	3/11/2021 15:20	70164870005	Lead	11.2	15	ug/L	
GM-01-SF-P-07	Nurses Office	Sink Faucet	3/5/2021 05:36	3/11/2021 15:23	70164870006	Lead	5.4	15	ug/L	
GM-01-CF-P-09	10 - Bathroom	Classroom Sink Faucet	3/5/2021 05:37	3/11/2021 15:24	70164870007	Lead	2.0	15	ug/L	
GM-01-CF-P-10	10	Classroom Sink Faucet	3/5/2021 05:37	3/11/2021 15:25	70164870008	Lead	2.4	15	ug/L	
GM-01-CF-P-11	11 - Bathroom	Classroom Sink Faucet	3/5/2021 05:40	3/11/2021 15:26	70164870009	Lead	1.3	15	ug/L	
GM-01-CF-P-12	11	Classroom Sink Faucet	3/5/2021 05:40	3/11/2021 15:27	70164870010	Lead	1.3	15	ug/L	
GM-01-CF-P-13	8 - Bathroom	Classroom Sink Faucet	3/5/2021 05:41	3/11/2021 15:28	70164870011	Lead	6.4	15	ug/L	
GM-01-CF-P-14	8	Classroom Sink Faucet	3/5/2021 05:41	3/11/2021 15:31	70164870012	Lead	1.3	15	ug/L	
GM-01-CF-P-15	9 - Bathroom	Classroom Sink Faucet	3/5/2021 05:43	3/11/2021 15:32	70164870013	Lead	<1.0	15	ug/L	
GM-01-CF-P-16	9	Classroom Sink Faucet	3/5/2021 05:43	3/11/2021 15:34	70164870014	Lead	4.1	15	ug/L	
GM-01-BF-P-17	6	Bathroom Faucet	3/5/2021 05:45	3/11/2021 15:35	70164870015	Lead	5.1	15	ug/L	
GM-01-CF-P-18	6	Classroom Sink Faucet	3/5/2021 05:45	3/11/2021 15:36	70164870016	Lead	3.1	15	ug/L	
GM-01-CF-P-19	7 - Bathroom	Classroom Sink Faucet	3/5/2021 05:46	3/11/2021 15:37	70164870017	Lead	2.5	15	ug/L	
GM-01-CF-P-20	7	Classroom Sink Faucet	3/5/2021 05:46	3/11/2021 15:38	70164870018	Lead	2.0	15	ug/L	
GM-01-CF-P-21	5 - Left	Classroom Sink Faucet	3/5/2021 05:48	3/11/2021 15:39	70164870019	Lead	8.6	15	ug/L	
GM-01-CF-P-22	5 - Right	Classroom Sink Faucet	3/5/2021 05:48	3/11/2021 15:40	70164870020	Lead	19.4	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-BF-P-23	5	Bathroom Faucet	3/5/2021 05:48	3/11/2021 15:43	70164870021	Lead	1.1	15	ug/L	
GM-01-CF-P-24	3 - Bathroom	Classroom Sink Faucet	3/5/2021 05:50	3/11/2021 15:48	70164870022	Lead	1.9	15	ug/L	
GM-01-DW-P-26	3	Bottle Filler	3/5/2021 05:50	3/11/2021 15:49	70164870023	Lead	<1.0	15	ug/L	
GM-01-CF-P-27	3	Classroom Sink Faucet	3/5/2021 05:50	3/11/2021 15:50	70164870024	Lead	13.3	15	ug/L	
GM-01-CF-P-28	4 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 05:50	3/11/2021 15:51	70164870025	Lead	10.4	15	ug/L	
GM-01-DW-P-30	4	Bottle Filler	3/5/2021 05:53	3/11/2021 15:51	70164870026	Lead	<1.0	15	ug/L	
GM-01-CF-P-31	4	Classroom Sink Faucet	3/5/2021 05:53	3/11/2021 15:53	70164870027	Lead	2.8	15	ug/L	
GM-01-CF-P-32	1 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 05:54	3/11/2021 15:53	70164870028	Lead	4.1	15	ug/L	
GM-01-DW-P-34	1	Bottle Filler	3/5/2021 05:54	3/11/2021 15:54	70164870029	Lead	<1.0	15	ug/L	
GM-01-CF-P-35	1	Classroom Sink Faucet	3/5/2021 05:54	3/11/2021 15:57	70164870030	Lead	18.9	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-CF-P-36	2 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 05:56	3/11/2021 15:58	70164870031	Lead	4.1	15	ug/L	
GM-01-DW-P-38	2	Bottle Filler	3/5/2021 05:56	3/11/2021 16:01	70164870032	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GM-01-CF-P-39	2	Classroom Sink Faucet	3/5/2021 05:56	3/11/2021 16:02	70164870033	Lead	63.9	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-SF-P-40	111 - Faculty Room	Sink Faucet	3/5/2021 06:00	3/11/2021 16:03	70164870034	Lead	4.5	15	ug/L	
GM-01-KF-P-41	Kitchen - Food Prep	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:04	70164870035	Lead	1.1	15	ug/L	
GM-01-KF-P-42	Kitchen - Hand Washing Center	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:05	70164870036	Lead	1.6	15	ug/L	
GM-01-KF-P-43	Kitchen - Hand Washing Back	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:06	70164870037	Lead	2.3	15	ug/L	
GM-01-BF-P-44	Kitchen - Bathroom	Bathroom Faucet	3/5/2021 06:02	3/11/2021 16:09	70164870038	Lead	15.5	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-BF-P-47	Men's Room - L	Bathroom Faucet	3/5/2021 06:05	3/11/2021 16:10	70164870039	Lead	2.6	15	ug/L	
GM-01-BF-P-48	Men's Room - R	Bathroom Faucet	3/5/2021 06:05	3/11/2021 16:11	70164870040	Lead	2.1	15	ug/L	
GM-01-BF-P-49	Women's Room - L	Bathroom Faucet	3/5/2021 06:06	3/11/2021 16:13	70164870041	Lead	7.9	15	ug/L	
GM-01-BF-P-50	Women's Room - R	Bathroom Faucet	3/5/2021 06:06	3/11/2021 16:16	70164870042	Lead	6.1	15	ug/L	
GM-01-CF-P-51	19 - Food Lab	Classroom Sink Faucet	3/5/2021 06:07	3/11/2021 16:17	70164870043	Lead	2.8	15	ug/L	
GM-01-SF-P-53	16 - Library Office	Sink Faucet	3/5/2021 06:08	3/11/2021 16:20	70164870044	Lead	17.0	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-CF-P-54	22	Classroom Sink Faucet	3/5/2021 06:08	3/11/2021 16:21	70164870045	Lead	19.1	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-CF-P-56	23	Classroom Sink Faucet	3/5/2021 06:09	3/11/2021 16:22	70164870046	Lead	5.4	15	ug/L	
GM-01-CF-P-58	24	Classroom Sink Faucet	3/5/2021 06:10	3/11/2021 16:23	70164870047	Lead	8.3	15	ug/L	
GM-01-CF-P-60	25	Classroom Sink Faucet	3/5/2021 06:11	3/11/2021 16:24	70164870048	Lead	10.5	15	ug/L	
GM-01-BF-P-62	Faculty Bathroom	Bathroom Faucet	3/5/2021 06:12	3/11/2021 16:25	70164870049	Lead	1.1	15	ug/L	
GM-01-CF-P-63	26	Classroom Sink Faucet	3/5/2021 06:13	3/11/2021 16:26	70164870050	Lead	11.2	15	ug/L	
GM-01-CF-P-65	28	Classroom Sink Faucet	3/5/2021 06:13	3/11/2021 16:27	70164870051	Lead	2.5	15	ug/L	
GM-01-CF-P-67	29	Classroom Sink Faucet	3/5/2021 06:14	3/11/2021 16:31	70164870052	Lead	35.8	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-CF-P-69	30	Classroom Sink Faucet	3/5/2021 06:15	3/11/2021 16:32	70164870053	Lead	3.2	15	ug/L	
GM-01-CF-P-71	31	Classroom Sink Faucet	3/5/2021 06:15	3/11/2021 16:33	70164870054	Lead	13.4	15	ug/L	
GM-01-CF-P-73	32	Classroom Sink Faucet	3/5/2021 06:16	3/11/2021 16:34	70164870055	Lead	8.8	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GM-01-CF-P-75	33	Classroom Sink Faucet	3/5/2021 06:16	3/11/2021 16:35	70164870056	Lead	14.9	15	ug/L	
GM-01-CF-P-77	34	Classroom Sink Faucet	3/5/2021 06:16	3/11/2021 16:36	70164870057	Lead	4.0	15	ug/L	
GM-01-CF-P-79	35	Classroom Sink Faucet	3/5/2021 06:18	3/11/2021 16:37	70164870058	Lead	11.5	15	ug/L	
GM-01-CF-P-81	36	Classroom Sink Faucet	3/5/2021 06:20	3/11/2021 16:38	70164870059	Lead	7.3	15	ug/L	
GM-01-CF-P-83	37	Classroom Sink Faucet	3/5/2021 06:21	3/11/2021 16:39	70164870060	Lead	10.1	15	ug/L	
GM-01-CF-P-85	38	Classroom Sink Faucet	3/5/2021 06:21	3/11/2021 16:44	70164870061	Lead	2.0	15	ug/L	
GM-01-CF-P-87	39	Classroom Sink Faucet	3/5/2021 06:22	3/11/2021 16:46	70164870062	Lead	4.2	15	ug/L	
GM-01-KF-P-89	Kitchen - Steam Table	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:47	70164870063	Lead	19.3	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)

NYSDOH Action Level for Lead of 15 ppb