

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
CHS-01-BF-P-01	Boy's Room by S118 - R	Bathroom Faucet	4/1/2021 05:07	4/12/2021 14:37	70167859001	Lead	4.6	15	ug/L	
CHS-01-BF-P-02	Boy's Room by S118 - L	Bathroom Faucet	4/1/2021 05:07	4/12/2021 14:41	70167859002	Lead	3.1	15	ug/L	
CHS-01-DW-P-03	Fountain by Boy's Room S118	Water Fountain	4/1/2021 05:09	4/12/2021 14:42	70167859003	Lead	<1.0	15	ug/L	
CHS-01-BF-P-04	Girl's Room by S102 - L	Bathroom Faucet	4/1/2021 05:10	4/12/2021 14:43	70167859004	Lead	1.7	15	ug/L	
CHS-01-BF-P-05	Girl's Room by S102 - R	Bathroom Faucet	4/1/2021 05:10	4/12/2021 14:44	70167859005	Lead	3.1	15	ug/L	
CHS-01-DW-P-06	Fountain by Women's Room by S102	Water Fountain	4/1/2021 05:11	4/12/2021 14:46	70167859006	Lead	<1.0	15	ug/L	
CHS-01-SF-P-07	Main Office Suite Break Room	Sink Faucet	4/1/2021 05:13	4/12/2021 14:47	70167859007	Lead	<1.0	15	ug/L	
CHS-01-BF-P-08	Main Office Suite Women's Room	Bathroom Faucet	4/1/2021 05:13	4/12/2021 14:48	70167859008	Lead	6.4	15	ug/L	
CHS-01-BF-P-09	Main Office Suite Men's Room	Bathroom Faucet	4/1/2021 05:13	4/12/2021 14:49	70167859009	Lead	<1.0	15	ug/L	
CHS-01-NF-P-10	Health Office - C102A First Aid Room	Sink Faucet	4/1/2021 05:13	4/12/2021 14:50	70167859010	Lead	<1.0	15	ug/L	
CHS-01-NF-P-11	Health Office - C102F Exam Room	Sink Faucet	4/1/2021 05:15	4/12/2021 14:51	70167859011	Lead	2.9	15	ug/L	
CHS-01-BF-P-12	Health Office - Girl's Room	Bathroom Faucet	4/1/2021 05:15	4/12/2021 14:54	70167859012	Lead	1.3	15	ug/L	
CHS-01-BF-P-13	Health Office - Boy's Room	Bathroom Faucet	4/1/2021 05:15	4/12/2021 14:55	70167859013	Lead	1.3	15	ug/L	
CHS-01-SF-P-14	Guidance Suite - Kitchen	Sink Faucet	4/1/2021 05:21	4/12/2021 18:07	70167859142	Lead	2.6	15	ug/L	
CHS-01-BF-P-15	Guidance Suite - Men's Room	Bathroom Faucet	4/1/2021 05:21	4/12/2021 18:07	70167859143	Lead	<1.0	15	ug/L	
CHS-01-BF-P-16	Guidance Suite - Women's Room	Bathroom Faucet	4/1/2021 05:21	4/12/2021 18:10	70167859144	Lead	<1.0	15	ug/L	
CHS-01-CF-P-17	N115	Classroom Sink Faucet	4/1/2021 05:23	4/12/2021 14:58	70167859014	Lead	1.2	15	ug/L	
CHS-01-CF-P-18	N106	Classroom Sink Faucet	4/1/2021 05:24	4/12/2021 14:59	70167859015	Lead	4.7	15	ug/L	
CHS-01-CF-P-19	N107	Classroom Sink Faucet	4/1/2021 05:25	4/12/2021 15:00	70167859016	Lead	6.9	15	ug/L	
CHS-01-SF-P-21	N108 - Faculty	Sink Faucet	4/1/2021 05:27	4/12/2021 15:01	70167859017	Lead	<1.0	15	ug/L	
CHS-01-BF-P-22	N108 - Faculty - Men's Room	Bathroom Faucet	4/1/2021 05:28	4/12/2021 15:02	70167859018	Lead	<1.0	15	ug/L	
CHS-01-BF-P-23	N108 - Faculty - Women's Room	Bathroom Faucet	4/1/2021 05:28	4/12/2021 15:02	70167859019	Lead	1.6	15	ug/L	
CHS-01-BF-P-24	Kitchen - Men's Room	Bathroom Faucet	4/1/2021 05:30	4/12/2021 15:03	70167859020	Lead	<1.0	15	ug/L	
CHS-01-BF-P-25	Kitchen - Women's Room	Bathroom Faucet	4/1/2021 05:30	4/12/2021 15:06	70167859021	Lead	<1.0	15	ug/L	
CHS-01-KF-P-26	Kitchen - Kettle	Kitchen Faucet	4/1/2021 05:32	4/12/2021 15:11	70167859022	Lead	<1.0	15	ug/L	
CHS-01-KF-P-27	Kitchen - Tilt Skillet	Kitchen Faucet	4/1/2021 05:32	4/12/2021 15:12	70167859023	Lead	<1.0	15	ug/L	
CHS-01-KF-P-28	Kitchen - Food Prep Center	Kitchen Faucet	4/1/2021 05:32	4/12/2021 15:13	70167859024	Lead	<1.0	15	ug/L	
CHS-01-KF-P-29	Kitchen - Handwash Center	Kitchen Faucet	4/1/2021 05:32	4/12/2021 15:14	70167859025	Lead	2.2	15	ug/L	
CHS-01-KF-P-30	Cafeteria - Handwash Center Back	Kitchen Faucet	4/1/2021 05:35	4/12/2021 15:15	70167859026	Lead	<1.0	15	ug/L	
CHS-01-KF-P-31	Cafeteria - Sink Center Back by Handwash	Kitchen Faucet	4/1/2021 05:35	4/12/2021 15:16	70167859027	Lead	<1.0	15	ug/L	
CHS-01-KF-P-32	Cafeteria - Steam Table Dishwash Rm Side	Kitchen Faucet	4/1/2021 05:35	4/12/2021 15:17	70167859028	Lead	<1.0	15	ug/L	
CHS-01-KF-P-33	Cafeteria - Dishwash Room - Handwash	Kitchen Faucet	4/1/2021 05:35	4/12/2021 15:18	70167859029	Lead	<1.0	15	ug/L	
CHS-01-KF-P-34	Cafeteria - Sink - Left Side	Kitchen Faucet	4/1/2021 05:35	4/12/2021 15:20	70167859030	Lead	<1.0	15	ug/L	
CHS-01-KF-P-35	Cafeteria - Steam Table - Left Side	Kitchen Faucet	4/1/2021 05:35	4/12/2021 15:21	70167859031	Lead	1.5	15	ug/L	
CHS-01-IM-P-36	Cafeteria - Ice Machine	Ice Machine	4/1/2021 05:38	4/12/2021 15:24	70167859032	Lead	<1.0	15	ug/L	
CHS-01-KF-P-37	Cafeteria - Handwash - Left Side	Kitchen Faucet	4/1/2021 05:35	4/12/2021 15:25	70167859033	Lead	<1.0	15	ug/L	
CHS-01-BF-P-38	Boy's Room by Kitchen - L	Bathroom Faucet	4/1/2021 05:47	4/12/2021 15:26	70167859034	Lead	2.1	15	ug/L	
CHS-01-BF-P-39	Boy's Room by Kitchen - C	Bathroom Faucet	4/1/2021 05:43	4/12/2021 15:27	70167859035	Lead	<1.0	15	ug/L	
CHS-01-BF-P-40	Boy's Room by Kitchen - R	Bathroom Faucet	4/1/2021 05:43	4/12/2021 15:28	70167859036	Lead	1.1	15	ug/L	
CHS-01-BF-P-41	Girl's Room by Kitchen - L	Bathroom Faucet	4/1/2021 05:45	4/12/2021 15:29	70167859037	Lead	2.8	15	ug/L	
CHS-01-BF-P-42	Girl's Room by Kitchen - C	Bathroom Faucet	4/1/2021 05:45	4/12/2021 15:32	70167859038	Lead	3.7	15	ug/L	
CHS-01-BF-P-43	Girl's Room by Kitchen - R	Bathroom Faucet	4/1/2021 05:45	4/12/2021 15:33	70167859039	Lead	1.6	15	ug/L	
CHS-01-SF-P-43A	Kitchen - Snack Shack	Sink Faucet	4/1/2021 05:38	4/12/2021 18:04	70167859141	Lead	<1.0	15	ug/L	
CHS-01-DW-P-45	Gym Fountains Right Section - Right Fountain	Water Fountain	4/1/2021 05:47	4/12/2021 15:34	70167859040	Lead	<1.0	15	ug/L	
CHS-01-DW-P-47	Gym Fountains Center Section - Right Fountain	Water Fountain	4/1/2021 05:48	4/12/2021 15:36	70167859041	Lead	<1.0	15	ug/L	
CHS-01-DW-P-48	Gym Fountains Left Section - Left Fountain	Water Fountain	4/1/2021 05:49	4/12/2021 15:39	70167859042	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
CHS-01-DW-P-49	Gym Fountains Left Section - Right Fountain	Water Fountain	4/1/2021 05:49	4/12/2021 15:40	70167859043	Lead	<1.0	15	ug/L	
CHS-B-BF-P-50	Team Room/Locker Room P010A - L	Bathroom Faucet	4/1/2021 05:52	4/12/2021 15:43	70167859044	Lead	<1.0	15	ug/L	
CHS-B-BF-P-51	Team Room/Locker Room P010A - R	Bathroom Faucet	4/1/2021 05:57	4/12/2021 15:44	70167859045	Lead	<1.0	15	ug/L	
CHS-B-SF-P-52	Maintenance Break Room Sink	Sink Faucet	4/1/2021 05:53	4/12/2021 15:45	70167859046	Lead	<1.0	15	ug/L	
CHS-01-CF-P-53	C107 - South Wall Left	Classroom Sink Faucet	4/1/2021 05:05	4/12/2021 15:46	70167859047	Lead	<1.0	15	ug/L	
CHS-01-CF-P-54	C107 - South Wall Right	Classroom Sink Faucet	4/1/2021 05:05	4/12/2021 15:47	70167859048	Lead	1.6	15	ug/L	
CHS-01-CF-P-55	C107 - Center	Classroom Sink Faucet	4/1/2021 05:05	4/12/2021 15:48	70167859049	Lead	<1.0	15	ug/L	
CHS-01-CF-P-56	C107 - North/Corridor Wall Left	Classroom Sink Faucet	4/1/2021 05:05	4/12/2021 15:49	70167859050	Lead	<1.0	15	ug/L	
CHS-01-CF-P-57	C107 - North/Corridor Wall Right	Classroom Sink Faucet	4/1/2021 05:05	4/12/2021 15:50	70167859051	Lead	1.1	15	ug/L	
CHS-01-BF-P-58	1st Fl C-Wing Girl's - L	Bathroom Faucet	4/1/2021 05:09	4/12/2021 15:54	70167859052	Lead	1.9	15	ug/L	
CHS-01-BF-P-59	1st Fl C-Wing Girl's - C	Bathroom Faucet	4/1/2021 05:09	4/12/2021 15:55	70167859053	Lead	4.3	15	ug/L	
CHS-01-BF-P-60	1st Fl C-Wing Girl's - R	Bathroom Faucet	4/1/2021 05:09	4/12/2021 15:56	70167859054	Lead	8.5	15	ug/L	
CHS-01-BF-P-61	1st Fl C-Wing Boy's - L	Bathroom Faucet	4/1/2021 05:10	4/12/2021 15:57	70167859055	Lead	9.6	15	ug/L	
CHS-01-BF-P-62	1st Fl C-Wing Boy's - C	Bathroom Faucet	4/1/2021 05:10	4/12/2021 15:58	70167859056	Lead	5.1	15	ug/L	
CHS-01-BF-P-63	1st Fl C-Wing Boy's - R	Bathroom Faucet	4/1/2021 05:10	4/12/2021 15:59	70167859057	Lead	2.6	15	ug/L	
CHS-01-BF-P-64	Gender Neutral by Boy's Aud	Bathroom Faucet	4/1/2021 05:11	4/12/2021 16:00	70167859058	Lead	2.9	15	ug/L	
CHS-01-BF-P-65	Boy's Room Aud - L	Bathroom Faucet	4/1/2021 05:14	4/12/2021 16:01	70167859059	Lead	3.7	15	ug/L	
CHS-01-BF-P-66	Boy's Room Aud - C	Bathroom Faucet	4/1/2021 05:14	4/12/2021 16:02	70167859060	Lead	1.7	15	ug/L	
CHS-01-BF-P-67	Boy's Room Aud - R	Bathroom Faucet	4/1/2021 05:14	4/12/2021 16:06	70167859061	Lead	10.4	15	ug/L	
CHS-01-BF-P-68	Girl's Room Aud - L	Bathroom Faucet	4/1/2021 05:16	4/12/2021 16:09	70167859062	Lead	185	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-68	Girl's Room Aud - L	Bathroom Faucet	5/5/2021 05:49	5/24/2021 09:10	70172403001	Lead	48.8	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
CHS-01-BF-S-68F	Girl's Room Aud - L	Bathroom Faucet	5/5/2021 05:49	5/24/2021 09:15	70172403002	Lead	3.5	15	ug/L	Flush Draw Sample is in compliance.
CHS-01-BF-P-69	Girl's Room Aud - C	Bathroom Faucet	4/1/2021 05:16	4/12/2021 16:10	70167859063	Lead	34.6	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-69	Girl's Room Aud - C	Bathroom Faucet	5/5/2021 05:49	5/24/2021 09:16	70172403003	Lead	40.9	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
CHS-01-BF-S-69F	Girl's Room Aud - C	Bathroom Faucet	5/5/2021 05:49	5/24/2021 09:17	70172403004	Lead	24.9	15	ug/L	Flush Draw Sample remains high.
CHS-01-BF-P-70	Girl's Room Aud - R	Bathroom Faucet	4/1/2021 05:16	4/12/2021 16:11	70167859064	Lead	283	15	ug/L	Remediation complete. Resampling data is below.

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
CHS-01-BF-S-70	Girl's Room Aud - R	Bathroom Faucet	5/5/2021 05:49	5/24/2021 09:18	70172403005	Lead	204	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
CHS-01-BF-S-70F	Girl's Room Aud - R	Bathroom Faucet	5/5/2021 05:49	5/24/2021 09:19	70172403006	Lead	33.8	15	ug/L	Flush Draw Sample remains high.
CHS-01-BF-P-71	Gender Neutral by Girl's Aud	Bathroom Faucet	4/1/2021 05:17	4/12/2021 16:12	70167859065	Lead	5.3	15	ug/L	
CHS-01-DW-P-72	Fountain - Gym Hall Corner	Bathroom Faucet	4/1/2021 05:18	4/12/2021 16:13	70167859066	Lead	<1.0	15	ug/L	
CHS-01-BF-P-73	Stage Bathroom	Bathroom Faucet	4/1/2021 05:19	4/12/2021 16:14	70167859067	Lead	2.9	15	ug/L	
CHS-01-CF-P-74	P112 - L	Classroom Sink Faucet	4/1/2021 05:20	4/12/2021 16:17	70167859068	Lead	4.3	15	ug/L	
CHS-01-CF-P-75	P112 - R	Classroom Sink Faucet	4/1/2021 05:20	4/12/2021 16:18	70167859069	Lead	2.0	15	ug/L	
CHS-01-DW-P-76	Fountain by A102 - L	Water Fountain	4/1/2021 05:22	4/12/2021 16:19	70167859070	Lead	<1.0	15	ug/L	
CHS-01-DW-P-77	Bottle Filler by A102	Bottle Filler	4/1/2021 05:23	4/12/2021 16:20	70167859071	Lead	<1.0	15	ug/L	
CHS-01-DW-P-77A	Fountain by A102 - R	Water Fountain	4/1/2021 05:23	4/12/2021 18:00	70167859139	Lead	<1.0	15	ug/L	
CHS-01-SF-P-78	Trainer's Room Sink	Sink Faucet	4/1/2021 05:27	4/12/2021 16:22	70167859072	Lead	<1.0	15	ug/L	
CHS-01-IM-P-79	Training Room Ice Machine	Ice Machine	4/1/2021 05:27	4/12/2021 16:23	70167859073	Lead	<1.0	15	ug/L	
CHS-01-BF-P-80	Boy's Locker Bathroom - Far L	Bathroom Faucet	4/1/2021 05:29	4/12/2021 16:24	70167859074	Lead	7.3	15	ug/L	
CHS-01-BF-P-81	Boy's Locker Bathroom - L Center	Bathroom Faucet	4/1/2021 05:29	4/12/2021 16:25	70167859075	Lead	5.6	15	ug/L	
CHS-01-BF-P-82	Boy's Locker Bathroom - R Center	Bathroom Faucet	4/1/2021 05:29	4/12/2021 16:28	70167859076	Lead	2.6	15	ug/L	
CHS-01-BF-P-83	Boy's Locker Bathroom - Far R	Bathroom Faucet	4/1/2021 05:29	4/12/2021 16:29	70167859077	Lead	1.4	15	ug/L	
CHS-01-DW-P-84	L Fountain by Boy's Locker	Water Fountain	4/1/2021 05:31	4/12/2021 16:30	70167859078	Lead	<1.0	15	ug/L	
CHS-01-DW-P-85	R Fountain by Boy's Locker	Water Fountain	4/1/2021 05:31	4/12/2021 16:31	70167859079	Lead	<1.0	15	ug/L	
CHS-01-BF-P-86	Boy's PE Office Bathroom	Bathroom Faucet	4/1/2021 05:32	4/12/2021 16:32	70167859080	Lead	9.6	15	ug/L	
CHS-01-BF-P-87	Boy's Coaches Room	Bathroom Faucet	4/1/2021 05:32	4/12/2021 16:35	70167859081	Lead	2.0	15	ug/L	
CHS-01-BF-P-88	Girl's PE Office Bathroom	Bathroom Faucet	4/1/2021 05:34	4/12/2021 16:39	70167859082	Lead	15.3	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-88	Girl's PE Office Bathroom	Bathroom Faucet	5/5/2021 06:14	5/24/2021 09:20	70172403007	Lead	10.2	15	ug/L	First Draw Resample is in compliance.
CHS-01-BF-S-88F	Girl's PE Office Bathroom	Bathroom Faucet	5/5/2021 06:14	5/24/2021 09:21	70172403008	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
CHS-01-BF-P-89	Girl's Coaches Room	Bathroom Faucet	4/1/2021 05:34	4/12/2021 16:40	70167859083	Lead	<1.0	15	ug/L	
CHS-01-DW-P-90	L - Fountain by Girl's Locker	Water Fountain	4/1/2021 05:35	4/12/2021 16:41	70167859084	Lead	<1.0	15	ug/L	
CHS-01-DW-P-91	R - Fountain by Girl's Locker	Water Fountain	4/1/2021 05:35	4/12/2021 16:42	70167859085	Lead	<1.0	15	ug/L	
CHS-01-BF-P-92	Girl's Locker Bathroom - Far L	Bathroom Faucet	4/1/2021 05:37	4/12/2021 16:43	70167859086	Lead	3.7	15	ug/L	
CHS-01-BF-P-93	Girl's Locker Bathroom - L Center	Bathroom Faucet	4/1/2021 05:37	4/12/2021 16:44	70167859087	Lead	11.3	15	ug/L	
CHS-01-BF-P-94	Girl's Locker Bathroom - R Center	Bathroom Faucet	4/1/2021 05:37	4/12/2021 16:45	70167859088	Lead	4.3	15	ug/L	
CHS-01-BF-P-95	Girl's Locker Bathroom - Far R	Bathroom Faucet	4/1/2021 05:37	4/12/2021 16:46	70167859089	Lead	29.3	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-95	Girl's Locker Bathroom - Far R	Bathroom Faucet	5/5/2021 06:12	5/24/2021 09:22	70172403009	Lead	10.1	15	ug/L	First Draw Resample is in compliance.
CHS-01-BF-S-95F	Girl's Locker Bathroom - Far R	Bathroom Faucet	5/5/2021 06:12	5/24/2021 09:23	70172403010	Lead	1.8	15	ug/L	Flush Draw Sample is in compliance.
CHS-01-BF-P-96	Varsity Officials Men's/Women's - L	Bathroom Faucet	4/1/2021 05:40	4/12/2021 16:47	70167859090	Lead	5.3	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
CHS-01-BF-P-97	Varsity Officials Men's/Women's - C	Bathroom Faucet	4/1/2021 05:40	4/12/2021 16:48	70167859091	Lead	5.5	15	ug/L	
CHS-01-BF-P-98	Varsity Officials Men's/Women's - R	Bathroom Faucet	4/1/2021 05:40	4/12/2021 16:53	70167859092	Lead	57.4	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-98	Varsity Officials Men's/Women's - R	Bathroom Faucet	5/5/2021 06:09	5/24/2021 09:23	70172403011	Lead	29.1	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
CHS-01-BF-S-98F	Varsity Officials Men's/Women's - R	Bathroom Faucet	5/5/2021 06:09	5/24/2021 09:28	70172403012	Lead	4.7	15	ug/L	Flush Draw Sample is in compliance.
CHS-01-BF-P-99	JV Officials Men's/Women's - L	Bathroom Faucet	4/1/2021 05:40	4/12/2021 16:53	70167859093	Lead	21.5	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-99	JV Officials Men's/Women's - L	Bathroom Faucet	5/5/2021 06:07	5/24/2021 09:29	70172403013	Lead	39.5	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
CHS-01-BF-S-99F	JV Officials Men's/Women's - L	Bathroom Faucet	5/5/2021 06:07	5/24/2021 09:30	70172403014	Lead	1.2	15	ug/L	Flush Draw Sample is in compliance.
CHS-01-BF-P-100	JV Officials Men's/Women's - 2nd	Bathroom Faucet	4/1/2021 05:40	4/12/2021 16:54	70167859094	Lead	20.0	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-100	JV Officials Men's/Women's - 2nd	Bathroom Faucet	5/5/2021 06:07	5/24/2021 09:31	70172403015	Lead	12.0	15	ug/L	First Draw Resample is in compliance.
CHS-01-BF-S-100F	JV Officials Men's/Women's - 2nd	Bathroom Faucet	5/5/2021 06:07	5/24/2021 09:31	70172403016	Lead	1.9	15	ug/L	Flush Draw Sample is in compliance.
CHS-01-BF-P-101	JV Officials Men's/Women's - 3rd	Bathroom Faucet	4/1/2021 05:41	4/12/2021 16:55	70167859095	Lead	9.4	15	ug/L	
CHS-01-BF-P-102	JV Officials Men's/Women's - 4th	Bathroom Faucet	4/1/2021 05:41	4/12/2021 16:56	70167859096	Lead	8.8	15	ug/L	
CHS-01-BF-P-103	JV Officials Men's/Women's - 5th	Bathroom Faucet	4/1/2021 05:41	4/12/2021 16:57	70167859097	Lead	19.2	15	ug/L	Remediation complete. Resampling data is below.
CHS-01-BF-S-103	JV Officials Men's/Women's - 5th	Bathroom Faucet	5/5/2021 06:07	5/24/2021 09:32	70172403017	Lead	14.1	15	ug/L	First Draw Resample is in compliance.
CHS-01-BF-S-103F	JV Officials Men's/Women's - 5th	Bathroom Faucet	5/5/2021 06:07	5/24/2021 09:33	70172403018	Lead	3.3	15	ug/L	Flush Draw Sample is in compliance.
CHS-02-BF-P-104	Boy's Room by S212 - L	Bathroom Faucet	4/1/2021 05:07	4/12/2021 16:58	70167859098	Lead	<1.0	15	ug/L	
CHS-02-BF-P-105	Boy's Room by S212 - R	Bathroom Faucet	4/1/2021 05:07	4/12/2021 16:59	70167859099	Lead	2.4	15	ug/L	
CHS-02-DW-P-106	Fountain by S211	Water Fountain	4/1/2021 05:09	4/12/2021 17:02	70167859100	Lead	<1.0	15	ug/L	
CHS-02-SF-P-107	S222 - Faculty - Sink	Sink Faucet	4/1/2021 05:11	4/12/2021 17:05	70167859101	Lead	<1.0	15	ug/L	
CHS-02-DW-P-108	Fountain by S203A	Water Fountain	4/1/2021 05:12	4/12/2021 17:08	70167859102	Lead	<1.0	15	ug/L	
CHS-02-BF-P-109	Girl's Room by S205 - L	Bathroom Faucet	4/1/2021 05:13	4/12/2021 17:09	70167859103	Lead	1.1	15	ug/L	
CHS-02-BF-P-110	Girl's Room by S205 - R	Bathroom Faucet	4/1/2021 05:13	4/12/2021 17:10	70167859104	Lead	<1.0	15	ug/L	
CHS-03-BF-P-112	Boy's Room by S311 - L	Bathroom Faucet	4/1/2021 05:15	4/12/2021 17:11	70167859105	Lead	5.4	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
CHS-03-BF-P-113	Boy's Room by S311 - R	Bathroom Faucet	4/1/2021 05:15	4/12/2021 17:13	70167859106	Lead	38.6	15	ug/L	Remediation complete. Resampling data is below.
CHS-03-BF-S-113	Boy's Room by S311 - R	Bathroom Faucet	5/5/2021 05:57	5/24/2021 09:34	70172403019	Lead	47.5	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
CHS-03-BF-S-113F	Boy's Room by S311 - R	Bathroom Faucet	5/5/2021 05:57	5/24/2021 09:37	70172403020	Lead	31.0	15	ug/L	Flush Draw Sample remains high.
CHS-03-DW-P-114	Fountain by S310	Water Fountain	4/1/2021 05:16	4/12/2021 17:14	70167859107	Lead	<1.0	15	ug/L	
CHS-03-BF-P-115	Left Faculty Restroom by S312	Bathroom Faucet	4/1/2021 05:17	4/12/2021 17:15	70167859108	Lead	1.6	15	ug/L	
CHS-03-BF-P-116	Right Faculty Restroom by S312	Bathroom Faucet	4/1/2021 05:18	4/12/2021 17:16	70167859109	Lead	1.2	15	ug/L	
CHS-03-SF-P-117	3rd Fl Faculty Area Pantry Sink	Sink Faucet	4/1/2021 05:19	4/12/2021 17:17	70167859110	Lead	<1.0	15	ug/L	
CHS-03-DW-P-118	Fountain by S303	Water Fountain	4/1/2021 05:21	4/12/2021 17:18	70167859111	Lead	<1.0	15	ug/L	
CHS-03-BF-P-119	Women's Room by S304 - L	Bathroom Faucet	4/1/2021 05:21	4/12/2021 17:21	70167859112	Lead	3.2	15	ug/L	
CHS-03-BF-P-120	Women's Room by S304 - R	Bathroom Faucet	4/1/2021 05:22	4/12/2021 17:22	70167859113	Lead	3.1	15	ug/L	
CHS-02-SF-P-121	Library Work Room Sink	Sink Faucet	4/1/2021 05:23	4/12/2021 17:25	70167859114	Lead	<1.0	15	ug/L	
CHS-02-SF-P-122	Library Work Room Women's Rm	Bathroom Faucet	4/1/2021 05:24	4/12/2021 17:26	70167859115	Lead	<1.0	15	ug/L	
CHS-02-SF-P-123	Library Work Room Men's Room	Bathroom Faucet	4/1/2021 05:24	4/12/2021 17:27	70167859116	Lead	1.4	15	ug/L	
CHS-02-DW-P-125	N222 Faculty Sink	Sink Faucet	4/1/2021 05:27	4/12/2021 17:28	70167859117	Lead	<1.0	15	ug/L	
CHS-02-BF-P-126	Boy's Room by N213 - L	Bathroom Faucet	4/1/2021 05:29	4/12/2021 17:29	70167859118	Lead	6.0	15	ug/L	
CHS-02-BF-P-127	Boy's Room by N213 - R	Bathroom Faucet	4/1/2021 05:29	4/12/2021 17:30	70167859119	Lead	1.9	15	ug/L	
CHS-02-DW-P-128	Fountain by N211	Water Fountain	4/1/2021 05:30	4/12/2021 17:30	70167859120	Lead	<1.0	15	ug/L	
CHS-02-BF-P-129	Girl's Room by N205 - L	Bathroom Faucet	4/1/2021 05:32	4/12/2021 17:33	70167859121	Lead	1.6	15	ug/L	
CHS-02-BF-P-130	Girl's Room by N205 - R	Bathroom Faucet	4/1/2021 05:32	4/12/2021 17:38	70167859122	Lead	<1.0	15	ug/L	
CHS-02-BF-P-131	Fountain by N203	Water Fountain	4/1/2021 05:33	4/12/2021 17:39	70167859123	Lead	<1.0	15	ug/L	
CHS-03-BF-P-132	3rd Fl North Left Faculty Bathroom	Bathroom Faucet	4/1/2021 05:35	4/12/2021 17:40	70167859124	Lead	<1.0	15	ug/L	
CHS-03-BF-P-133	3rd Fl North Right Faculty Bathroom	Bathroom Faucet	4/1/2021 05:36	4/12/2021 17:41	70167859125	Lead	1.8	15	ug/L	
CHS-03-BF-P-134	Boy's Room by N311 - L	Bathroom Faucet	4/1/2021 05:37	4/12/2021 17:42	70167859126	Lead	140	15	ug/L	Remediation complete. Resampling data is below.
CHS-03-BF-S-134	Boy's Room by N311 - L	Bathroom Faucet	5/5/2021 06:01	5/24/2021 09:40	70172403021	Lead	12.3	15	ug/L	First Draw Resample is in compliance.
CHS-03-BF-S-134F	Boy's Room by N311 - L	Bathroom Faucet	5/5/2021 06:01	5/24/2021 09:42	70172403022	Lead	3.7	15	ug/L	Flush Draw Sample is in compliance.
CHS-03-BF-P-135	Boy's Room by N311 - R	Bathroom Faucet	4/1/2021 05:37	4/12/2021 17:43	70167859127	Lead	37.3	15	ug/L	Remediation complete. Resampling data is below.
CHS-03-BF-S-135	Boy's Room by N311 - R	Bathroom Faucet	5/5/2021 06:01	5/24/2021 09:43	70172403023	Lead	17.8	15	ug/L	First draw resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
CHS-03-BF-S-135F	Boy's Room by N311 - R	Bathroom Faucet	5/5/2021 06:01	5/24/2021 09:44	70172403024	Lead	4.1	15	ug/L	Flush Draw Sample is in compliance.
CHS-03-BF-P-136	Fountain by N310	Water Fountain	4/1/2021 05:38	4/12/2021 17:44	70167859128	Lead	<1.0	15	ug/L	
CHS-03-SF-P-137	3rd Floor North Faculty Pantry Sink	Sink Faucet	4/1/2021 05:42	4/12/2021 17:45	70167859129	Lead	<1.0	15	ug/L	
CHS-03-BF-P-138	Girl's Room by N304 - L	Bathroom Faucet	4/1/2021 05:39	4/12/2021 17:47	70167859130	Lead	2.2	15	ug/L	
CHS-03-BF-P-139	Girl's Room by N304 - R	Bathroom Faucet	4/1/2021 05:39	4/12/2021 17:48	70167859131	Lead	5.8	15	ug/L	
CHS-03-DW-P-140	Fountain by N303	Water Fountain	4/1/2021 05:40	4/12/2021 17:51	70167859132	Lead	<1.0	15	ug/L	
CHS-02-BF-P-141	2nd Floor C-Wing Girl's Rm - L	Bathroom Faucet	4/1/2021 05:45	4/12/2021 17:52	70167859133	Lead	1.2	15	ug/L	
CHS-02-BF-P-142	2nd Floor C-Wing Girl's Rm - C	Bathroom Faucet	4/1/2021 05:45	4/12/2021 17:53	70167859134	Lead	3.2	15	ug/L	
CHS-02-BF-P-143	2nd Floor C-Wing Girl's Rm - R	Bathroom Faucet	4/1/2021 05:45	4/12/2021 17:54	70167859135	Lead	7.7	15	ug/L	
CHS-02-BF-P-144	2nd Floor C-Wing Boy's Rm - L	Bathroom Faucet	4/1/2021 05:47	4/12/2021 17:55	70167859136	Lead	6.8	15	ug/L	
CHS-02-BF-P-145	2nd Floor C-Wing Boy's Rm - C	Bathroom Faucet	4/1/2021 05:47	4/12/2021 17:56	70167859137	Lead	6.1	15	ug/L	
CHS-02-BF-P-146	2nd Floor C-Wing Boy's Rm - R	Bathroom Faucet	4/1/2021 05:47	4/12/2021 17:59	70167859138	Lead	1.1	15	ug/L	
CHS-01-SF-P-147	Room C112	Classroom Sink Faucet	4/1/2021 05:55	4/12/2021 18:01	70167859140	Lead	<1.0	15	ug/L	

NYSDOH Action Level for Lead of 15 ppb