

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
DPS-01-CF-P-01	6 - Conference Room	Sink Faucet	3/5/2021 05:34	3/15/2021 11:49	70164875001	Lead	19.8	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-01	6 - Conference Room	Sink Faucet	4/20/2021 06:44	5/7/2021 10:24	70170692001	Lead	19.2	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
DPS-01-CF-S-01F	6 - Conference Room	Sink Faucet	4/20/2021 06:44	5/7/2021 10:25	70170692002	Lead	2.7	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-SF-P-03	Library	Sink Faucet	3/5/2021 05:37	3/15/2021 11:53	70164875002	Lead	10.4	15	ug/L	
DPS-01-BF-P-04	Girls Room - L	Bathroom Faucet	3/5/2021 05:44	3/15/2021 11:54	70164875003	Lead	6.3	15	ug/L	
DPS-01-BF-P-05	Girls Room - R	Bathroom Faucet	3/5/2021 05:44	3/15/2021 11:54	70164875004	Lead	7.9	15	ug/L	
DPS-01-BF-P-06	Mens Room	Bathroom Faucet	3/5/2021 05:45	3/15/2021 11:55	70164875005	Lead	13.5	15	ug/L	
DPS-01-BF-P-07	Girls Room - Far Left	Bathroom Faucet	3/5/2021 05:50	3/15/2021 11:58	70164875006	Lead	10.5	15	ug/L	
DPS-01-BF-P-08	Girls Room - Second	Bathroom Faucet	3/5/2021 05:50	3/15/2021 11:59	70164875007	Lead	26.9	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-08	Girls Room - Second	Bathroom Faucet	4/20/2021 06:46	5/7/2021 10:26	70170692003	Lead	28.5	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
DPS-01-CF-S-08F	Girls Room - Second	Bathroom Faucet	4/20/2021 06:46	5/7/2021 10:27	70170692004	Lead	1.8	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-BF-P-10	Girls Room - Fourth	Bathroom Faucet	3/5/2021 05:50	3/15/2021 12:00	70164875008	Lead	9.0	15	ug/L	
DPS-01-SF-P-11	Main Office Book Room	Sink Faucet	3/5/2021 05:54	3/15/2021 12:01	70164875009	Lead	7.9	15	ug/L	
DPS-01-CF-P-14	18 - L Faucet	Classroom Sink Faucet	3/5/2021 05:57	3/15/2021 12:02	70164875010	Lead	8.5	15	ug/L	
DPS-01-CF-P-15	18 - R Faucet	Classroom Sink Faucet	3/5/2021 05:57	3/15/2021 12:05	70164875011	Lead	19.5	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-15	18 - R Faucet	Classroom Sink Faucet	4/20/2021 06:48	5/7/2021 10:29	70170692005	Lead	6.6	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-15F	18 - R Faucet	Classroom Sink Faucet	4/20/2021 06:48	5/7/2021 10:30	70170692006	Lead	1.2	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-BF-P-16	Boys Room by 13 - L	Bathroom Faucet	3/5/2021 05:59	3/15/2021 12:06	70164875012	Lead	12.5	15	ug/L	
DPS-01-BF-P-17	Boys Room by 13 - C	Bathroom Faucet	3/5/2021 05:59	3/15/2021 12:07	70164875013	Lead	22.0	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-17	Boys Room by 13 - C	Bathroom Faucet	4/20/2021 06:50	5/7/2021 10:31	70170692007	Lead	11.3	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-17F	Boys Room by 13 - C	Bathroom Faucet	4/20/2021 06:50	5/7/2021 10:34	70170692008	Lead	2.5	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-BF-P-18	Boys Room by 13 - R	Bathroom Faucet	3/5/2021 05:59	3/15/2021 12:10	70164875014	Lead	22.8	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-18	Boys Room by 13 - R	Bathroom Faucet	4/20/2021 06:51	5/7/2021 10:35	70170692009	Lead	12.9	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-18F	Boys Room by 13 - R	Bathroom Faucet	4/20/2021 06:51	5/7/2021 10:36	70170692010	Lead	1.4	15	ug/L	Flush Draw Sample is in compliance.

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
DPS-01-SF-P-19	Faculty Room	Sink Faucet	3/5/2021 06:01	3/15/2021 12:11	70164875015	Lead	4.7	15	ug/L	
DPS-01-KF-P-20	Kitchen - Handwashing by Cooler	Kitchen Faucet	3/5/2021 06:03	3/15/2021 12:12	70164875016	Lead	5.2	15	ug/L	
DPS-01-KF-P-21	Kitchen - Food Prep	Kitchen Faucet	3/5/2021 06:03	3/15/2021 12:13	70164875017	Lead	<1.0	15	ug/L	
DPS-01-KF-P-21A	Kitchen - Handwashing by Door	Kitchen Faucet	3/5/2021 06:05	3/15/2021 13:08	70164875053	Lead	3.4	15	ug/L	
DPS-01-KF-P-21B	Kitchen Sink	Kitchen Faucet	3/5/2021 06:05	3/15/2021 13:09	70164875054	Lead	<1.0	15	ug/L	
DPS-01-BF-P-22	26 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:17	3/15/2021 12:14	70164875018	Lead	135	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-22	26 - Outside Bathroom	Classroom Sink Faucet	4/20/2021 06:53	5/7/2021 10:37	70170692011	Lead	5.4	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-22F	26 - Outside Bathroom	Classroom Sink Faucet	4/20/2021 06:53	5/7/2021 10:38	70170692012	Lead	1.8	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-CF-P-24	26	Classroom Sink Faucet	3/5/2021 06:17	3/15/2021 12:15	70164875019	Lead	13.7	15	ug/L	
DPS-01-CF-P-25	28 - Food Lab	Classroom Sink Faucet	3/5/2021 06:19	3/15/2021 12:16	70164875020	Lead	5.1	15	ug/L	
DPS-01-CF-P-27	34	Classroom Sink Faucet	3/5/2021 06:27	3/15/2021 12:24	70164875023	Lead	11.6	15	ug/L	
DPS-01-CF-P-28	34 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:23	3/15/2021 12:23	70164875022	Lead	10.4	15	ug/L	
DPS-01-CF-P-30	32	Classroom Sink Faucet	3/5/2021 06:23	3/15/2021 12:18	70164875021	Lead	30.0	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-30	32	Classroom Sink Faucet	4/20/2021 06:56	5/7/2021 10:41	70170692013	Lead	10.0	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-30F	32	Classroom Sink Faucet	4/20/2021 06:56	5/7/2021 10:42	70170692014	Lead	2.8	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-CF-P-31	35 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:32	3/15/2021 12:25	70164875024	Lead	4.6	15	ug/L	
DPS-01-CF-P-32	35	Classroom Sink Faucet	3/5/2021 06:32	3/15/2021 12:26	70164875025	Lead	12.6	15	ug/L	
DPS-01-CF-P-33	36 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:34	3/15/2021 12:27	70164875026	Lead	7.7	15	ug/L	
DPS-01-CF-P-35	36	Classroom Sink Faucet	3/5/2021 06:34	3/15/2021 12:28	70164875027	Lead	26.0	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-35	36	Classroom Sink Faucet	4/20/2021 06:58	5/7/2021 10:43	70170692015	Lead	6.9	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-35F	36	Classroom Sink Faucet	4/20/2021 06:58	5/7/2021 10:44	70170692016	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-CF-P-36	37 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:36	3/15/2021 12:29	70164875028	Lead	2.6	15	ug/L	
DPS-01-CF-P-38	37	Classroom Sink Faucet	3/5/2021 06:36	3/15/2021 12:30	70164875029	Lead	22.3	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-38	37	Classroom Sink Faucet	4/20/2021 07:00	5/7/2021 10:47	70170692017	Lead	2.6	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-38F	37	Classroom Sink Faucet	4/20/2021 07:00	5/7/2021 10:50	70170692018	Lead	2.0	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-CF-P-39	44 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:39	3/15/2021 12:33	70164875030	Lead	1.3	15	ug/L	
DPS-01-CF-P-40	44	Classroom Sink Faucet	3/5/2021 06:39	3/15/2021 12:34	70164875031	Lead	13.2	15	ug/L	
DPS-01-CF-P-42	43 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:40	3/15/2021 12:37	70164875032	Lead	5.1	15	ug/L	
DPS-01-CF-P-43	43	Classroom Sink Faucet	3/5/2021 06:40	3/15/2021 12:38	70164875033	Lead	7.9	15	ug/L	
DPS-01-CF-P-44	42 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:43	3/15/2021 12:39	70164875034	Lead	3.4	15	ug/L	
DPS-01-CF-P-45	42	Classroom Sink Faucet	3/5/2021 06:45	3/15/2021 12:40	70164875035	Lead	12.0	15	ug/L	
DPS-01-CF-P-46	41 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:45	3/15/2021 12:41	70164875036	Lead	2.7	15	ug/L	
DPS-01-CF-P-47	41	Classroom Sink Faucet	3/5/2021 06:45	3/15/2021 12:41	70164875037	Lead	5.5	15	ug/L	
DPS-01-CF-P-49	40 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 06:47	3/15/2021 12:44	70164875038	Lead	2.3	15	ug/L	
DPS-01-CF-P-50	40	Classroom Sink Faucet	3/5/2021 06:47	3/15/2021 12:45	70164875039	Lead	21.8	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-50	40	Classroom Sink Faucet	4/20/2021 07:02	5/7/2021 10:52	70170692019	Lead	8.5	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-50F	40	Classroom Sink Faucet	4/20/2021 07:02	5/7/2021 10:53	70170692020	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
DPS-01-SF-P-51	30 - Nurse	Sink Faucet	3/5/2021 06:50	3/15/2021 12:46	70164875040	Lead	18.4	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-51	30 - Nurse	Sink Faucet	4/20/2021 07:04	5/7/2021 10:54	70170692021	Lead	8.5	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-51F	30 - Nurse	Sink Faucet	4/20/2021 07:04	5/7/2021 10:55	70170692022	Lead	1.6	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-BF-P-52	30 - Nurse	Bathroom Faucet	3/5/2021 06:50	3/15/2021 12:49	70164875041	Lead	7.6	15	ug/L	
DPS-01-BF-P-53	Boys Room Gym Corridor	Bathroom Faucet	3/5/2021 06:52	3/15/2021 12:52	70164875042	Lead	6.6	15	ug/L	
DPS-01-BF-P-54	Girls Room Gym Corridor	Bathroom Faucet	3/5/2021 06:52	3/15/2021 12:53	70164875043	Lead	11.2	15	ug/L	
DPS-01-BF-P-56	Girls Locker Room	Bathroom Faucet	3/5/2021 06:58	3/15/2021 12:56	70164875044	Lead	6.1	15	ug/L	
DPS-01-BF-P-57	Boys Locker Room	Bathroom Faucet	3/5/2021 06:58	3/15/2021 12:57	70164875045	Lead	6.3	15	ug/L	
DPS-01-CF-P-59	61	Classroom Sink Faucet	3/5/2021 07:00	3/15/2021 12:58	70164875046	Lead	2.1	15	ug/L	
DPS-01-CF-P-61	60	Classroom Sink Faucet	3/5/2021 07:01	3/15/2021 12:59	70164875047	Lead	34.4	15	ug/L	Remediation complete. Resampling data is below.
DPS-01-CF-S-61	60	Classroom Sink Faucet	4/20/2021 07:07	5/7/2021 10:56	70170692023	Lead	11.4	15	ug/L	First Draw Resample is in compliance.
DPS-01-CF-S-61F	60	Classroom Sink Faucet	4/20/2021 07:07	5/7/2021 10:57	70170692024	Lead	1.9	15	ug/L	Flush Draw Sample is in compliance.
DPS-01-CF-P-63	63	Classroom Sink Faucet	3/5/2021 07:03	3/15/2021 13:00	70164875048	Lead	14.0	15	ug/L	
DPS-01-CF-P-65	62	Classroom Sink Faucet	3/5/2021 07:03	3/15/2021 13:01	70164875049	Lead	12.0	15	ug/L	
DPS-01-CF-P-67	65	Classroom Sink Faucet	3/5/2021 07:05	3/15/2021 13:01	70164875050	Lead	8.2	15	ug/L	
DPS-01-CF-P-69	64	Classroom Sink Faucet	3/5/2021 07:06	3/15/2021 13:02	70164875051	Lead	3.4	15	ug/L	
DPS-01-KF-P-70	Kitchen - Steam Table	Kitchen Faucet	3/5/2021 06:14	3/15/2021 13:07	70164875052	Lead	8.1	15	ug/L	

NYSDOH Action Level for Lead of 15 ppb