

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GENET-01-CF-P-01	DO - Break Room	Classroom Sink Faucet	3/11/2021 05:31	3/24/2021 10:14	70165769001	Lead	<1.0	15	ug/L	
GENET-01-BF-P-02	Girls Room by 100 L	Bathroom Faucet	3/11/2021 05:35	3/24/2021 10:17	70165769002	Lead	3.5	15	ug/L	
GENET-01-BF-P-03	Girls Room by 100 C	Bathroom Faucet	3/11/2021 05:35	3/24/2021 10:18	70165769003	Lead	3.5	15	ug/L	
GENET-01-BF-P-04	Girls Room by 100 R	Bathroom Faucet	3/11/2021 05:35	3/24/2021 10:19	70165769004	Lead	3.7	15	ug/L	
GENET-01-BF-P-05	103	Bathroom Faucet	3/11/2021 05:36	3/24/2021 10:20	70165769005	Lead	3.2	15	ug/L	
GENET-01-BF-P-06	111	Classroom Sink Faucet	3/11/2021 05:36	3/24/2021 10:21	70165769006	Lead	<1.0	15	ug/L	
GENET-01-BF-P-08	Boys Room by 112/114 L	Bathroom Faucet	3/11/2021 05:37	3/24/2021 10:23	70165769007	Lead	2.1	15	ug/L	
GENET-01-BF-P-09	Boys Room by 112/114 R	Bathroom Faucet	3/11/2021 05:37	3/24/2021 10:24	70165769008	Lead	1.1	15	ug/L	
GENET-01-CF-P-10	114	Classroom Sink Faucet	3/11/2021 05:39	3/24/2021 10:25	70165769009	Lead	<1.0	15	ug/L	
GENET-01-BF-P-11	Fountain by Womens Room	Bathroom Faucet	3/11/2021 05:39	3/24/2021 10:26	70165769010	Lead	7.9	15	ug/L	
GENET-01-BF-P-12	Womens Room by 114 C	Bathroom Faucet	3/11/2021 05:39	3/24/2021 10:27	70165769011	Lead	20.9	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GENET-01-BF-S-12	Womens Room by 114 C	Bathroom Faucet	4/22/2021 07:09	5/7/2021 10:12	70170691001	Lead	1.5	15	ug/L	First Draw Resample is in compliance.
GENET-01-BF-S-12F	Womens Room by 114 C	Bathroom Faucet	4/22/2021 07:09	5/7/2021 10:13	70170691002	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
GENET-01-BF-P-13	Womens Room by 114 R	Bathroom Faucet	3/11/2021 05:39	3/24/2021 10:30	70165769012	Lead	2.5	15	ug/L	
GENET-01-DW-P-14	Fountain by Womens Room	Water Fountain	3/11/2021 05:39	3/24/2021 10:31	70165769013	Lead	1.9	15	ug/L	
GENET-01-BF-P-15	Mens Room Main Entrance L	Bathroom Faucet	3/11/2021 05:40	3/24/2021 10:32	70165769014	Lead	37.5	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GENET-01-BF-S-15	Mens Room Main Entrance L	Bathroom Faucet	4/22/2021 07:12	5/7/2021 10:18	70170691003	Lead	14.6	15	ug/L	First Draw Resample is in compliance.
GENET-01-BF-S-15F	Mens Room Main Entrance L	Bathroom Faucet	4/22/2021 07:12	5/7/2021 10:21	70170691004	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
GENET-01-BF-P-16	Mens Room Main Entrance R	Bathroom Faucet	3/11/2021 05:40	3/24/2021 10:35	70165769015	Lead	2.1	15	ug/L	
GENET-01-CF-P-17	117 - Faculty Room	Sink Faucet	3/11/2021 05:41	3/24/2021 10:36	70165769016	Lead	<1.0	15	ug/L	
GENET-01-CF-P-19	125	Classroom Sink Faucet	3/11/2021 05:43	3/24/2021 10:37	70165769017	Lead	<1.0	15	ug/L	
GENET-01-DW-P-20	Cafeteria - Water Fountain	Water Fountain	3/11/2021 05:43	3/24/2021 10:38	70165769018	Lead	7.5	15	ug/L	
GENET-01-KF-P-21	Kitchen - Food Prep Entrance	Kitchen Faucet	3/11/2021 05:45	3/24/2021 10:39	70165769019	Lead	<1.0	15	ug/L	
GENET-01-KF-P-22	Kitchen - Hand Washing South	Kitchen Faucet	3/11/2021 05:45	3/24/2021 10:40	70165769020	Lead	<1.0	15	ug/L	
GENET-01-KF-P-23	Kitchen - Food Prep at Office	Kitchen Faucet	3/11/2021 05:45	3/24/2021 10:43	70165769021	Lead	<1.0	15	ug/L	
GENET-01-BF-P-24	Kitchen - Bathroom	Bathroom Faucet	3/11/2021 05:45	3/24/2021 10:48	70165769022	Lead	5.1	15	ug/L	
GENET-01-KF-P-25	Kitchen - Hand Washing North	Kitchen Faucet	3/11/2021 05:45	3/24/2021 10:49	70165769023	Lead	<1.0	15	ug/L	
GENET-01-CF-P-26	128	Classroom Sink Faucet	3/11/2021 05:47	3/24/2021 10:50	70165769024	Lead	<1.0	15	ug/L	
GENET-01-DW-P-27	Fountain Outside 126	Water Fountain	3/11/2021 05:47	3/24/2021 10:51	70165769025	Lead	3.6	15	ug/L	
GENET-01-CF-P-28	126	Classroom Sink Faucet	3/11/2021 05:47	3/24/2021 10:52	70165769026	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GENET-01-SF-P-29	118 - Principals Office	Sink Faucet	3/11/2021 05:49	3/24/2021 10:53	70165769027	Lead	<1.0	15	ug/L	
GENET-01-SF-P-31	149	Sink Faucet	3/11/2021 05:50	3/24/2021 10:54	70165769028	Lead	12.9	15	ug/L	
GENET-01-BF-P-32	Girls Room by 149 L	Bathroom Faucet	3/11/2021 05:50	3/24/2021 10:55	70165769029	Lead	4.1	15	ug/L	
GENET-01-BF-P-33	Girls Room by 149 R	Bathroom Faucet	3/11/2021 05:50	3/24/2021 10:56	70165769030	Lead	1.4	15	ug/L	
GENET-01-BF-P-34	Nurse	Bathroom Faucet	3/11/2021 05:52	3/24/2021 10:58	70165769031	Lead	<1.0	15	ug/L	
GENET-01-SF-P-35	Boy's Locker Room	Sink Faucet	3/11/2021 05:52	3/24/2021 11:01	70165769032	Lead	<1.0	15	ug/L	
GENET-01-SF-P-36	Girls Locker Room	Sink Faucet	3/11/2021 05:52	3/24/2021 11:02	70165769033	Lead	1.8	15	ug/L	
GENET-01-CF-P-37	171	Classroom Sink Faucet	3/11/2021 05:53	3/24/2021 11:03	70165769034	Lead	<1.0	15	ug/L	
GENET-01-BF-P-38	171	Bathroom Faucet	3/11/2021 05:53	3/24/2021 11:04	70165769035	Lead	2.5	15	ug/L	
GENET-01-CF-P-39	172	Sink Faucet	3/11/2021 05:54	3/24/2021 11:05	70165769036	Lead	<1.0	15	ug/L	
GENET-01-CF-P-40	174 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:55	3/24/2021 11:06	70165769037	Lead	<1.0	15	ug/L	
GENET-01-CF-P-41	174	Classroom Sink Faucet	3/11/2021 05:55	3/24/2021 11:07	70165769038	Lead	<1.0	15	ug/L	
GENET-01-DW-P-42	Fountain Outside 176	Water Fountain	3/11/2021 05:55	3/24/2021 11:10	70165769039	Lead	1.2	15	ug/L	
GENET-01-CF-P-43	177	Classroom Sink Faucet	3/11/2021 05:56	3/24/2021 11:11	70165769040	Lead	<1.0	15	ug/L	
GENET-01-BF-P-44	177	Bathroom Faucet	3/11/2021 05:56	3/24/2021 11:14	70165769041	Lead	7.9	15	ug/L	
GENET-01-CF-P-45	176 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:56	3/24/2021 11:17	70165769042	Lead	<1.0	15	ug/L	
GENET-01-CF-P-46	176	Classroom Sink Faucet	3/11/2021 05:56	3/24/2021 11:18	70165769043	Lead	<1.0	15	ug/L	
GENET-01-CF-P-47	178 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:57	3/24/2021 11:19	70165769044	Lead	<1.0	15	ug/L	
GENET-01-CF-P-48	178	Classroom Sink Faucet	3/11/2021 05:57	3/24/2021 11:21	70165769045	Lead	<1.0	15	ug/L	
GENET-01-CF-P-49	179 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:59	3/24/2021 11:23	70165769046	Lead	<1.0	15	ug/L	
GENET-01-CF-P-50	179	Classroom Sink Faucet	3/11/2021 05:59	3/24/2021 11:24	70165769047	Lead	<1.0	15	ug/L	
GENET-02-CF-P-51	245	Classroom Sink Faucet	3/11/2021 06:05	3/24/2021 11:24	70165769048	Lead	<1.0	15	ug/L	
GENET-02-BF-P-52	Gender Neutral Bathroom - L	Bathroom Faucet	3/11/2021 06:09	3/24/2021 11:25	70165769049	Lead	1.8	15	ug/L	
GENET-02-CF-P-54	248	Classroom Sink Faucet	3/11/2021 06:06	3/24/2021 11:26	70165769050	Lead	<1.0	15	ug/L	
GENET-02-BF-P-55	241 - Bathroom	Bathroom Faucet	3/11/2021 06:07	3/24/2021 11:27	70165769051	Lead	<1.0	15	ug/L	
GENET-02-CF-P-56	246	Classroom Sink Faucet	3/11/2021 06:07	3/24/2021 11:30	70165769052	Lead	<1.0	15	ug/L	
GENET-02-DW-P-57	Fountain Outside 244	Water Fountain	3/11/2021 06:08	3/24/2021 11:33	70165769053	Lead	<1.0	15	ug/L	
GENET-02-BF-P-58	Girls Room by 244	Bathroom Faucet	3/11/2021 06:09	3/24/2021 11:34	70165769054	Lead	<1.0	15	ug/L	
GENET-02-CF-P-59	244	Classroom Sink Faucet	3/11/2021 06:09	3/24/2021 11:35	70165769055	Lead	<1.0	15	ug/L	
GENET-02-CF-P-60	242	Classroom Sink Faucet	3/11/2021 06:09	3/24/2021 11:36	70165769056	Lead	<1.0	15	ug/L	
GENET-02-BF-P-61	Boys Room by 242 - L	Bathroom Faucet	3/11/2021 06:10	3/24/2021 11:37	70165769057	Lead	<1.0	15	ug/L	
GENET-02-BF-P-62	Boys Room by 242 - R	Bathroom Faucet	3/11/2021 06:10	3/24/2021 11:38	70165769058	Lead	1.5	15	ug/L	
GENET-02-CF-P-63	238	Classroom Sink Faucet	3/11/2021 06:10	3/24/2021 11:39	70165769059	Lead	<1.0	15	ug/L	
GENET-02-CF-P-64	231	Classroom Sink Faucet	3/11/2021 06:11	3/24/2021 11:40	70165769060	Lead	<1.0	15	ug/L	
GENET-02-BF-P-65	231	Bathroom Faucet	3/11/2021 06:11	3/24/2021 11:45	70165769061	Lead	2.3	15	ug/L	
GENET-02-CF-P-66	229	Classroom Sink Faucet	3/11/2021 06:11	3/24/2021 11:48	70165769062	Lead	<1.0	15	ug/L	
GENET-02-CF-P-67	227	Classroom Sink Faucet	3/11/2021 06:12	3/24/2021 11:49	70165769063	Lead	<1.0	15	ug/L	
GENET-02-SF-P-69	226 - Faculty 2nd Floor	Sink Faucet	3/11/2021 06:12	3/24/2021 11:50	70165769064	Lead	<1.0	15	ug/L	
GENET-02-BF-P-70	226 - Men's Bathroom	Bathroom Faucet	3/11/2021 06:12	3/24/2021 11:51	70165769065	Lead	<1.0	15	ug/L	
GENET-02-BF-P-71	226 - Women's Bathroom	Bathroom Faucet	3/11/2021 06:12	3/24/2021 11:52	70165769066	Lead	<1.0	15	ug/L	
GENET-02-CF-P-72	214	Classroom Sink Faucet	3/11/2021 06:14	3/24/2021 11:53	70165769067	Lead	1.8	15	ug/L	
GENET-02-CF-P-73	217	Classroom Sink Faucet	3/11/2021 06:14	3/24/2021 11:54	70165769068	Lead	<1.0	15	ug/L	
GENET-02-CF-P-74	216	Classroom Sink Faucet	3/11/2021 06:14	3/24/2021 11:56	70165769069	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GENET-02-DW-P-75	Fountain Outside 218	Water Fountain	3/11/2021 06:14	3/24/2021 11:57	70165769070	Lead	2.5	15	ug/L	
GENET-02-CF-P-76	218	Classroom Sink Faucet	3/11/2021 06:16	3/24/2021 11:58	70165769071	Lead	87.6	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GENET-02-CF-S-76	219	Classroom Sink Faucet	4/22/2021 07:16	5/7/2021 10:22	70170691005	Lead	1.5	15	ug/L	First Draw Resample is in compliance.
GENET-02-CF-S-76F	220	Classroom Sink Faucet	4/22/2021 07:16	5/7/2021 10:23	70170691006	Lead	10.1	15	ug/L	Flush Draw Sample is in compliance.
GENET-02-CF-P-77	220	Classroom Sink Faucet	3/11/2021 06:17	3/24/2021 12:01	70165769072	Lead	1.4	15	ug/L	
GENET-02-DW-P-78	Fountain Outside 211	Water Fountain	3/11/2021 06:17	3/24/2021 12:02	70165769073	Lead	1.3	15	ug/L	
GENET-02-CF-P-79	209	Classroom Sink Faucet	3/11/2021 06:17	3/24/2021 12:03	70165769074	Lead	<1.0	15	ug/L	
GENET-02-BF-P-80	Boys Room by 209 - L	Bathroom Faucet	3/11/2021 06:17	3/24/2021 12:04	70165769075	Lead	8.1	15	ug/L	
GENET-02-BF-P-81	Boys Room by 209 - C	Bathroom Faucet	3/11/2021 06:18	3/24/2021 12:05	70165769076	Lead	1.3	15	ug/L	
GENET-02-BF-P-82	Boys Room by 209 - R	Bathroom Faucet	3/11/2021 06:18	3/24/2021 12:08	70165769077	Lead	1.7	15	ug/L	
GENET-02-CF-P-83	205	Classroom Sink Faucet	3/11/2021 06:20	3/24/2021 12:09	70165769078	Lead	<1.0	15	ug/L	
GENET-02-CF-P-84	203	Classroom Sink Faucet	3/11/2021 06:20	3/24/2021 12:10	70165769079	Lead	<1.0	15	ug/L	
GENET-02-CF-P-85	201	Classroom Sink Faucet	3/11/2021 06:21	3/24/2021 12:11	70165769080	Lead	1.5	15	ug/L	
GENET-02-BF-P-86	Girls Room by 204 - L	Bathroom Faucet	3/11/2021 06:21	3/24/2021 12:14	70165769081	Lead	5.5	15	ug/L	
GENET-02-BF-P-87	Girls Room by 204 - C	Bathroom Faucet	3/11/2021 06:21	3/24/2021 12:17	70165769082	Lead	1.6	15	ug/L	
GENET-02-BF-P-88	Girls Room by 204 - R	Bathroom Faucet	3/11/2021 06:21	3/24/2021 12:20	70165769083	Lead	2.2	15	ug/L	
GENET-02-CF-P-89	200	Classroom Sink Faucet	3/11/2021 06:22	3/24/2021 12:21	70165769084	Lead	<1.0	15	ug/L	
GENET-02-DW-P-90	DO Fountain - By 413	Water Fountain	3/11/2021 06:23	3/24/2021 12:22	70165769085	Lead	14.1	15	ug/L	
GENET-02-BF-P-91	DO Mens Rm 2nd Floor	Bathroom Faucet	3/11/2021 06:24	3/24/2021 12:23	70165769086	Lead	<1.0	15	ug/L	
GENET-02-BF-P-92	DO Womens Rm 2nd Floor	Bathroom Faucet	3/11/2021 06:24	3/24/2021 12:23	70165769087	Lead	<1.0	15	ug/L	
GENET-01-KF-P-93	Kitchen - Steam Table	Kitchen Faucet	3/11/2021 05:45	3/24/2021 12:24	70165769088	Lead	<1.0	15	ug/L	

NYSDOH Action Level for Lead of 15 ppb