

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GM-01-SF-P-02	Girl's Locker Room	Sink Faucet	3/5/2021 05:33	3/11/2021 15:13	70164870001	Lead	2.0	15	ug/L	
GM-01-SF-P-03	Boy's Locker Room	Sink Faucet	3/5/2021 05:34	3/11/2021 15:17	70164870002	Lead	<1.0	15	ug/L	
GM-01-BF-P-04	Men's Room by Main Office	Bathroom Faucet	3/5/2021 05:34	3/11/2021 15:18	70164870003	Lead	1.6	15	ug/L	
GM-01-BF-P-05	Women's Room by Main Office	Bathroom Faucet	3/5/2021 05:35	3/11/2021 15:19	70164870004	Lead	3.6	15	ug/L	
GM-01-BF-P-06	Nurses Office	Bathroom Faucet	3/5/2021 05:36	3/11/2021 15:20	70164870005	Lead	11.2	15	ug/L	
GM-01-SF-P-07	Nurses Office	Sink Faucet	3/5/2021 05:36	3/11/2021 15:23	70164870006	Lead	5.4	15	ug/L	
GM-01-CF-P-09	10 - Bathroom	Classroom Sink Faucet	3/5/2021 05:37	3/11/2021 15:24	70164870007	Lead	2.0	15	ug/L	
GM-01-CF-P-10	10	Classroom Sink Faucet	3/5/2021 05:37	3/11/2021 15:25	70164870008	Lead	2.4	15	ug/L	
GM-01-CF-P-11	11 - Bathroom	Classroom Sink Faucet	3/5/2021 05:40	3/11/2021 15:26	70164870009	Lead	1.3	15	ug/L	
GM-01-CF-P-12	11	Classroom Sink Faucet	3/5/2021 05:40	3/11/2021 15:27	70164870010	Lead	1.3	15	ug/L	
GM-01-CF-P-13	8 - Bathroom	Classroom Sink Faucet	3/5/2021 05:41	3/11/2021 15:28	70164870011	Lead	6.4	15	ug/L	
GM-01-CF-P-14	8	Classroom Sink Faucet	3/5/2021 05:41	3/11/2021 15:31	70164870012	Lead	1.3	15	ug/L	
GM-01-CF-P-15	9 - Bathroom	Classroom Sink Faucet	3/5/2021 05:43	3/11/2021 15:32	70164870013	Lead	<1.0	15	ug/L	
GM-01-CF-P-16	9	Classroom Sink Faucet	3/5/2021 05:43	3/11/2021 15:34	70164870014	Lead	4.1	15	ug/L	
GM-01-BF-P-17	6	Bathroom Faucet	3/5/2021 05:45	3/11/2021 15:35	70164870015	Lead	5.1	15	ug/L	
GM-01-CF-P-18	6	Classroom Sink Faucet	3/5/2021 05:45	3/11/2021 15:36	70164870016	Lead	3.1	15	ug/L	
GM-01-CF-P-19	7 - Bathroom	Classroom Sink Faucet	3/5/2021 05:46	3/11/2021 15:37	70164870017	Lead	2.5	15	ug/L	
GM-01-CF-P-20	7	Classroom Sink Faucet	3/5/2021 05:46	3/11/2021 15:38	70164870018	Lead	2.0	15	ug/L	
GM-01-CF-P-21	5 - Left	Classroom Sink Faucet	3/5/2021 05:48	3/11/2021 15:39	70164870019	Lead	8.6	15	ug/L	
GM-01-CF-P-22	5 - Right	Classroom Sink Faucet	3/5/2021 05:48	3/11/2021 15:40	70164870020	Lead	19.4	15	ug/L	Remediation complete. Resampling data is below.
GM-01-CF-S-22	5 - Right	Classroom Sink Faucet	4/20/2021 06:39	5/7/2021 09:52	70170688001	Lead	1.6	15	ug/L	First Draw Resample is in compliance.
GM-01-CF-S-22F	5 - Right	Classroom Sink Faucet	4/20/2021 06:39	5/7/2021 09:53	70170688002	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
GM-01-BF-P-23	5	Bathroom Faucet	3/5/2021 05:48	3/11/2021 15:43	70164870021	Lead	1.1	15	ug/L	
GM-01-CF-P-24	3 - Bathroom	Classroom Sink Faucet	3/5/2021 05:50	3/11/2021 15:48	70164870022	Lead	1.9	15	ug/L	
GM-01-DW-P-26	3	Bottle Filler	3/5/2021 05:50	3/11/2021 15:49	70164870023	Lead	<1.0	15	ug/L	
GM-01-CF-P-27	3	Classroom Sink Faucet	3/5/2021 05:50	3/11/2021 15:50	70164870024	Lead	13.3	15	ug/L	
GM-01-CF-P-28	4 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 05:50	3/11/2021 15:51	70164870025	Lead	10.4	15	ug/L	
GM-01-DW-P-30	4	Bottle Filler	3/5/2021 05:53	3/11/2021 15:51	70164870026	Lead	<1.0	15	ug/L	
GM-01-CF-P-31	4	Classroom Sink Faucet	3/5/2021 05:53	3/11/2021 15:53	70164870027	Lead	2.8	15	ug/L	
GM-01-CF-P-32	1 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 05:54	3/11/2021 15:53	70164870028	Lead	4.1	15	ug/L	
GM-01-DW-P-34	1	Bottle Filler	3/5/2021 05:54	3/11/2021 15:54	70164870029	Lead	<1.0	15	ug/L	
GM-01-CF-P-35	1	Classroom Sink Faucet	3/5/2021 05:54	3/11/2021 15:57	70164870030	Lead	18.9	15	ug/L	Remediation complete. Resampling data is below.
GM-01-CF-S-35	1	Classroom Sink Faucet	4/20/2021 06:44	5/7/2021 09:55	70170688003	Lead	1.2	15	ug/L	First Draw Resample is in compliance.
GM-01-CF-S-35F	1	Classroom Sink Faucet	4/20/2021 06:44	5/7/2021 09:56	70170688004	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
GM-01-CF-P-36	2 - Outside Bathroom	Classroom Sink Faucet	3/5/2021 05:56	3/11/2021 15:58	70164870031	Lead	4.1	15	ug/L	
GM-01-DW-P-38	2	Bottle Filler	3/5/2021 05:56	3/11/2021 16:01	70164870032	Lead	<1.0	15	ug/L	
GM-01-CF-P-39	2	Classroom Sink Faucet	3/5/2021 05:56	3/11/2021 16:02	70164870033	Lead	63.9	15	ug/L	Remediation complete. Resampling data is below.
GM-01-CF-S-39	2	Classroom Sink Faucet	4/20/2021 06:42	5/7/2021 09:57	70170688005	Lead	4.6	15	ug/L	First Draw Resample is in compliance.

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GM-01-CF-S-39F	2	Classroom Sink Faucet	4/20/2021 06:42	5/7/2021 09:58	70170688006	Lead	<1.0	15	ug/L	<b>Flush Draw</b> Sample is in compliance.
GM-01-SF-P-40	111 - Faculty Room	Sink Faucet	3/5/2021 06:00	3/11/2021 16:03	70164870034	Lead	4.5	15	ug/L	
GM-01-KF-P-41	Kitchen - Food Prep	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:04	70164870035	Lead	1.1	15	ug/L	
GM-01-KF-P-42	Kitchen - Hand Washing Center	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:05	70164870036	Lead	1.6	15	ug/L	
GM-01-KF-P-43	Kitchen - Hand Washing Back	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:06	70164870037	Lead	2.3	15	ug/L	
GM-01-BF-P-44	Kitchen - Bathroom	Bathroom Faucet	3/5/2021 06:02	3/11/2021 16:09	70164870038	Lead	15.5	15	ug/L	Remediation complete. Resampling data is below.
GM-01-BF-S-44	Kitchen - Bathroom	Bathroom Faucet	4/20/2021 06:48	5/7/2021 09:59	70170688007	Lead	15.6	15	ug/L	<b>First Draw</b> Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
GM-01-BF-S-44F	Kitchen - Bathroom	Bathroom Faucet	4/20/2021 06:48	5/7/2021 10:00	70170688008	Lead	1.6	15	ug/L	<b>Flush Draw</b> Sample is in compliance.
GM-01-BF-P-47	Men's Room - L	Bathroom Faucet	3/5/2021 06:05	3/11/2021 16:10	70164870039	Lead	2.6	15	ug/L	
GM-01-BF-P-48	Men's Room - R	Bathroom Faucet	3/5/2021 06:05	3/11/2021 16:11	70164870040	Lead	2.1	15	ug/L	
GM-01-BF-P-49	Women's Room - L	Bathroom Faucet	3/5/2021 06:06	3/11/2021 16:13	70164870041	Lead	7.9	15	ug/L	
GM-01-BF-P-50	Women's Room - R	Bathroom Faucet	3/5/2021 06:06	3/11/2021 16:16	70164870042	Lead	6.1	15	ug/L	
GM-01-CF-P-51	19 - Food Lab	Classroom Sink Faucet	3/5/2021 06:07	3/11/2021 16:17	70164870043	Lead	2.8	15	ug/L	
GM-01-SF-P-53	16 - Library Office	Sink Faucet	3/5/2021 06:08	3/11/2021 16:20	70164870044	Lead	17.0	15	ug/L	Remediation complete. Resampling data is below.
GM-01-SF-S-53	16 - Library Office	Sink Faucet	4/20/2021 06:53	5/7/2021 10:01	70170688009	Lead	1.1	15	ug/L	<b>First Draw</b> Resample is in compliance.
GM-01-SF-S-53F	16 - Library Office	Sink Faucet	4/20/2021 06:53	5/7/2021 10:04	70170688010	Lead	<1.0	15	ug/L	<b>Flush Draw</b> Sample is in compliance.
GM-01-CF-P-54	22	Classroom Sink Faucet	3/5/2021 06:08	3/11/2021 16:21	70164870045	Lead	19.1	15	ug/L	Remediation complete. Resampling data is below.
GM-01-CF-S-54	22	Classroom Sink Faucet	4/20/2021 06:56	5/7/2021 10:07	70170688011	Lead	2.5	15	ug/L	<b>First Draw</b> Resample is in compliance.
GM-01-CF-S-54F	22	Classroom Sink Faucet	4/20/2021 06:56	5/7/2021 10:08	70170688012	Lead	2.2	15	ug/L	<b>Flush Draw</b> Sample is in compliance.
GM-01-CF-P-56	23	Classroom Sink Faucet	3/5/2021 06:09	3/11/2021 16:22	70164870046	Lead	5.4	15	ug/L	
GM-01-CF-P-58	24	Classroom Sink Faucet	3/5/2021 06:10	3/11/2021 16:23	70164870047	Lead	8.3	15	ug/L	
GM-01-CF-P-60	25	Classroom Sink Faucet	3/5/2021 06:11	3/11/2021 16:24	70164870048	Lead	10.5	15	ug/L	
GM-01-BF-P-62	Faculty Bathroom	Bathroom Faucet	3/5/2021 06:12	3/11/2021 16:25	70164870049	Lead	1.1	15	ug/L	
GM-01-CF-P-63	26	Classroom Sink Faucet	3/5/2021 06:13	3/11/2021 16:26	70164870050	Lead	11.2	15	ug/L	
GM-01-CF-P-65	28	Classroom Sink Faucet	3/5/2021 06:13	3/11/2021 16:27	70164870051	Lead	2.5	15	ug/L	
GM-01-CF-P-67	29	Classroom Sink Faucet	3/5/2021 06:14	3/11/2021 16:31	70164870052	Lead	35.8	15	ug/L	Remediation complete. Resampling data is below.
GM-01-CF-S-67	29	Classroom Sink Faucet	4/20/2021 06:59	5/7/2021 10:09	70170688013	Lead	5.0	15	ug/L	<b>First Draw</b> Resample is in compliance.
GM-01-CF-S-67F	29	Classroom Sink Faucet	4/20/2021 06:59	5/7/2021 10:10	70170688014	Lead	1.4	15	ug/L	<b>Flush Draw</b> Sample is in compliance.
GM-01-CF-P-69	30	Classroom Sink Faucet	3/5/2021 06:15	3/11/2021 16:32	70164870053	Lead	3.2	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
GM-01-CF-P-71	31	Classroom Sink Faucet	3/5/2021 06:15	3/11/2021 16:33	70164870054	Lead	13.4	15	ug/L	
GM-01-CF-P-73	32	Classroom Sink Faucet	3/5/2021 06:16	3/11/2021 16:34	70164870055	Lead	8.8	15	ug/L	
GM-01-CF-P-75	33	Classroom Sink Faucet	3/5/2021 06:16	3/11/2021 16:35	70164870056	Lead	14.9	15	ug/L	
GM-01-CF-P-77	34	Classroom Sink Faucet	3/5/2021 06:16	3/11/2021 16:36	70164870057	Lead	4.0	15	ug/L	
GM-01-CF-P-79	35	Classroom Sink Faucet	3/5/2021 06:18	3/11/2021 16:37	70164870058	Lead	11.5	15	ug/L	
GM-01-CF-P-81	36	Classroom Sink Faucet	3/5/2021 06:20	3/11/2021 16:38	70164870059	Lead	7.3	15	ug/L	
GM-01-CF-P-83	37	Classroom Sink Faucet	3/5/2021 06:21	3/11/2021 16:39	70164870060	Lead	10.1	15	ug/L	
GM-01-CF-P-85	38	Classroom Sink Faucet	3/5/2021 06:21	3/11/2021 16:44	70164870061	Lead	2.0	15	ug/L	
GM-01-CF-P-87	39	Classroom Sink Faucet	3/5/2021 06:22	3/11/2021 16:46	70164870062	Lead	4.2	15	ug/L	
GM-01-KF-P-89	Kitchen - Steam Table	Kitchen Faucet	3/5/2021 06:02	3/11/2021 16:47	70164870063	Lead	19.3	15	ug/L	Remediation complete. Resampling data is below.
GM-01-KF-S-89	Kitchen - Steam Table	Kitchen Faucet	4/20/2021 06:50	5/7/2021 10:11	70170688015	Lead	7.9	15	ug/L	<b>First Draw</b> Resample is in compliance.
GM-01-KF-S-89F	Kitchen - Steam Table	Kitchen Faucet	4/20/2021 06:50	5/7/2021 10:11	70170688016	Lead	1.8	15	ug/L	<b>Flush Draw</b> Sample is in compliance.

NYSDOH Action Level for Lead of 15 ppb