

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
RM-02-DW-P-01	Main Entrance Fountain - L	Water Fountain	3/11/2021 05:30	3/23/2021 15:42	70165764001	Lead	<1.0	15	ug/L	
RM-02-DW-P-02	Main Entrance Fountain - R	Water Fountain	3/11/2021 05:30	3/23/2021 15:48	70165764002	Lead	<1.0	15	ug/L	
RM-02-SF-P-03	Main Office Copy Room	Sink Faucet	3/11/2021 05:32	3/23/2021 15:49	70165764003	Lead	<1.0	15	ug/L	
RM-02-CF-P-04	143 - Food Lab	Classroom Sink Faucet	3/11/2021 05:33	3/23/2021 15:49	70165764004	Lead	4.9	15	ug/L	
RM-02-CF-P-05	8 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:34	3/23/2021 15:50	70165764005	Lead	<1.0	15	ug/L	
RM-02-CF-P-07	8	Classroom Sink Faucet	3/11/2021 05:36	3/23/2021 15:51	70165764006	Lead	<1.0	15	ug/L	
RM-02-CF-P-08	6 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:37	3/23/2021 15:52	70165764007	Lead	1.2	15	ug/L	
RM-02-CF-P-10	6	Classroom Sink Faucet	3/11/2021 05:38	3/23/2021 15:53	70165764008	Lead	3.0	15	ug/L	
RM-02-CF-P-11	4 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:40	3/23/2021 15:54	70165764009	Lead	<1.0	15	ug/L	
RM-02-DW-P-12	4	Water Fountain	3/11/2021 05:41	3/23/2021 15:55	70165764010	Lead	2.3	15	ug/L	
RM-02-CF-P-13	4	Classroom Sink Faucet	3/11/2021 05:42	3/23/2021 15:56	70165764011	Lead	<1.0	15	ug/L	
RM-02-CF-P-14	3 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:42	3/23/2021 16:01	70165764012	Lead	<1.0	15	ug/L	
RM-02-CF-P-16	3	Classroom Sink Faucet	3/11/2021 05:43	3/23/2021 16:01	70165764013	Lead	1.4	15	ug/L	
RM-02-BF-P-17	2	Bathroom Faucet	3/11/2021 05:44	3/23/2021 16:02	70165764014	Lead	1.8	15	ug/L	
RM-02-DW-P-18	2	Water Fountain	3/11/2021 05:45	3/23/2021 16:03	70165764015	Lead	<1.0	15	ug/L	
RM-02-CF-P-19	2	Classroom Sink Faucet	3/11/2021 05:45	3/23/2021 16:04	70165764016	Lead	1.1	15	ug/L	
RM-02-BF-P-20	1	Bathroom Faucet	3/11/2021 05:46	3/23/2021 16:05	70165764017	Lead	3.4	15	ug/L	
RM-02-DW-P-21	1	Water Fountain	3/11/2021 05:47	3/23/2021 16:06	70165764018	Lead	10.7	15	ug/L	
RM-02-CF-P-22	1	Classroom Sink Faucet	3/11/2021 05:47	3/23/2021 16:07	70165764019	Lead	<1.0	15	ug/L	
RM-02-CF-P-23	5 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:49	3/23/2021 16:10	70165764020	Lead	1.3	15	ug/L	
RM-02-CF-P-24	5	Classroom Sink Faucet	3/11/2021 05:49	3/23/2021 16:13	70165764021	Lead	12.7	15	ug/L	
RM-02-CF-P-25	7 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:50	3/23/2021 16:15	70165764022	Lead	1.8	15	ug/L	
RM-02-DW-P-26	7	Water Fountain	3/11/2021 05:50	3/23/2021 16:16	70165764023	Lead	1.9	15	ug/L	
RM-02-CF-P-27	7	Classroom Sink Faucet	3/11/2021 05:50	3/23/2021 16:17	70165764024	Lead	2.2	15	ug/L	
RM-02-CF-P-28	9 - Outside Bathroom	Classroom Sink Faucet	3/11/2021 05:52	3/23/2021 16:18	70165764025	Lead	1.3	15	ug/L	
RM-02-DW-P-29	9	Water Fountain	3/11/2021 05:52	3/23/2021 16:21	70165764026	Lead	1.4	15	ug/L	
RM-02-CF-P-30	9	Classroom Sink Faucet	3/11/2021 05:53	3/23/2021 16:22	70165764027	Lead	2.2	15	ug/L	
RM-02-BF-P-31	140 - Health Office	Bathroom Faucet	3/11/2021 05:54	3/23/2021 16:23	70165764028	Lead	2.1	15	ug/L	
RM-02-SF-P-32	140 - Health Office	Sink Faucet	3/11/2021 05:54	3/23/2021 16:24	70165764029	Lead	<1.0	15	ug/L	
RM-02-BF-P-33	Women's Room Main Hall	Bathroom Faucet	3/11/2021 05:55	3/23/2021 16:25	70165764030	Lead	<1.0	15	ug/L	
RM-02-BF-P-34	106 - Old Custodial Office	Bathroom Faucet	3/11/2021 05:56	3/23/2021 16:26	70165764031	Lead	<1.0	15	ug/L	
RM-02-BF-P-35	Boy's Room by 120 - L	Bathroom Faucet	3/11/2021 05:58	3/23/2021 16:29	70165764032	Lead	3.0	15	ug/L	
RM-02-BF-P-36	Boy's Room by 120 - R	Bathroom Faucet	3/11/2021 05:59	3/23/2021 16:29	70165764033	Lead	19.2	15	ug/L	Remediation complete. Resampling data is below.
RM-02-BF-S-36	Boy's Room by 120 - R	Bathroom Faucet	4/22/2021 06:39	5/7/2021 00:01	70170678002	Lead	99.7	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
RM-02-BF-S-36F	Boy's Room by 120 - R	Bathroom Faucet	4/22/2021 06:39	5/6/2021 23:57	70170678001	Lead	5.8	15	ug/L	Flush Draw Sample is in compliance.
RM-02-BF-P-37	Girl's Room by 120 - L	Bathroom Faucet	3/11/2021 05:59	3/23/2021 16:32	70165764034	Lead	8.4	15	ug/L	
RM-02-BF-P-38	Girl's Room by 120 - R	Bathroom Faucet	3/11/2021 05:59	3/23/2021 16:33	70165764035	Lead	47.9	15	ug/L	Remediation complete. Resampling data is below.
RM-02-BF-S-38	Girl's Room by 120 - R	Bathroom Faucet	4/22/2021 06:41	5/7/2021 00:04	70170678003	Lead	8.4	15	ug/L	First Draw Resample is in compliance.

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
RM-02-BF-S-38F	Girl's Room by 120 - R	Bathroom Faucet	4/22/2021 06:41	5/7/2021 00:05	70170678004	Lead	13.3	15	ug/L	Flush Draw Sample is in compliance.
RM-02-DW-P-39	Fountains by 10 - L	Water Fountain	3/11/2021 06:00	3/23/2021 16:34	70165764036	Lead	7.8	15	ug/L	
RM-02-CF-P-41	12 - By door - L	Classroom Sink Faucet	3/11/2021 06:01	3/23/2021 16:35	70165764037	Lead	4.5	15	ug/L	
RM-02-CF-P-42	12 - R	Classroom Sink Faucet	3/11/2021 06:02	3/23/2021 16:36	70165764038	Lead	3.4	15	ug/L	
RM-02-CF-P-44	13	Classroom Sink Faucet	3/11/2021 06:03	3/23/2021 16:37	70165764039	Lead	1.3	15	ug/L	
RM-02-SF-P-45	222 - Girl's Locker	Sink Faucet	3/11/2021 06:05	3/23/2021 16:38	70165764040	Lead	<1.0	15	ug/L	
RM-02-SF-P-46	221 Men's Locker	Sink Faucet	3/11/2021 06:05	3/23/2021 16:41	70165764041	Lead	2.5	15	ug/L	
RM-02-DW-P-47	Gym Fountains - L	Water Fountain	3/11/2021 06:06	3/23/2021 16:45	70165764042	Lead	<1.0	15	ug/L	
RM-02-DW-P-49	Gym Bottle Filler	Bottle Filler	3/11/2021 06:07	3/23/2021 16:46	70165764043	Lead	<1.0	15	ug/L	
RM-02-KF-P-51	Kitchen - Handwashing	Kitchen Faucet	3/11/2021 06:11	3/23/2021 16:47	70165764044	Lead	<1.0	15	ug/L	
RM-02-KF-P-52	Kitchen - Steam Table	Kitchen Faucet	3/11/2021 06:12	3/23/2021 16:48	70165764045	Lead	1.0	15	ug/L	
RM-02-KF-P-53	Kitchen - Food Prep	Kitchen Faucet	3/11/2021 06:12	3/23/2021 16:49	70165764046	Lead	<1.0	15	ug/L	
RM-02-SF-P-54	111	Sink Faucet	3/11/2021 06:14	3/23/2021 16:50	70165764047	Lead	<1.0	15	ug/L	
RM-02-SF-P-55	106 - Faculty Room	Sink Faucet	3/11/2021 06:15	3/23/2021 16:51	70165764048	Lead	1.3	15	ug/L	
RM-02-BF-P-56	Men's Room (Right Restroom)	Bathroom Faucet	3/11/2021 06:15	3/23/2021 16:52	70165764049	Lead	<1.0	15	ug/L	
RM-02-BF-P-57	Women's Room (Left Restroom)	Bathroom Faucet	3/11/2021 06:16	3/23/2021 16:54	70165764050	Lead	<1.0	15	ug/L	
RM-02-SF-P-58	Library Office Prep	Sink Faucet	3/11/2021 06:18	3/23/2021 16:56	70165764051	Lead	2.0	15	ug/L	
RM-02-SF-P-59	Library by Desk	Sink Faucet	3/11/2021 06:19	3/23/2021 16:58	70165764052	Lead	1.8	15	ug/L	
RM-02-CF-P-60	21	Classroom Sink Faucet	3/11/2021 06:20	3/23/2021 16:59	70165764053	Lead	5.9	15	ug/L	
RM-02-DW-P-61	Fountain by 21	Water Fountain	3/11/2021 06:22	3/23/2021 17:00	70165764054	Lead	3.0	15	ug/L	
RM-02-CF-P-62	20	Classroom Sink Faucet	3/11/2021 06:23	3/23/2021 17:01	70165764055	Lead	2.4	15	ug/L	
RM-02-BF-P-63	20	Bathroom Faucet	3/11/2021 06:24	3/23/2021 17:02	70165764056	Lead	<1.0	15	ug/L	
RM-02-BF-P-64	19	Bathroom Faucet	3/11/2021 06:25	3/23/2021 17:03	70165764057	Lead	<1.0	15	ug/L	
RM-02-CF-P-66	19	Classroom Sink Faucet	3/11/2021 06:25	3/23/2021 17:06	70165764058	Lead	25.6	15	ug/L	Remediation complete. Resampling data is below.
RM-02-CF-S-66	19	Classroom Sink Faucet	4/22/2021 06:44	5/7/2021 00:06	70170678005	Lead	15.4	15	ug/L	First Draw Resample remains high. Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
RM-02-CF-S-66F	19	Classroom Sink Faucet	4/22/2021 06:44	5/7/2021 00:07	70170678006	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
RM-02-CF-P-67	18	Classroom Sink Faucet	3/11/2021 06:27	3/23/2021 17:07	70165764059	Lead	2.6	15	ug/L	
RM-02-CF-P-68	17A	Classroom Sink Faucet	3/11/2021 06:28	3/23/2021 17:08	70165764060	Lead	1.8	15	ug/L	
RM-02-CF-P-69	16	Classroom Sink Faucet	3/11/2021 06:29	3/23/2021 17:10	70165764061	Lead	<1.0	15	ug/L	
RM-02-CF-P-70	15	Classroom Sink Faucet	3/11/2021 06:29	3/23/2021 17:13	70165764062	Lead	<1.0	15	ug/L	
RM-02-CF-P-72	14	Classroom Sink Faucet	3/11/2021 06:30	3/23/2021 17:14	70165764063	Lead	1.7	15	ug/L	
RM-01-CF-P-73	34	Classroom Sink Faucet	3/11/2021 06:33	3/23/2021 17:17	70165764064	Lead	2.5	15	ug/L	
RM-01-DW-P-74	34	Water Fountain	3/11/2021 06:33	3/23/2021 17:18	70165764065	Lead	25.0	15	ug/L	Remediation complete. Resampling data is below.
RM-01-DW-S-74	34	Water Fountain	4/22/2021 06:51	5/7/2021 00:08	70170678007	Lead	1.6	15	ug/L	First Draw Resample is in compliance.
RM-01-DW-S-74F	34	Water Fountain	4/22/2021 06:51	5/7/2021 00:09	70170678008	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
RM-01-CF-P-75	33	Classroom Sink Faucet	3/11/2021 06:34	3/23/2021 17:19	70165764066	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
RM-01-CF-P-76	32	Classroom Sink Faucet	3/11/2021 06:35	3/23/2021 17:20	70165764067	Lead	2.0	15	ug/L	
RM-01-DW-P-77	Fountain Outside 31	Water Fountain	3/11/2021 06:36	3/23/2021 17:21	70165764068	Lead	<1.0	15	ug/L	
RM-01-CF-P-78	31	Classroom Sink Faucet	3/11/2021 06:37	3/23/2021 17:22	70165764069	Lead	<1.0	15	ug/L	
RM-01-CF-P-79	30	Classroom Sink Faucet	3/11/2021 06:38	3/23/2021 17:23	70165764070	Lead	18.1	15	ug/L	Remediation complete. Resampling data is below.
RM-01-CF-S-79	30	Classroom Sink Faucet	4/22/2021 06:49	5/7/2021 00:10	70170678009	Lead	<1.0	15	ug/L	First Draw Resample is in compliance.
RM-01-CF-S-79F	30	Classroom Sink Faucet	4/22/2021 06:49	5/7/2021 00:11	70170678010	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
RM-01-BF-P-80	Girl's Room - L	Bathroom Faucet	3/11/2021 06:38	3/23/2021 17:24	70165764071	Lead	<1.0	15	ug/L	
RM-01-BF-P-81	Girl's Room - R	Bathroom Faucet	3/11/2021 06:39	3/23/2021 17:28	70165764072	Lead	<1.0	15	ug/L	
RM-01-BF-P-82	Boy's Room - L	Bathroom Faucet	3/11/2021 06:41	3/23/2021 17:29	70165764073	Lead	<1.0	15	ug/L	
RM-01-BF-P-83	Boy's Room - R	Bathroom Faucet	3/11/2021 06:42	3/23/2021 17:30	70165764074	Lead	<1.0	15	ug/L	
RM-01-CF-P-84	29A	Classroom Sink Faucet	3/11/2021 06:42	3/23/2021 17:31	70165764075	Lead	<1.0	15	ug/L	
RM-01-CF-P-85	28	Classroom Sink Faucet	3/11/2021 06:43	3/23/2021 17:32	70165764076	Lead	1.1	15	ug/L	
RM-01-DW-P-86	28	Water Fountain	3/11/2021 06:44	3/23/2021 17:33	70165764077	Lead	4.2	15	ug/L	
RM-01-CF-P-87	27	Classroom Sink Faucet	3/11/2021 06:45	3/23/2021 17:34	70165764078	Lead	1.1	15	ug/L	
RM-01-CF-P-88	26	Classroom Sink Faucet	3/11/2021 06:46	3/23/2021 17:35	70165764079	Lead	27.0	15	ug/L	Remediation complete. Resampling data is below.
RM-01-CF-S-88	26	Classroom Sink Faucet	4/22/2021 06:47	5/7/2021 00:12	70170678011	Lead	<1.0	15	ug/L	First Draw Resample is in compliance.
RM-01-CF-S-88F	26	Classroom Sink Faucet	4/22/2021 06:47	5/7/2021 00:16	70170678012	Lead	<1.0	15	ug/L	Flush Draw Sample is in compliance.
RM-01-CF-P-89	25	Classroom Sink Faucet	3/11/2021 06:47	3/23/2021 17:36	70165764080	Lead	1.1	15	ug/L	
RM-01-DW-P-90	Fountain Outside 25	Water Fountain	3/11/2021 06:48	3/23/2021 17:41	70165764081	Lead	<1.0	15	ug/L	
RM-01-CF-P-91	24	Classroom Sink Faucet	3/11/2021 06:49	3/23/2021 17:43	70165764082	Lead	<1.0	15	ug/L	
RM-02-KF-P-92	Kitchen - Multiuse Sink - L	Kitchen Faucet	3/11/2021 06:11	3/23/2021 17:44	70165764083	Lead	<1.0	15	ug/L	
RM-02-KF-P-93	Kitchen - Multiuse Sink - R	Kitchen Faucet	3/11/2021 06:11	3/23/2021 17:45	70165764084	Lead	<1.0	15	ug/L	
RM-02-DW-P-94	Room 6	2nd Water Fountain	3/11/2021 05:39	3/23/2021 17:46	70165764085	Lead	<1.0	15	ug/L	
RM-02-BF-P-95	Room 13	Bathroom Faucet	3/11/2021 06:03	3/23/2021 17:47	70165764086	Lead	2.4	15	ug/L	
RM-02-CF-P-96	Library by 21	Sink Faucet	3/11/2021 06:21	3/23/2021 17:48	70165764087	Lead	7.9	15	ug/L	
RM-01-BF-P-97	1st Floor Boy's Bathroom - Center	Bathroom Faucet	3/11/2021 06:42	3/23/2021 17:51	70165764088	Lead	<1.0	15	ug/L	
RM-02-BF-P-98	2nd Floor Boy's Bathroom by Room 14 - R	Bathroom Faucet	3/11/2021 06:52	3/23/2021 17:52	70165764089	Lead	<1.0	15	ug/L	
RM-02-BF-P-99	2nd Floor Boy's Bathroom by Room 14 - C	Bathroom Faucet	3/11/2021 06:52	3/23/2021 17:53	70165764090	Lead	<1.0	15	ug/L	
RM-02-BF-P-100	2nd Floor Boy's Bathroom by Room 14 - L	Bathroom Faucet	3/11/2021 06:52	3/23/2021 17:54	70165764091	Lead	<1.0	15	ug/L	

NYSDOH Action Level for Lead of 15 ppb