

PACE LABS

Pace Labs address: 14 Walker Way, Albany, NY 12205

District Name: East Greenbush CSD

School Name: Columbia High School

Street address: 962 Luther Road, East Greenbush, NY 12061

Sample ID	Columbia Location	Analysis Required	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDO H Action Level	Units
CHS-01-BF-P-01	Boy's Room by S118 - R Bathroom Faucet	Lead	CHS-01-BF-P-01	5/29/2025 6:10	6/16/2025 18:17	70359784001	Lead	<1.0	5	ug/L
CHS-01-BF-P-02	Boy's Room by S118 - L Bathroom Faucet	Lead	CHS-01-BF-P-02	5/29/2025 6:11	6/16/2025 18:18	70359784002	Lead	<1.0	5	ug/L
CHS-01-DW-P-03	Fountain by Boy's Room S118 Water Fountain	Lead	CHS-01-DW-P-03	5/29/2025 6:12	6/16/2025 18:23	70359784003	Lead	<1.0	5	ug/L
CHS-01-BF-P-04	Girl's Room by S102 - L Bathroom Faucet	Lead	CHS-01-BF-P-04	5/29/2025 6:13	6/16/2025 18:27	70359784004	Lead	<1.0	5	ug/L
CHS-01-BF-P-05	Girl's Room by S102 - R Bathroom Faucet	Lead	CHS-01-BF-P-05	5/29/2025 6:14	6/16/2025 18:32	70359784005	Lead	<1.0	5	ug/L
CHS-01-DW-P-06	Fountain by Women's Room by S102 Water Fountain	Lead	CHS-01-DW-P-06	5/29/2025 6:15	6/16/2025 18:36	70359784006	Lead	<1.0	5	ug/L
CHS-01-DW-P-06A	Bottle Filler by Women's Room by S102	Lead	CHS-01-DW-P-06A	5/29/2025 6:16	6/16/2025 18:41	70359784007	Lead	<1.0	5	ug/L
CHS-01-SF-P-07	Main Office Suite Break Room Sink Faucet	Lead	CHS-01-SF-P-07	5/29/2025 5:56	6/16/2025 18:42	70359784008	Lead	<1.0	5	ug/L
CHS-01-BF-P-08	Main Office Suite Women's Room Bathroom Faucet	Lead	CHS-01-BF-P-08	5/29/2025 5:57	6/16/2025 18:44	70359784009	Lead	<1.0	5	ug/L
CHS-01-BF-P-09	Main Office Suite Men's Room Bathroom Faucet	Lead	CHS-01-BF-P-09	5/29/2025 5:58	6/16/2025 18:45	70359784010	Lead	<1.0	5	ug/L
CHS-01-SF-P-10	Health Office - C102A First Aid Room Sink Faucet	Lead	CHS-01-BS-P-10	5/29/2025 5:59	6/16/2025 18:47	70359784011	Lead	<1.0	5	ug/L
CHS-01-SF-P-11	Health Office - C102F Exam Room Sink Faucet	Lead	CHS-01-BS-P-11	5/29/2025 6:00	6/16/2025 18:48	70359784012	Lead	2.3	5	ug/L
CHS-01-BF-P-12	Health Office - Girl's Room Bathroom Faucet	Lead	CHS-01-BF-P-12	5/29/2025 6:01	6/16/2025 18:50	70359784013	Lead	<1.0	5	ug/L
CHS-01-BF-P-13	Health Office - Boy's Room Bathroom Faucet	Lead	CHS-01-BF-P-13	5/29/2025 6:02	6/16/2025 18:52	70359784014	Lead	<1.0	5	ug/L
CHS-01-SF-P-14	Guidance Suite - Kitchen Sink Faucet	Lead	CHS-01-SF-P-14	5/29/2025 6:04	6/16/2025 18:53	70359784015	Lead	<1.0	5	ug/L
CHS-01-BF-P-15	Guidance Suite - GN Left Bathroom Faucet	Lead	CHS-01-BF-P-15	5/29/2025 6:05	6/16/2025 18:55	70359784016	Lead	<1.0	5	ug/L
CHS-01-BF-P-16	Guidance Suite - GN Right Bathroom Faucet	Lead	CHS-01-BF-P-16	5/29/2025 6:06	6/16/2025 18:59	70359784017	Lead	<1.0	5	ug/L
CHS-01-CF-P-17	N115 Classroom Sink Faucet	Lead	CHS-01-CF-P-17	5/29/2025 6:08	6/16/2025 19:01	70359784018	Lead	<1.0	5	ug/L
CHS-01-SF-P-20	N108 - Faculty Sink Faucet	Lead	CHS-01-SF-P-20	5/29/2025 5:50	6/16/2025 19:02	70359784019	Lead	<1.0	5	ug/L
CHS-01-BF-P-21	N108 - Faculty - GN Left Bathroom Faucet	Lead	CHS-01-BF-P-21	5/29/2025 5:51	6/16/2025 19:04	70359784020	Lead	<1.0	5	ug/L
CHS-01-BF-P-22	N108 - Faculty - GN Right Bathroom Faucet	Lead	CHS-01-BF-P-22	5/29/2025 5:52	6/16/2025 19:06	70359784021	Lead	<1.0	5	ug/L
CHS-01-BF-P-23	Kitchen - GN Left Bathroom Faucet	Lead	CHS-01-BF-P-23	5/29/2025 5:05	6/16/2025 19:07	70359784022	Lead	<1.0	5	ug/L
CHS-01-BF-P-24	Kitchen - GN Right Bathroom Faucet	Lead	CHS-01-BF-P-24	5/29/2025 5:06	6/16/2025 19:09	70359784023	Lead	<1.0	5	ug/L
CHS-01-KF-P-25	Kitchen - Kettle Kitchen Faucet	Lead	CHS-01-KF-P-25	5/29/2025 5:07	6/17/2025 12:06	70359784024	Lead	<1.0	5	ug/L
CHS-01-KF-P-26	Kitchen - Tilt Skillet Kitchen Faucet	Lead	CHS-01-KF-P-26	5/29/2025 5:08	6/17/2025 12:10	70359784025	Lead	<1.0	5	ug/L
CHS-01-KF-P-27	Kitchen - Food Prep Center Kitchen Faucet	Lead	CHS-01-KF-P-27	5/9/2025 5:09	6/17/2025 12:17	70359784026	Lead	<1.0	5	ug/L
CHS-01-KF-P-28	Kitchen - Handwash Center Kitchen Faucet	Lead	CHS-01-KF-P-28	5/9/2025 5:10	6/17/2025 12:19	70359784027	Lead	1.8	5	ug/L
CHS-01-KF-P-29	Cafeteria - Handwash Center Back Right Kitchen Faucet	Lead	CHS-01-KF-P-29	5/9/2025 5:11	6/17/2025 12:20	70359784028	Lead	<1.0	5	ug/L
CHS-01-KF-P-30	Cafeteria - Sink Center Back by Handwash Kitchen Faucet	Lead	CHS-01-KF-P-30	5/9/2025 5:12	6/17/2025 12:22	70359784029	Lead	<1.0	5	ug/L
CHS-01-KF-P-31	Cafeteria - Steam Table Dishwash Rm Side Kitchen Faucet	Lead	CHS-01-KF-P-31	5/9/2025 5:13	6/17/2025 12:23	70359784030	Lead	<1.0	5	ug/L
CHS-01-KF-P-32	Cafeteria - Steam Table Snack Shack Side Kitchen Faucet	Lead	CHS-01-KF-P-32	5/9/2025 5:14	6/17/2025 12:25	70359784031	Lead	<1.0	5	ug/L
CHS-01-KF-P-33	Cafeteria - Dishwash Room - Handwash Kitchen Faucet	Lead	CHS-01-KF-P-33	5/9/2025 5:15	6/17/2025 13:19	70359784032	Lead	<1.0	5	ug/L
CHS-01-KF-P-34	Cafeteria - Sink - Left Side Kitchen Faucet	Lead	CHS-01-KF-P-34	5/9/2025 5:16	6/17/2025 13:21	70359784033	Lead	<1.0	5	ug/L
CHS-01-IM-P-36	Cafeteria - Ice Machine	Lead	CHS-01-IM-P-36	5/31/2025 8:45	6/17/2025 13:22	70359784034	Lead	<1.0	5	ug/L
CHS-01-BF-P-38	Boy's Room by Kitchen - L Bathroom Faucet	Lead	CHS-01-BF-P-38	5/29/2025 5:20	6/17/2025 13:24	70359784035	Lead	<1.0	5	ug/L
CHS-01-BF-P-39	Boy's Room by Kitchen - C Bathroom Faucet	Lead	CHS-01-BF-P-39	5/29/2025 5:21	6/17/2025 13:29	70359784036	Lead	<1.0	5	ug/L

CHS-01-BF-P-40	Boy's Room by Kitchen - R Bathroom Faucet	Lead	CHS-01-BF-P-40	5/29/2025 5:22	6/17/2025 13:30	70359784037	Lead	<1.0	5	ug/L
CHS-01-BF-P-41	Girl's Room by Kitchen - L Bathroom Faucet	Lead	CHS-01-BF-P-41	5/29/2025 5:23	6/17/2025 13:32	70359784038	Lead	<1.0	5	ug/L
CHS-01-BF-P-42	Girl's Room by Kitchen - C Bathroom Faucet	Lead	CHS-01-BF-P-42	5/29/2025 5:24	6/17/2025 13:34	70359784039	Lead	<1.0	5	ug/L
CHS-01-BF-P-43	Girl's Room by Kitchen - R Bathroom Faucet	Lead	CHS-01-BF-P-43	5/29/2025 5:25	6/17/2025 13:35	70359784040	Lead	<1.0	5	ug/L
CHS-01-SF-P-44	Cafeteria - Snack Shack Sink Faucet	Lead	CHS-01-SF-P-44	6/3/2025 7:30	6/17/2025 13:37	70359784041	Lead	<1.0	5	ug/L
CHS-01-DW-P-45	Gym Fountains Right Section - Right Water Fountain	Lead	CHS-01-DW-P-45	5/29/2025 5:35	6/17/2025 13:41	70359784042	Lead	<1.0	5	ug/L
CHS-01-DW-P-47	Gym Fountains Center Section Water Fountain	Lead	CHS-01-DW-P-47	5/29/2025 5:37	6/17/2025 13:49	70359784043	Lead	<1.0	5	ug/L
CHS-01-DW-P-49	Gym Fountains Left Section Water Fountain	Lead	CHS-01-DW-P-49	5/29/2025 5:39	6/17/2025 13:53	70359784044	Lead	<1.0	5	ug/L
CHS-01-DW-P-50	Gym Fountains Left Section - BF Bottle Filler	Lead	CHS-01-DW-P-50	5/29/2025 5:40	6/17/2025 13:55	70359784045	Lead	<1.0	5	ug/L
CHS-01-CF-P-55	Maintenance Break Room Sink Faucet	Lead	CHS-01-CF-P-55	5/31/2025 6:00	6/17/2025 13:56	70359784046	Lead	<1.0	5	ug/L
CHS-01-CF-P-56	C107 - South Exterior Wall Left Classroom Sink Faucet	Lead	CHS-01-CF-P-56	5/31/2025 6:28	6/17/2025 13:58	70359784047	Lead	2.3	5	ug/L
CHS-01-CF-P-57	C107 - South Exterior Wall Right Classroom Sink Faucet	Lead	CHS-01-CF-P-57	5/31/2025 6:29	6/17/2025 14:00	70359784048	Lead	<1.0	5	ug/L
CHS-01-CF-P-58	C107 - Center Classroom Sink Faucet	Lead	CHS-01-CF-P-58	5/31/2025 6:30	6/17/2025 14:01	70359784049	Lead	<1.0	5	ug/L
CHS-01-CF-P-59	C107 - North/Corridor Wall Left Classroom Sink Faucet	Lead	CHS-01-CF-P-59	5/31/2025 6:31	6/17/2025 14:06	70359784050	Lead	<1.0	5	ug/L
CHS-01-CF-P-60	C107 - North/Corridor Wall Right Classroom Sink Faucet	Lead	CHS-01-CF-P-60	5/31/2025 6:32	6/17/2025 14:07	70359784051	Lead	1.7	5	ug/L
CHS-01-BF-P-68	Gender Neutral Right by Auditorium	Lead	CHS-01-BF-P-68	5/31/2025 6:35	6/17/2025 14:09	70359784052	Lead	<1.0	5	ug/L
CHS-01-BF-P-69	Boy's Room Aud - L Bathroom Faucet	Lead	CHS-01-BF-P-69	5/31/2025 6:37	6/17/2025 14:11	70359784053	Lead	<1.0	5	ug/L
CHS-01-BF-P-70	Boy's Room Aud - C Bathroom Faucet	Lead	CHS-01-BF-P-70	5/31/2025 6:38	6/17/2025 14:12	70359784054	Lead	<1.0	5	ug/L
CHS-01-BF-P-71	Boy's Room Aud - R Bathroom Faucet	Lead	CHS-01-BF-P-71	5/31/2025 6:39	6/17/2025 14:14	70359784055	Lead	<1.0	5	ug/L
CHS-01-BF-P-72	Girl's Room Aud - L Bathroom Faucet	Lead	CHS-01-BF-P-72	5/31/2025 6:40	6/17/2025 14:15	70359784056	Lead	<1.0	5	ug/L
CHS-01-BF-P-73	Girl's Room Aud - C Bathroom Faucet	Lead	CHS-01-BF-P-73	5/31/2025 6:41	6/17/2025 14:17	70359784057	Lead	<1.0	5	ug/L
CHS-01-BF-P-74	Girl's Room Aud - R Bathroom Faucet	Lead	CHS-01-BF-P-74	5/31/2025 6:42	6/17/2025 14:19	70359784058	Lead	<1.0	5	ug/L
CHS-01-BF-P-75	Gender Neutral Left by Auditorium	Lead	CHS-01-BF-P-75	5/31/2025 6:36	6/17/2025 14:20	70359784059	Lead	<1.0	5	ug/L
CHS-01-DW-P-76	Fountain - Gym Hall Corner Bathroom Faucet	Lead	CHS-01-DW-P-76	5/31/2025 6:50	6/17/2025 14:25	70359784060	Lead	<1.0	5	ug/L
CHS-01-BF-P-77	Stage BR across from Band Room Bathroom Faucet	Lead	CHS-01-BF-P-77	5/31/2025 6:52	6/17/2025 14:26	70359784061	Lead	<1.0	5	ug/L
CHS-01-CF-P-78	P112 Band Room - L Classroom Sink Faucet	Lead	CHS-01-CF-P-78	5/31/2025 6:53	6/17/2025 14:31	70359784062	Lead	<1.0	5	ug/L
CHS-01-CF-P-79	P112 - Band - R Classroom Sink Faucet	Lead	CHS-01-CF-P-79	5/31/2025 6:54	6/17/2025 14:35	70359784063	Lead	1.5	5	ug/L
CHS-01-DW-P-80	Fountain by A102 - L Water Fountain	Lead	CHS-01-DW-P-80	5/31/2025 6:55	6/17/2025 14:43	70359784064	Lead	<1.0	5	ug/L
CHS-01-DW-P-81	Bottle Filler by A102 Bottle Filler	Lead	CHS-01-DW-P-81	5/31/2025 6:56	6/17/2025 14:44	70359784065	Lead	<1.0	5	ug/L
CHS-01-DW-P-82	Fountain by A102 - R Water Fountain	Lead	CHS-01-DW-P-82	5/31/2025 6:57	6/17/2025 14:46	70359784066	Lead	<1.0	5	ug/L
CHS-01-SF-P-83	Trainer's Room Sink Faucet	Lead	CHS-01-SF-P-83	5/31/2025 7:00	6/17/2025 14:47	70359784067	Lead	<1.0	5	ug/L
CHS-01-IM-P-84	Training Room Ice Machine	Lead	CHS-01-IM-P-84	5/31/2025 9:01	6/17/2025 14:49	70359784068	Lead	<1.0	5	ug/L
CHS-01-BF-P-85	Boy's Locker Bathroom - Far L Bathroom Faucet	Lead	CHS-01-BF-P-85	5/31/2025 6:03	6/17/2025 14:51	70359784069	Lead	2.7	5	ug/L
CHS-01-BF-P-86	Boy's Locker Bathroom - L Center Bathroom Faucet	Lead	CHS-01-BF-P-86	5/31/2025 6:04	6/17/2025 14:52	70359784070	Lead	1.2	5	ug/L
CHS-01-BF-P-87	Boy's Locker Bathroom - R Center Bathroom Faucet	Lead	CHS-01-BF-P-87	5/31/2025 6:05	6/17/2025 14:54	70359784071	Lead	<1.0	5	ug/L
CHS-01-BF-P-88	Boy's Locker Bathroom - Far R Bathroom Faucet	Lead	CHS-01-BF-P-88	5/31/2025 6:06	6/17/2025 14:55	70359784072	Lead	<1.0	5	ug/L
CHS-01-DW-P-89	L Fountain by Boy's Locker Water Fountain	Lead	CHS-01-DW-P-89	5/31/2025 6:07	6/17/2025 14:57	70359784073	Lead	<1.0	5	ug/L
CHS-01-DW-P-90	R Fountain by Boy's Locker Water Fountain	Lead	CHS-01-DW-P-90	5/31/2025 6:08	6/17/2025 15:02	70359784074	Lead	<1.0	5	ug/L
CHS-01-BF-P-91	Boy's Coaches Room Bathroom Faucet	Lead	CHS-01-BF-P-91	5/31/2025 6:10	6/17/2025 15:03	70359784075	Lead	<1.0	5	ug/L
CHS-01-BF-P-92	Boy's PE Office Bathroom Bathroom Faucet	Lead	CHS-01-BF-P-92	5/31/2025 6:09	6/17/2025 15:05	70359784076	Lead	<1.0	5	ug/L
CHS-01-BF-P-93	Girl's PE Office Bathroom Bathroom Faucet	Lead	CHS-01-BF-P-93	5/31/2025 6:11	6/17/2025 15:07	70359784077	Lead	<1.0	5	ug/L
CHS-01-BF-P-94	Girl's Coaches Room Bathroom Faucet	Lead	CHS-01-BF-P-94	5/31/2025 6:12	6/17/2025 15:08	70359784078	Lead	<1.0	5	ug/L
CHS-01-DW-P-95	L - Fountain by Girl's Locker Water Fountain	Lead	CHS-01-DW-P-95	5/31/2025 6:13	6/17/2025 15:10	70359784079	Lead	<1.0	5	ug/L
CHS-01-DW-P-96	R - Fountain by Girl's Locker Water Fountain	Lead	CHS-01-DW-P-96	5/31/2025 6:14	6/17/2025 15:11	70359784080	Lead	<1.0	5	ug/L

CHS-01-DW-P-96A	R - Bottle Filler by Girl's Locker Water Fountain	Lead	CHS-01-DW-P-96A	5/31/2025 6:15	6/17/2025 15:13	70359784081	Lead	<1.0	5	ug/L
CHS-01-BF-P-97	Girl's Locker Bathroom - Far L Bathroom Faucet	Lead	CHS-01-BF-P-97	5/29/2025 6:28	6/17/2025 15:21	70359784082	Lead	1.9	5	ug/L
CHS-01-BF-P-98	Girl's Locker Bathroom - L Center Bathroom Faucet	Lead	CHS-01-BF-P-98	5/29/2025 6:29	6/17/2025 15:25	70359784083	Lead	1.3	5	ug/L
CHS-01-BF-P-99	Girl's Locker Bathroom - R Center Bathroom Faucet	Lead	CHS-01-BF-P-99	5/29/2025 5:30	6/17/2025 15:29	70359784084	Lead	<1.0	5	ug/L
CHS-01-BF-P-100	Girl's Locker Bathroom - Far R Bathroom Faucet	Lead	CHS-01-BF-P-100	5/29/2025 5:31	6/17/2025 15:31	70359784085	Lead	<1.0	5	ug/L
CHS-01-BF-P-101	Varsity Officials Men's/Women's - L Bathroom Faucet	Lead	CHS-01-BF-P-101	5/31/2025 6:19	6/17/2025 15:33	70359784086	Lead	3.4	5	ug/L
CHS-01-BF-P-102	Varsity Officials Men's/Women's - C Bathroom Faucet	Lead	CHS-01-BF-P-102	5/31/2025 6:20	6/17/2025 15:34	70359784087	Lead	2.9	5	ug/L
CHS-01-BF-P-103	Varsity Officials Men's/Women's - R Bathroom Faucet	Lead	CHS-01-BF-P-103	5/31/2025 6:21	6/17/2025 15:39	70359784088	Lead	<1.0	5	ug/L
CHS-01-BF-P-104	JV Officials Men's/Women's - L Bathroom Faucet	Lead	CHS-01-BF-P-104	5/31/2025 6:22	6/17/2025 15:41	70359784089	Lead	2.2	5	ug/L
CHS-01-BF-P-105	JV Officials Men's/Women's - 2nd Bathroom Faucet	Lead	CHS-01-BF-P-105	5/31/2025 6:23	6/17/2025 15:42	70359784090	Lead	29.9	5	ug/L
CHS-01-BF-P-106	JV Officials Men's/Women's - 3rd Bathroom Faucet	Lead	CHS-01-BF-P-106	5/31/2025 6:24	6/17/2025 15:44	70359784091	Lead	22.5	5	ug/L
CHS-01-BF-P-107	JV Officials Men's/Women's - 4th Bathroom Faucet	Lead	CHS-01-BF-P-107	5/31/2025 6:25	6/17/2025 15:45	70359784092	Lead	10.9	5	ug/L
CHS-01-BF-P-108	JV Officials Men's/Women's - 5th Bathroom Faucet	Lead	CHS-01-BF-P-108	5/31/2025 6:26	6/17/2025 15:47	70359784093	Lead	5.3	5	ug/L
CHS-02-BF-P-109	Boy's Room by S212 - L Bathroom Faucet	Lead	CHS-02-BF-P-109	5/31/2025 7:15	6/17/2025 15:48	70359784094	Lead	<1.0	5	ug/L
CHS-02-BF-P-110	Boy's Room by S212 - R Bathroom Faucet	Lead	CHS-02-BF-P-110	5/31/2025 7:16	6/17/2025 15:50	70359784095	Lead	<1.0	5	ug/L
CHS-02-DW-P-111	Fountain by S211 Water Fountain	Lead	CHS-02-DW-P-111	5/31/2025 7:17	6/17/2025 15:52	70359784096	Lead	<1.0	5	ug/L
CHS-02-SF-P-112	S222 - Faculty Sink Faucet	Lead	CHS-02-SF-P-112	5/31/2025 7:20	6/17/2025 15:53	70359784097	Lead	<1.0	5	ug/L
CHS-02-DW-P-113	Fountain by S203A Water Fountain	Lead	CHS-02-DW-P-113	5/31/2025 7:23	6/17/2025 15:58	70359784098	Lead	<1.0	5	ug/L
CHS-02-BF-P-114	Girl's Room by S205 - L Bathroom Faucet	Lead	CHS-02-BF-P-114	5/31/2025 7:24	6/17/2025 15:59	70359784099	Lead	1.1	5	ug/L
CHS-02-BF-P-115	Girl's Room by S205 - R Bathroom Faucet	Lead	CHS-02-BF-P-115	5/31/2025 7:25	6/17/2025 16:01	70359784100	Lead	<1.0	5	ug/L
CHS-03-BF-P-116	Boy's Room by S311 - L Bathroom Faucet	Lead	CHS-03-BF-P-116	5/31/2025 7:30	6/17/2025 16:03	70359784101	Lead	<1.0	5	ug/L
CHS-03-BF-P-117	Boy's Room by S311 - R Bathroom Faucet	Lead	CHS-03-BF-P-117	5/31/2025 7:31	6/17/2025 16:07	70359784102	Lead	<1.0	5	ug/L
CHS-03-DW-P-118	Fountain by S310 Water Fountain	Lead	CHS-03-DW-P-118	5/31/2025 7:32	6/17/2025 16:12	70359784103	Lead	<1.0	5	ug/L
CHS-03-BF-P-119	Left Faculty Restroom by S312 Bathroom Faucet	Lead	CHS-03-BF-P-119	5/31/2025 7:35	6/17/2025 16:19	70359784104	Lead	1.4	5	ug/L
CHS-03-BF-P-120	Right Faculty Restroom by S312 Bathroom Faucet	Lead	CHS-03-BF-P-120	5/31/2025 7:36	6/17/2025 16:21	70359784105	Lead	<1.0	5	ug/L
CHS-03-SF-P-121	3rd Fl Faculty Area Pantry Sink Faucet	Lead	CHS-03-SF-P-121	5/31/2025 7:38	6/17/2025 16:22	70359784106	Lead	<1.0	5	ug/L
CHS-03-BF-P-124	Women's Room by S304 - L Bathroom Faucet	Lead	CHS-03-BF-P-124	5/31/2025 7:40	6/17/2025 16:24	70359784107	Lead	<1.0	5	ug/L
CHS-03-BF-P-125	Women's Room by S304 - R Bathroom Faucet	Lead	CHS-03-BF-P-125	5/31/2025 7:41	6/17/2025 16:25	70359784108	Lead	1.1	5	ug/L
CHS-02-SF-P-126	Library Work Room Sink Faucet	Lead	CHS-02-SF-P-126	5/31/2025 7:45	6/17/2025 16:27	70359784109	Lead	<1.0	5	ug/L
CHS-02-BF-P-127	Library Work GN Left Bathroom Faucet	Lead	CHS-02-BF-P-127	5/31/2025 7:46	6/17/2025 16:29	70359784110	Lead	<1.0	5	ug/L
CHS-02-BF-P-128	Library Work GN Right Bathroom Faucet	Lead	CHS-02-BF-P-128	5/31/2025 7:47	6/17/2025 16:30	70359784111	Lead	<1.0	5	ug/L
CHS-02-SF-P-129	N222 Faculty Sink Faucet	Lead	CHS-02-SF-P-129	5/31/2025 7:50	6/17/2025 16:35	70359784112	Lead	<1.0	5	ug/L
CHS-02-BF-P-130	Boy's Room by N213 - L Bathroom Faucet	Lead	CHS-02-BF-P-130	5/31/2025 7:51	6/17/2025 16:37	70359784113	Lead	<1.0	5	ug/L
CHS-02-BF-P-131	Boy's Room by N213 - R Bathroom Faucet	Lead	CHS-02-BF-P-131	5/31/2025 7:52	6/17/2025 16:38	70359784114	Lead	<1.0	5	ug/L
CHS-02-DW-P-132	Fountain by N211 Water Fountain	Lead	CHS-02-DW-P-132	5/31/2025 7:53	6/17/2025 16:40	70359784115	Lead	<1.0	5	ug/L
CHS-02-BF-P-133	Girl's Room by N205 - L Bathroom Faucet	Lead	CHS-02-BF-P-133	5/31/2025 8:00	6/17/2025 16:41	70359784116	Lead	<1.0	5	ug/L
CHS-02-BF-P-134	Girl's Room by N205 - R Bathroom Faucet	Lead	CHS-02-BF-P-134	5/31/2025 8:01	6/17/2025 16:43	70359784117	Lead	<1.0	5	ug/L
CHS-02-DW-P-135	Fountain by N203 Water Fountain	Lead	CHS-02-DW-P-135	5/31/2025 8:02	6/17/2025 16:45	70359784118	Lead	<1.0	5	ug/L
CHS-02-DW-P-136	Fountain by N204 Bottle Filler	Lead	CHS-02-DW-P-136	5/31/2025 8:03	6/17/2025 16:46	70359784119	Lead	<1.0	5	ug/L
CHS-03-BF-P-137	3rd Fl GN North Left Faculty Bathroom Faucet	Lead	CHS-03-BF-P-137	5/31/2025 8:06	6/17/2025 16:48	70359784120	Lead	<1.0	5	ug/L
CHS-03-BF-P-138	3rd Fl North GN Right Faculty Bathroom Faucet	Lead	CHS-03-BF-P-138	5/31/2025 8:07	6/17/2025 16:49	70359784121	Lead	<1.0	5	ug/L
CHS-03-BF-P-139	Boy's Room by N311 - L Bathroom Faucet	Lead	CHS-03-BF-P-139	5/31/2025 8:09	6/17/2025 16:57	70359784122	Lead	<1.0	5	ug/L
CHS-03-BF-P-140	Boy's Room by N311 - R Bathroom Faucet	Lead	CHS-03-BF-P-140	5/31/2025 8:10	6/17/2025 17:02	70359784123	Lead	<1.0	5	ug/L
CHS-03-DW-P-141	Fountain by N310 Water Fountain	Lead	CHS-03-DW-P-141	5/31/2025 8:11	6/17/2025 17:06	70359784124	Lead	<1.0	5	ug/L

CHS-03-SF-P-142	3rd Floor North Faculty Pantry Sink Sink Faucet	Lead	CHS-03-SF-P-142	5/31/2025 8:13	6/17/2025 17:08	70359784125	Lead	<1.0	5	ug/L
CHS-03-BF-P-144	Girl's Room by N304 - R Bathroom Faucet	Lead	CHS-03-BF-P-144	5/31/2025 8:15	6/17/2025 17:12	70359784126	Lead	<1.0	5	ug/L
CHS-03-DW-P-145	Fountain by N303 Water Fountain	Lead	CHS-03-DW-P-145	5/31/2025 8:16	6/17/2025 17:14	70359784127	Lead	<1.0	5	ug/L
CHS-03-DW-P-145A	Fountain by N303 Bottle Filler	Lead	CHS-03-DW-P-145	5/31/2025 8:17	6/17/2025 17:15	70359784128	Lead	<1.0	5	ug/L
CHS-02-BF-P-146	2nd Floor C-Wing Girl's Rm - L Bathroom Faucet	Lead	CHS-02-BF-P-146	5/31/2025 8:30	6/17/2025 17:17	70359784129	Lead	<1.0	5	ug/L
CHS-02-BF-P-147	2nd Floor C-Wing Girl's Rm - C Bathroom Faucet	Lead	CHS-02-BF-P-147	5/31/2025 8:31	6/17/2025 17:19	70359784130	Lead	2.5	5	ug/L
CHS-02-BF-P-148	2nd Floor C-Wing Girl's Rm - R Bathroom Faucet	Lead	CHS-02-BF-P-148	5/31/2025 8:32	6/17/2025 17:20	70359784131	Lead	9.2	5	ug/L
CHS-02-BF-P-149	2nd Floor C-Wing Boy's Rm - L Bathroom Faucet	Lead	CHS-02-BF-P-149	5/31/2025 8:33	6/17/2025 17:22	70359784132	Lead	1.2	5	ug/L
CHS-02-BF-P-150	2nd Floor C-Wing Boy's Rm - C Bathroom Faucet	Lead	CHS-02-BF-P-150	5/31/2025 8:34	6/17/2025 17:23	70359784133	Lead	1	5	ug/L
CHS-02-BF-P-151	2nd Floor C-Wing Boy's Rm - R Bathroom Faucet	Lead	CHS-02-BF-P-151	5/31/2025 8:35	6/17/2025 17:25	70359784134	Lead	4.1	5	ug/L