

PACE LABS										
Pace Labs address: 14 Walker Way, Albany, NY 12205										
District Name: East Greenbush CSD										
School Name: Donald P. Sutherland Elementary School										
Street address: 4 John St, Nassau, NY 12123										
Sample ID	Donald P. Sutherland Location	Analysis Required	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
DPS-01-CF-P-01	6 - Conference Room Sink Faucet	Lead	DPS-01-CF-P-01	5/6/2025 8:00	5/28/2025 12:24	70354497001	Lead	9.7	5	ug/L
DPS-01-SF-P-02	Library Sink Faucet	Lead	DPS-01-SF-P-02	5/6/2025 8:01	5/28/2025 12:25	70354497002	Lead	11.4	5	ug/L
DPS-01-BF-P-03	Ladies Room - L Bathroom Faucet	Lead	DPS-01-BF-P-03	5/6/2025 8:02	5/28/2025 12:30	70354497003	Lead	6.8	5	ug/L
DPS-01-BF-P-04	Ladies Room - R Bathroom Faucet	Lead	DPS-01-BF-P-04	5/6/2025 8:03	5/28/2025 12:31	70354497004	Lead	5.2	5	ug/L
DPS-01-BF-P-05	Mens Room Bathroom Faucet	Lead	DPS-01-BF-P-05	5/6/2025 8:04	5/28/2025 12:32	70354497005	Lead	10.9	5	ug/L
DPS-01-SF-P-10	Main Office Book Room Sink Faucet	Lead	DPS-01-SF-P-10	5/6/2025 8:05	5/28/2025 12:34	70354497006	Lead	5.7	5	ug/L
DPS-01-CF-P-12	18 - R Faucet Classroom Sink Faucet	Lead	DPS-01-CF-P-12	5/6/2025 8:07	5/28/2025 12:35	70354497007	Lead	4.7	5	ug/L
DPS-01-BF-P-13	Boys Room by 13 - L Bathroom Faucet	Lead	DPS-01-BF-P-13	5/6/2025 8:08	5/28/2025 12:40	70354497008	Lead	2.4	5	ug/L
DPS-01-BF-S-14	Boys Room by 13 - R Bathroom Faucet	Lead	DPS-01-BF-P-14	5/6/2025 8:09	5/28/2025 12:47	70354497009	Lead	1.9	5	ug/L
DPS-01-SF-P-15	Faculty Room Sink Faucet	Lead	DPS-01-SF-P-15	5/6/2025 8:10	5/28/2025 12:51	70354497010	Lead	3.6	5	ug/L
DPS-01-KF-P-16	Kitchen - Handwashing by Cooler Sink Faucet	Lead	DPS-01-KF-P-16	5/6/2025 7:07	5/28/2025 12:53	70354497011	Lead	14	5	ug/L
DPS-01-KF-P-17	Kitchen - Food Prep Sink Faucet	Lead	DPS-01-KF-P-17	5/6/2025 7:05	5/28/2025 12:54	70354497012	Lead	<1.0	5	ug/L
DPS-01-KF-P-18	Kitchen - Handwashing by Door Sink Faucet	Lead	DPS-01-KF-P-18	5/6/2025 7:00	5/28/2025 12:56	70354497013	Lead	2	5	ug/L
DPS-01-KF-P-19	Kitchen Sink Faucet by window	Lead	DPS-01-KF-P-19	5/6/2025 7:02	5/28/2025 12:57	70354497014	Lead	<1.0	5	ug/L
DPS-01-KF-P-20	Kitchen Sink Faucet	Lead	DPS-01-KF-P-20	5/6/2025 7:04	5/28/2025 12:59	70354497015	Lead	4.2	5	ug/L
DPS-01-CF-P-21	26 Bathroom Faucet	Lead	DPS-01-CF-P-21	5/6/2025 8:11	5/28/2025 13:00	70354497016	Lead	<1.0	5	ug/L
DPS-01-CF-P-22	28 - Faculty Sink Faucet	Lead	DPS-01-CF-P-22	5/6/2025 8:13	5/28/2025 13:04	70354497017	Lead	2.6	5	ug/L
DPS-01-CF-P-23	34 Classroom Sink Faucet	Lead	DPS-01-CF-P-23	5/6/2025 8:25	5/28/2025 13:06	70354497018	Lead	2.4	5	ug/L
DPS-01-CF-P-24	32 Classroom Sink Faucet	Lead	DPS-01-CF-P-24	5/6/2025 8:26	5/28/2025 13:07	70354497019	Lead	1.8	5	ug/L
DPS-01-CF-P-27	35 Classroom Sink Faucet	Lead	DPS-01-CF-P-27	5/6/2025 8:27	5/28/2025 13:09	70354497020	Lead	1.9	5	ug/L
DPS-01-CF-P-29	29 Classroom Sink Faucet art room	Lead	DPS-01-CF-P-29	5/6/2025 8:14	5/28/2025 13:10	70354497021	Lead	1.6	5	ug/L
DPS-01-CF-P-30	37 Classroom Sink Faucet	Lead	DPS-01-CF-P-30	5/6/2025 8:29	5/28/2025 13:12	70354497022	Lead	2.2	5	ug/L
DPS-01-CF-P-31	44 - Outside Bathroom Classroom Sink Faucet	Lead	DPS-01-CF-P-31	5/6/2025 8:30	5/28/2025 13:13	70354497023	Lead	1.7	5	ug/L
DPS-01-CF-P-32	44 Classroom Sink Faucet	Lead	DPS-01-CF-P-32	5/6/2025 8:31	5/28/2025 13:14	70354497024	Lead	8.9	5	ug/L
DPS-01-CF-P-33	43 - Outside Bathroom Classroom Sink Faucet	Lead	DPS-01-CF-P-33	5/6/2025 8:32	5/28/2025 13:16	70354497025	Lead	2.5	5	ug/L
DPS-01-CF-P-34	43 Classroom Sink Faucet	Lead	DPS-01-CF-P-34	5/6/2025 8:33	5/28/2025 13:17	70354497026	Lead	6.1	5	ug/L
DPS-01-CF-P-35	42 - Outside Bathroom Classroom Sink Faucet	Lead	DPS-01-CF-P-35	5/6/2025 8:34	5/28/2025 13:22	70354497027	Lead	3.6	5	ug/L
DPS-01-CF-P-36	42 Classroom Sink Faucet	Lead	DPS-01-CF-P-36	5/6/2025 8:35	5/28/2025 13:26	70354497028	Lead	11.8	5	ug/L
DPS-01-CF-P-37	41 - Outside Bathroom Classroom Sink Faucet	Lead	DPS-01-CF-P-37	5/6/2025 8:36	5/28/2025 13:30	70354497029	Lead	1.6	5	ug/L
DPS-01-CF-P-38	41 Classroom Sink Faucet	Lead	DPS-01-CF-P-38	5/6/2025 8:37	5/28/2025 13:35	70354497030	Lead	36.2	5	ug/L
DPS-01-CF-P-39	40 - Outside Bathroom Classroom Sink Faucet	Lead	DPS-01-CF-P-39	5/6/2025 8:38	5/28/2025 13:39	70354497031	Lead	<1.0	5	ug/L
DPS-01-CF-P-40	40 Classroom Sink Faucet	Lead	DPS-01-CF-P-40	5/6/2025 8:39	5/28/2025 13:40	70354497032	Lead	6.4	5	ug/L
DPS-01-SF-P-41	30 - Nurse Sink Faucet	Lead	DPS-01-SF-P-41	5/6/2025 8:40	5/28/2025 13:42	70354497033	Lead	11.4	5	ug/L
DPS-01-BF-P-42	30 - Nurse Bathroom Faucet	Lead	DPS-01-BF-P-42	5/6/2025 8:41	5/28/2025 13:43	70354497034	Lead	5.2	5	ug/L

DPS-01-BF-P-43	Boys Locker Room Bathroom Faucet	Lead	DPS-01-BF-P-43	5/6/2025 8:42	5/28/2025 13:45	70354497035	Lead	3.8	5	ug/L
DPS-01-BF-P-44	Girls Locker Room Bathroom Faucet	Lead	DPS-01-BF-P-44	5/6/2025 8:43	5/28/2025 13:46	70354497036	Lead	4.1	5	ug/L
DPS-01-BF-P-45	Girls Room Gym Corridor Bathroom Faucet	Lead	DPS-01-BF-P-45	5/6/2025 8:44	5/28/2025 13:48	70354497037	Lead	7.5	5	ug/L
DPS-01-BF-P-46	Boys Room Gym Corridor Bathroom Faucet	Lead	DPS-01-BF-P-46	5/6/2025 8:45	5/28/2025 13:49	70354497038	Lead	2.8	5	ug/L
DPS-01-CF-P-47	61 Classroom Sink Faucet	Lead	DPS-01-CF-P-47	5/6/2025 8:46	5/28/2025 13:50	70354497039	Lead	1.8	5	ug/L
DPS-01-CF-S-48	60 Classroom Sink Faucet	Lead	DPS-01-CF-S-48	5/6/2025 8:47	5/28/2025 13:52	70354497040	Lead	2.1	5	ug/L
DPS-01-CF-P-49	63 Classroom Sink Faucet	Lead	DPS-01-CF-P-49	5/6/2025 8:48	5/28/2025 13:56	70354497041	Lead	5.8	5	ug/L
DPS-01-CF-P-50	62 Classroom Sink Faucet	Lead	DPS-01-CF-P-50	5/6/2025 8:49	5/28/2025 13:58	70354497042	Lead	2.9	5	ug/L
DPS-01-CF-P-51	65 Classroom Sink Faucet	Lead	DPS-01-CF-P-51	5/6/2025 8:50	5/28/2025 13:59	70354497043	Lead	1.2	5	ug/L
DPS-01-CF-P-52	64 Classroom Sink Faucet	Lead	DPS-01-CF-P-52	5/7/2025 7:19	5/28/2025 14:01	70354497044	Lead	3.4	5	ug/L
DPS-01-KF-P-53	Kitchen - Steam Table Kitchen Faucet	Lead	DPS-01-KF-P-53	5/7/2025 7:01	5/28/2025 14:02	70354497045	Lead	10.3	5	ug/L
DPS-01-CF-P-54	Rm 36 Classroom Sink	Lead	DPS-01-CF-P-54	5/6/2025 8:28	5/28/2025 14:04	70354497046	Lead	3.1	5	ug/L
DPS-01-CF-P-55	Rm 26 Classroom Sink	Lead	DPS-01-CF-P-55	5/6/2025 8:12	5/28/2025 14:05	70354497047	Lead	4.8	5	ug/L
DPS-01-DW-P-56	Water fountain by main office	Lead	DPS-01-DW-P-56	5/7/2025 7:08	5/28/2025 14:09	70354497048	Lead	<1.0	5	ug/L
DPS-01-DW-P-57	Bottle Filler by main office	Lead	DPS-01-DW-P-57	5/7/2025 7:09	5/28/2025 14:17	70354497049	Lead	<1.0	5	ug/L
DPS-01-DW-P-58	Water fountain by basement access	Lead	DPS-01-DW-P-58	5/7/2025 7:07	5/28/2025 14:21	70354497050	Lead	6.9	5	ug/L
DPS-01-DW-P-59	Water fountain outside gym	Lead	DPS-01-DW-P-59	5/7/2025 7:17	5/28/2025 14:23	70354497051	Lead	<1.0	5	ug/L
DPS-01-DW-P-60	Bottle filler outside gym	Lead	DPS-01-DW-P-60	5/7/2025 7:16	5/28/2025 14:24	70354497052	Lead	<1.0	5	ug/L
DPS-01-DW-P-61	Water fountain outside rm 44	Lead	DPS-01-DW-P-61	5/7/2025 7:14	5/28/2025 14:25	70354497053	Lead	<1.0	5	ug/L
DPS-01-DW-P-62	bottle filler outside rm 44	Lead	DPS-01-DW-P-62	5/7/2025 7:13	5/28/2025 14:27	70354497054	Lead	<1.0	5	ug/L