

PACE LABS										
Pace Labs address: 14 Walker Way, Albany, NY 12205										
District Name: East Greenbush CSD										
School Name: Genet Elementary School										
Street address: 29 Englewood Ave, East Greenbush, NY 12061										
Sample ID	Genet Location	Analysis Required	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
GENET-01-CF-P-01	DO - Break Room Classroom Sink Faucet	Lead	GENET-01-CF-P-01	5/15/2025 6:08	5/30/2025 17:14	70355681001	Lead	<1.0	5	ug/L
GENET-01-CF-P-09	114 Classroom Sink Faucet	Lead	GENET-01-CF-P-09	5/15/2025 5:59	5/30/2025 17:15	70355681002	Lead	<1.0	5	ug/L
GENET-01-DW-P-13	Bottle filler by Womens Room Water Fountain	Lead	GENET-01-DW-P-13	5/15/2025 5:57	5/30/2025 17:20	70355681003	Lead	<1.0	5	ug/L
GENET-01-DW-P-14	Fountain by Womens Room Water Fountain	Lead	GENET-01-DW-P-14	5/15/2025 5:56	5/30/2025 17:25	70355681004	Lead	<1.0	5	ug/L
GENET-01-SF-P-18	117 - Faculty Room Sink Faucet	Lead	GENET-01-SF-P-18	5/15/2025 5:51	5/30/2025 17:33	70355681005	Lead	1.3	5	ug/L
GENET-01-SF-P-18	125 Classroom Sink Faucet	Lead	GENET-01-SF-P-19	5/15/2025 5:48	5/30/2025 17:34	70355681006	Lead	<1.0	5	ug/L
GENET-01-DW-P-20	Cafeteria - Water Fountain Water Fountain	Lead	GENET-01-DW-P-20	5/15/2025 5:37	5/30/2025 17:36	70355681007	Lead	<1.0	5	ug/L
GENET-01-KF-P-21	Kitchen - Food Prep Entrance Kitchen Faucet	Lead	GENET-01-KF-P-21	5/15/2025 5:31	5/30/2025 17:37	70355681008	Lead	<1.0	5	ug/L
GENET-01-KF-P-22	Kitchen - Hand Washing South Kitchen Faucet	Lead	GENET-01-KF-P-22	5/15/2025 5:33	5/30/2025 17:39	70355681009	Lead	<1.0	5	ug/L
GENET-01-KF-P-23	Kitchen - Food Prep at Office Kitchen Faucet	Lead	GENET-01-KF-P-23	5/15/2025 5:34	5/30/2025 17:41	70355681010	Lead	<1.0	5	ug/L
GENET-01-DW-P-24	Water fountain outside gym by 168	Lead	GENET-01-DW-P-24	5/15/2025 6:26	5/30/2025 17:42	70355681011	Lead	<1.0	5	ug/L
GENET-01-DW-P-32	Bottle filler outside gym by 168	Lead	GENET-01-DW-P-32	5/15/2025 6:25	5/30/2025 17:44	70355681012	Lead	<1.0	5	ug/L
GENET-01-DW-P-25	Cafeteria Bottle Filler with #20	Lead	GENET-01-DW-P-25	5/15/2025 5:38	5/30/2025 17:45	70355681013	Lead	<1.0	5	ug/L
GENET-01-KF-P-26	Kitchen - Steam Table Kitchen Faucet	Lead	GENET-01-KF-P-26	5/15/2025 5:30	5/30/2025 17:47	70355681014	Lead	<1.0	5	ug/L
GENET-01-CF-P-27	128 Classroom Sink Faucet	Lead	GENET-01-CF-P-27	5/15/2025 5:46	5/30/2025 17:52	70355681015	Lead	<1.0	5	ug/L
GENET-01-CF-P-29	126 Classroom Sink Faucet	Lead	GENET-01-CF-P-29	5/15/2025 5:47	5/30/2025 17:53	70355681016	Lead	<1.0	5	ug/L
GENET-01-SF-P-30	118 - Principals Office Sink Faucet	Lead	GENET-01-SF-P-30	5/15/2025 6:12	5/30/2025 17:55	70355681017	Lead	<1.0	5	ug/L
GENET-01-CF-P-31	149 Sink Faucet	Lead	GENET-01-CF-P-31	5/15/2025 6:14	5/30/2025 17:57	70355681018	Lead	<1.0	5	ug/L
GENET-01-SF-P-34	Nurse Bathroom Faucet	Lead	GENET-01-SF-P-34	5/15/2025 6:17	5/30/2025 17:58	70355681019	Lead	<1.0	5	ug/L
GENET-01-BF-P-35	Boy's Locker Room Sink Faucet	Lead	GENET-01-BF-P-35	5/15/2025 6:20	5/30/2025 18:00	70355681020	Lead	<1.0	5	ug/L
GENET-01-BF-P-36	Girls Locker Room Sink Faucet	Lead	GENET-01-BF-P-36	5/15/2025 6:22	5/30/2025 18:02	70355681021	Lead	12.3	5	ug/L
GENET-01-CF-P-37	171 Classroom Sink Faucet	Lead	GENET-01-CF-P-37	5/15/2025 6:28	5/30/2025 18:03	70355681022	Lead	<1.0	5	ug/L
GENET-01-CF-P-39	172 Sink Faucet	Lead	GENET-01-CF-P-39	5/15/2025 6:30	5/30/2025 18:11	70355681023	Lead	<1.0	5	ug/L
GENET-01-CF-P-40	174 -Classroom Sink Faucet	Lead	GENET-01-CF-P-40	5/15/2025 6:32	5/30/2025 18:13	70355681024	Lead	<1.0	5	ug/L
GENET-01-DW-P-42	Fountain Outside 176 Water Fountain	Lead	GENET-01-DW-P-42	5/15/2025 6:36	5/30/2025 18:17	70355681025	Lead	<1.0	5	ug/L
GENET-01-CF-P-43	177 Classroom Sink Faucet	Lead	GENET-01-CF-P-43	5/15/2025 6:38	5/30/2025 18:22	70355681026	Lead	<1.0	5	ug/L
GENET-01-CF-P-46	176 Classroom Sink Faucet	Lead	GENET-01-CF-P-46	5/15/2025 6:43	5/30/2025 18:24	70355681027	Lead	<1.0	5	ug/L
GENET-01-CF-P-48	178 Classroom Sink Faucet	Lead	GENET-01-CF-P-48	5/15/2025 6:44	5/30/2025 18:25	70355681028	Lead	<1.0	5	ug/L
GENET-01-CF-P-50	179 Classroom Sink Faucet	Lead	GENET-01-CF-P-50	5/15/2025 6:46	5/30/2025 18:30	70355681029	Lead	<1.0	5	ug/L
GENET-02-CF-P-51	245 Classroom Sink Faucet	Lead	GENET-02-CF-P-51	5/15/2025 7:45	5/30/2025 18:32	70355681030	Lead	<1.0	5	ug/L
GENET-02-CF-P-53	248 Classroom Sink Faucet	Lead	GENET-02-CF-P-53	5/15/2025 7:44	5/30/2025 18:33	70355681031	Lead	<1.0	5	ug/L
GENET-02-CF-P-55	246 Classroom Sink Faucet	Lead	GENET-02-CF-P-55	5/15/2025 7:43	5/30/2025 18:35	70355681032	Lead	<1.0	5	ug/L
GENET-02-DW-P-55	Fountain Outside 244 Water Fountain	Lead	GENET-02-DW-P-56	5/15/2025 7:42	5/30/2025 18:36	70355681033	Lead	<1.0	5	ug/L
GENET-02-CF-P-58	244 Classroom Sink Faucet	Lead	GENET-02-CF-P-58	5/15/2025 7:40	5/30/2025 18:38	70355681034	Lead	<1.0	5	ug/L

GENET-02-CF-P-59	242 Classroom Sink Faucet	Lead	GENET-02-CF-P-59	5/15/2025 7:38	5/30/2025 18:40	70355681035	Lead	<1.0	5	ug/L
GENET-02-CF-P-62	238 Classroom Sink Faucet	Lead	GENET-02-CF-P-62	5/15/2025 7:35	5/30/2025 18:41	70355681036	Lead	<1.0	5	ug/L
GENET-02-CF-P-63	231 Classroom Sink Faucet	Lead	GENET-02-CF-P-63	5/15/2025 7:33	5/30/2025 18:43	70355681037	Lead	<1.0	5	ug/L
GENET-02-BF-P-64	231 Bathroom Faucet	Lead	GENET-02-BF-P-64	5/15/2025 7:32	5/30/2025 18:44	70355681038	Lead	<1.0	5	ug/L
GENET-02-CF-P-65	229 Classroom Sink Faucet	Lead	GENET-02-CF-P-65	5/15/2025 7:30	5/30/2025 18:49	70355681039	Lead	<1.0	5	ug/L
GENET-02-CF-P-66	227 Classroom Sink Faucet	Lead	GENET-02-CF-P-66	5/15/2025 7:28	5/30/2025 18:51	70355681040	Lead	<1.0	5	ug/L
GENET-02-SF-P-67	226 - Faculty 2nd Floor Sink Faucet	Lead	GENET-02-SF-P-67	5/15/2025 7:25	5/30/2025 18:52	70355681041	Lead	<1.0	5	ug/L
GENET-02-BF-P-68	226 - GN Bathroom Faucet across from 238	Lead	GENET-02-BF-P-68	5/15/2025 7:24	5/30/2025 18:54	70355681042	Lead	<1.0	5	ug/L
GENET-02-CF-P-70	214 Classroom Sink Faucet	Lead	GENET-02-CF-P-70	5/15/2025 7:14	5/30/2025 18:59	70355681043	Lead	<1.0	5	ug/L
GENET-02-CF-P-71	217 Classroom Sink Faucet	Lead	GENET-02-CF-P-71	5/15/2025 7:15	5/30/2025 19:03	70355681044	Lead	<1.0	5	ug/L
GENET-02-CF-P-72	216 Classroom Sink Faucet	Lead	GENET-02-CF-P-72	5/15/2025 7:17	5/30/2025 19:11	70355681045	Lead	<1.0	5	ug/L
GENET-02-DW-P-73	Fountain Outside 218 Water Fountain	Lead	GENET-02-DW-P-73	5/15/2025 7:18	5/30/2025 19:13	70355681046	Lead	3.5	5	ug/L
GENET-02-CF-P-74	218 Classroom Sink Faucet	Lead	GENET-02-CF-P-74	5/15/2025 7:22	5/30/2025 19:14	70355681047	Lead	4.7	5	ug/L
GENET-02-CF-P-76	220 Classroom Sink Faucet	Lead	GENET-02-CF-P-76	5/15/2025 7:21	5/30/2025 19:16	70355681048	Lead	<1.0	5	ug/L
GENET-02-DW-P-76	Fountain Outside 211 Water Fountain	Lead	GENET-02-DW-P-76	5/15/2025 7:11	5/30/2025 19:18	70355681049	Lead	1.6	5	ug/L
GENET-02-CF-P-78	209 Classroom Sink Faucet	Lead	GENET-02-CF-P-78	5/15/2025 7:10	5/30/2025 19:19	70355681050	Lead	<1.0	5	ug/L
GENET-02-CF-P-81	205 Classroom Sink Faucet	Lead	GENET-02-CF-P-82	5/15/2025 7:08	5/30/2025 19:21	70355681051	Lead	<1.0	5	ug/L
GENET-02-CF-P-82	203 Classroom Sink Faucet	Lead	GENET-02-CF-P-83	5/15/2025 7:06	5/30/2025 19:22	70355681052	Lead	<1.0	5	ug/L
GENET-02-CF-P-84	201 Classroom Sink Faucet	Lead	GENET-02-CF-P-84	5/15/2025 7:04	5/30/2025 19:27	70355681053	Lead	1	5	ug/L
GENET-02-CF-P-88	200 Classroom Sink Faucet	Lead	GENET-02-CF-P-88	5/15/2025 7:02	5/30/2025 19:29	70355681054	Lead	<1.0	5	ug/L
GENET-02-DW-P-89	DO Fountain - By 413 Water Fountain	Lead	GENET-02-DW-P-89	5/15/2025 6:59	5/30/2025 19:30	70355681055	Lead	9.3	5	ug/L
GENET-02-BF-P-90	DO GN Right 2nd Floor Bathroom Faucet	Lead	GENET-02-BF-P-90	5/15/2025 6:56	5/30/2025 19:32	70355681056	Lead	<1.0	5	ug/L
GENET-02-BF-P-91	DO GN Left 2nd Floor Bathroom Faucet	Lead	GENET-02-BF-P-91	5/15/2025 6:57	5/30/2025 19:33	70355681057	Lead	<1.0	5	ug/L