

PACE LABS											
Pace Labs address: 14 Walker Way, Albany, NY 12205											
District Name: East Greenbush CSD											
School Name: Howard L. Goff Middle School											
Street address: 35 Gilligan Rd, East Greenbush, NY 12061											
Sample ID	Goff Location	Analysis Required	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDO H Action Level	Units	
GOFF-01-BF-P-01	Girl's Room by 108 - far L	Lead	GOFF-01-BF-P-01	5/8/2025 5:13	5/28/2025 14:31	70354498001	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-03	Girl's Room by 108 - R Center	Lead	GOFF-01-BF-P-03	5/8/2025 5:15	5/28/2025 14:33	70354498002	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-04	Girl's Room by 108 - Far R Bathroom Faucet	Lead	GOFF-01-BF-P-04	5/8/2025 5:16	5/28/2025 14:34	70354498003	Lead	17.4	5	ug/L	
GOFF-01-DW-P-05	Bottle Filler by Bathrooms Bottle Filler	Lead	GOFF-01-DW-P-05	5/8/2025 5:17	5/28/2025 14:36	70354498004	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-06	Boy's Room - L Bathroom Faucet	Lead	GOFF-01-BF-P-06	5/8/2025 5:18	5/28/2025 14:37	70354498005	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-07	Boy's Room - C Bathroom Faucet	Lead	GOFF-01-BF-P-07	5/8/2025 5:19	5/28/2025 14:39	70354498006	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-08	Boy's Room - R Bathroom Faucet	Lead	GOFF-01-BF-P-08	5/8/2025 5:20	5/28/2025 14:40	70354498007	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-09	Guidance Suite Bathroom Faucet	Lead	GOFF-01-BF-P-09	5/8/2025 5:21	5/28/2025 14:42	70354498008	Lead	<1.0	5	ug/L	
GOFF-01-DW-P-10	Bottle Filler by C107 Bottle Filler	Lead	GOFF-01-DW-P-10	5/8/2025 5:22	5/28/2025 14:43	70354498009	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-11	Main Office Bathroom Bathroom Faucet	Lead	GOFF-01-BF-P-11	5/8/2025 5:26	5/28/2025 14:45	70354498010	Lead	<1.0	5	ug/L	
GOFF-01-SF-P-12	Main Office Break Room Sink Faucet	Lead	GOFF-01-SF-P-12	5/8/2025 5:27	5/28/2025 14:49	70354498011	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-17	Girl's Bathroom by Faculty Bathroom Faucet	Lead	GOFF-01-BF-P-17	5/8/2025 5:31	5/28/2025 14:51	70354498012	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-18	Boy's Bathroom Health Corridor - L Bathroom Faucet	Lead	GOFF-01-BF-P-18	5/8/2025 5:32	5/28/2025 14:52	70354498013	Lead	9.6	5	ug/L	
GOFF-01-BF-P-19	Boy's Bathroom Health Corridor -R Bathroom Faucet	Lead	GOFF-01-BF-P-19	5/8/2025 5:33	5/28/2025 14:57	70354498014	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-20	Health Office Bathroom Faucet	Lead	GOFF-01-BF-P-20	5/8/2025 5:34	5/28/2025 15:01	70354498015	Lead	<1.0	5	ug/L	
GOFF-01-SF-P-21	Health Office - Exam Room Sink Faucet	Lead	GOFF-01-SF-P-21	5/8/2025 5:35	5/28/2025 15:08	70354498016	Lead	<1.0	5	ug/L	
GOFF-01-KF-P-22	Kitchen - Handwashing - By Office Kitchen Faucet	Lead	GOFF-01-KF-P-22	5/8/2025 5:00	5/28/2025 15:10	70354498017	Lead	<1.0	5	ug/L	
GOFF-01-KF-P-23	Kitchen - Food Prep on Wall Kitchen Faucet	Lead	GOFF-01-KF-P-23	5/8/2025 5:01	5/28/2025 15:11	70354498018	Lead	1.5	5	ug/L	
GOFF-01-KF-P-24	Kitchen - Food Prep Center Kitchen Faucet	Lead	GOFF-01-KF-P-24	5/8/2025 5:02	5/28/2025 15:13	70354498019	Lead	<1.0	5	ug/L	
GOFF-01-KF-P-25	Kitchen - Tilt Skillet Kitchen Faucet	Lead	GOFF-01-KF-P-25	5/8/2025 5:03	5/28/2025 15:15	70354498020	Lead	<1.0	5	ug/L	
GOFF-01-KF-P-26	Kitchen - Kettle Kitchen Faucet	Lead	GOFF-01-KF-P-26	5/8/2025 5:04	5/28/2025 15:16	70354498021	Lead	3.2	5	ug/L	
GOFF-01-KF-P-27	Kitchen - Sink by Kettle Kitchen Faucet	Lead	GOFF-01-KF-P-27	5/8/2025 5:05	5/28/2025 15:17	70354498022	Lead	1.3	5	ug/L	
GOFF-01-KF-P-28	Kitchen - Steam Table - R Kitchen Faucet	Lead	GOFF-01-KF-P-28	5/8/2025 5:06	5/28/2025 15:19	70354498023	Lead	<1.0	5	ug/L	
GOFF-01-KF-P-29	Kitchen - Steam Table - L Kitchen Faucet	Lead	GOFF-01-KF-P-29	5/8/2025 5:07	5/28/2025 15:20	70354498024	Lead	<1.0	5	ug/L	
GOFF-01-KF-P-30	Kitchen - Handwashing by Dish Wash Area Kitchen Faucet	Lead	GOFF-01-KF-P-30	5/8/2025 5:08	5/28/2025 15:25	70354498025	Lead	<1.0	5	ug/L	
GOFF-01-KF-P-31	Kitchen Bathroom Bathroom Faucet	Lead	GOFF-01-KF-P-31	5/8/2025 5:09	5/28/2025 15:26	70354498026	Lead	<1.0	5	ug/L	
GOFF-01-SF-P-32	Girl's Coaches Office Sink Faucet	Lead	GOFF-01-SF-P-32	5/8/2025 5:40	5/28/2025 15:28	70354498027	Lead	1.4	5	ug/L	
GOFF-01-BF-P-33	Girl's Locker Bathroom - L Bathroom Faucet	Lead	GOFF-01-BF-P-33	5/8/2025 5:41	5/28/2025 15:29	70354498028	Lead	2.9	5	ug/L	
GOFF-01-BF-P-34	Girl's Locker Bathroom - R Bathroom Faucet	Lead	GOFF-01-BF-P-34	5/8/2025 5:42	5/28/2025 15:31	70354498029	Lead	1.2	5	ug/L	
GOFF-01-BF-P-35	Boy's Locker Bathroom Bathroom Faucet	Lead	GOFF-01-BF-P-35	5/8/2025 5:43	5/28/2025 15:32	70354498030	Lead	1.9	5	ug/L	
GOFF-01-BF-P-36	Boy's Coaches Office Bathroom Faucet	Lead	GOFF-01-BF-P-36	5/8/2025 5:44	5/28/2025 15:34	70354498031	Lead	4	5	ug/L	
GOFF-01-BF-P-37	142 - L Classroom Sink Faucet	Lead	GOFF-01-BF-P-37	5/8/2025 5:57	5/28/2025 15:35	70354498032	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-38	142 - R Classroom Sink Faucet	Lead	GOFF-01-BF-P-38	5/8/2025 5:55	5/28/2025 15:37	70354498033	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-39	146 - L Classroom Sink Faucet	Lead	GOFF-01-BF-P-39	5/8/2025 5:52	5/28/2025 15:44	70354498034	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-40	146 - C Classroom Sink Faucet	Lead	GOFF-01-BF-P-40	5/8/2025 5:53	5/28/2025 15:48	70354498035	Lead	<1.0	5	ug/L	
GOFF-01-BF-P-41	146 - R Classroom Sink Faucet	Lead	GOFF-01-BF-P-41	5/8/2025 5:54	5/28/2025 15:53	70354498036	Lead	<1.0	5	ug/L	

GOFF-01-CF-P-42	151 - Music - L Classroom Sink Faucet	Lead	GOFF-01-CF-P-42	5/8/2025 5:55	5/28/2025 15:54	70354498037	Lead	<1.0	5	ug/L
GOFF-01-CF-P-43	151 - Music - R Classroom Sink Faucet	Lead	GOFF-01-CF-P-43	5/8/2025 5:56	5/28/2025 15:56	70354498038	Lead	<1.0	5	ug/L
GOFF-01-BF-P-44	Taylor Girl's Room - Far L Bathroom Faucet	Lead	GOFF-01-BF-P-44	5/8/2025 5:57	5/28/2025 16:00	70354498039	Lead	1.1	5	ug/L
GOFF-01-BF-P-45	Taylor Girl's Room - L Center Bathroom Faucet	Lead	GOFF-01-BF-P-45	5/8/2025 5:58	5/28/2025 16:02	70354498040	Lead	1.3	5	ug/L
GOFF-01-BF-P-46	Taylor Girl's Room - R Center Bathroom Faucet	Lead	GOFF-01-BF-P-46	5/8/2025 5:59	5/28/2025 16:03	70354498041	Lead	1.3	5	ug/L
GOFF-01-BF-P-47	Taylor Girl's Room - Far R Bathroom Faucet	Lead	GOFF-01-BF-P-47	5/8/2025 6:00	5/28/2025 16:05	70354498042	Lead	1.4	5	ug/L
GOFF-01-DW-P-48	Bottle Filler by Bathrooms in Taylor	Lead	GOFF-01-DW-P-48	5/8/2025 6:01	5/28/2025 16:06	70354498043	Lead	<1.0	5	ug/L
GOFF-01-BF-P-49	Taylor Boy's Room - Far L Bathroom Faucet	Lead	GOFF-01-BF-P-49	5/8/2025 6:03	5/28/2025 16:08	70354498044	Lead	2.6	5	ug/L
GOFF-01-BF-P-50	Taylor Boy's Room - L Center Bathroom Faucet	Lead	GOFF-01-BF-P-50	5/8/2025 6:04	5/28/2025 16:09	70354498045	Lead	<1.0	5	ug/L
GOFF-01-BF-P-51	Taylor Boy's Room - R Center Bathroom Faucet	Lead	GOFF-01-BF-P-51	5/8/2025 6:05	5/28/2025 16:11	70354498046	Lead	<1.0	5	ug/L
GOFF-01-BF-P-52	Taylor Boy's Room - Far R Bathroom Faucet	Lead	GOFF-01-BF-P-52	5/8/2025 6:06	5/28/2025 16:12	70354498047	Lead	2.2	5	ug/L
GOFF-01-BF-P-53	Taylor 2nd Fl Boys - L Bathroom Faucet	Lead	GOFF-01-BF-P-53	5/8/2025 6:13	5/28/2025 16:14	70354498048	Lead	<1.0	5	ug/L
GOFF-01-BF-P-54	Taylor 2nd Fl Boys - L Center Bathroom Faucet	Lead	GOFF-01-BF-P-54	5/8/2025 6:14	5/28/2025 16:18	70354498049	Lead	1.6	5	ug/L
GOFF-01-BF-P-55	Taylor 2nd Fl Boys - R Center Bathroom Faucet	Lead	GOFF-01-BF-P-55	5/8/2025 6:15	5/28/2025 16:19	70354498050	Lead	<1.0	5	ug/L
GOFF-01-BF-P-56	Taylor 2nd Fl Boys - R Bathroom Faucet	Lead	GOFF-01-BF-P-56	5/8/2025 6:16	5/28/2025 16:21	70354498051	Lead	10	5	ug/L
GOFF-01-BF-P-57	Taylor Office Bathroom Faucet	Lead	GOFF-01-BF-P-57	5/8/2025 6:07	5/28/2025 16:22	70354498052	Lead	<1.0	5	ug/L
GOFF-01-BF-P-58	Taylor 2nd Fl Girls - Far L Bathroom Faucet	Lead	GOFF-01-BF-P-58	5/8/2025 6:11	5/28/2025 16:24	70354498053	Lead	3.1	5	ug/L
GOFF-01-BF-P-59	Taylor 2nd Fl Girls - L Center Bathroom Faucet	Lead	GOFF-01-BF-P-59	5/8/2025 6:10	5/28/2025 16:28	70354498054	Lead	2	5	ug/L
GOFF-01-BF-P-60	Taylor 2nd Fl Girls - R Center Bathroom Faucet	Lead	GOFF-01-BF-P-60	5/8/2025 6:09	5/28/2025 16:36	70354498055	Lead	<1.0	5	ug/L
GOFF-01-BF-P-61	Taylor 2nd Fl Girls - Far R Bathroom Faucet	Lead	GOFF-01-BF-P-61	5/8/2025 6:08	5/28/2025 16:40	70354498056	Lead	13.8	5	ug/L
GOFF-01-BF-P-62	Red Girl's Room - Far L Bathroom Faucet	Lead	GOFF-01-BF-P-62	5/8/2025 6:18	5/28/2025 16:42	70354498057	Lead	<1.0	5	ug/L
GOFF-01-BF-P-63	Red Girl's Room - L Center Bathroom Faucet	Lead	GOFF-01-BF-P-63	5/8/2025 6:19	5/28/2025 16:43	70354498058	Lead	<1.0	5	ug/L
GOFF-01-BF-P-64	Red Girl's Room - R Center Bathroom Faucet	Lead	GOFF-01-BF-P-64	5/8/2025 6:21	5/28/2025 16:45	70354498059	Lead	<1.0	5	ug/L
GOFF-01-BF-P-65	Red Girl's Room - Far R Bathroom Faucet	Lead	GOFF-01-BF-P-65	5/8/2025 6:20	5/28/2025 16:46	70354498060	Lead	<1.0	5	ug/L
GOFF-01-BF-P-66	Red Boy's Room - Far L Bathroom Faucet	Lead	GOFF-01-BF-P-66	5/8/2025 6:22	5/28/2025 16:48	70354498061	Lead	3.4	5	ug/L
GOFF-01-BF-P-68	Red Boy's Room - R Center Bathroom Faucet	Lead	GOFF-01-BF-P-68	5/8/2025 6:24	5/28/2025 16:49	70354498062	Lead	<1.0	5	ug/L
GOFF-01-BF-P-69	Red Boy's Room - Far R Bathroom Faucet	Lead	GOFF-01-BF-P-69	5/8/2025 6:23	5/28/2025 16:53	70354498063	Lead	<1.0	5	ug/L
GOFF-01-BF-P-70	Red House Office Bathroom Faucet	Lead	GOFF-01-BF-P-70	5/8/2025 6:27	5/28/2025 16:55	70354498064	Lead	<1.0	5	ug/L
GOFF-01-DW-P-71	Bottle Filler Red House Bottle Filler	Lead	GOFF-01-DW-P-71	5/8/2025 6:25	5/28/2025 16:56	70354498065	Lead	<1.0	5	ug/L
GOFF-02-BF-P-72	Red 2nd Floor Boys - Far L Bathroom Faucet	Lead	GOFF-02-BF-P-72	5/8/2025 6:29	5/28/2025 16:58	70354498066	Lead	<1.0	5	ug/L
GOFF-02-BF-P-73	Red 2nd Floor Boys - L Center Bathroom Faucet	Lead	GOFF-02-BF-P-73	5/8/2025 6:28	5/28/2025 16:59	70354498067	Lead	2.4	5	ug/L
GOFF-02-BF-P-74	Red 2nd Floor Boys - R Center Bathroom Faucet	Lead	GOFF-02-BF-P-74	5/8/2025 6:31	5/28/2025 17:01	70354498068	Lead	1.3	5	ug/L
GOFF-02-BF-P-75	Red 2nd Floor Boys - Far R Bathroom Faucet	Lead	GOFF-02-BF-P-75	5/8/2025 6:30	5/28/2025 17:02	70354498069	Lead	<1.0	5	ug/L
GOFF-02-BF-P-77	Red 2nd Floor Girls - L Center Bathroom Faucet	Lead	GOFF-02-BF-P-77	5/8/2025 6:32	5/28/2025 17:04	70354498070	Lead	<1.0	5	ug/L
GOFF-02-BF-P-79	Red 2nd Floor Girls - Far R Bathroom Faucet	Lead	GOFF-02-BF-P-79	5/8/2025 6:33	5/28/2025 17:05	70354498071	Lead	<1.0	5	ug/L
GOFF-02-CF-P-80	219 Left Side - L Classroom Faucet	Lead	GOFF-02-CF-P-80	5/8/2025 6:41	5/28/2025 17:07	70354498072	Lead	<1.0	5	ug/L
GOFF-02-CF-P-81	219 Left Side - R Classroom Faucet	Lead	GOFF-02-CF-P-81	5/8/2025 6:40	5/28/2025 17:11	70354498073	Lead	<1.0	5	ug/L
GOFF-02-CF-P-82	219 Right Side - L Classroom Faucet	Lead	GOFF-02-CF-P-82	5/8/2025 6:39	5/28/2025 17:15	70354498074	Lead	<1.0	5	ug/L
GOFF-02-CF-P-83	219 Right Side - C Classroom Faucet	Lead	GOFF-02-CF-P-83	5/8/2025 6:42	5/28/2025 17:20	70354498075	Lead	<1.0	5	ug/L
GOFF-02-CF-P-84	219 Right Side - R Classroom Faucet	Lead	GOFF-02-CF-P-84	5/8/2025 6:38	5/28/2025 17:24	70354498076	Lead	<1.0	5	ug/L
GOFF-02-DW-P-85	Bottle Filler by 219 Bottle Filler	Lead	GOFF-02-DW-P-85	5/8/2025 6:43	5/28/2025 17:28	70354498077	Lead	<1.0	5	ug/L
GOFF-02-BF-P-86	Boy's Room by 208 - L Bathroom Faucet	Lead	GOFF-02-BF-P-86	5/8/2025 6:48	5/28/2025 17:30	70354498078	Lead	<1.0	5	ug/L
GOFF-02-BF-P-87	Boy's Room by 208 - C Bathroom Faucet	Lead	GOFF-02-BF-P-87	5/8/2025 6:47	5/28/2025 17:31	70354498079	Lead	<1.0	5	ug/L
GOFF-02-BF-P-88	Boy's Room by 208 - R Bathroom Faucet	Lead	GOFF-02-BF-P-88	5/8/2025 6:48	5/28/2025 17:33	70354498080	Lead	<1.0	5	ug/L
GOFF-02-DW-P-89	Bottle Filler by Bathrooms Bottle Filler	Lead	GOFF-02-DW-P-89	5/8/2025 6:45	5/28/2025 17:34	70354498081	Lead	<1.0	5	ug/L

GOFF-02-BF-P-91	Girl's Room by 208 - L Center Bathroom Faucet	Lead	GOFF-02-BF-P-91	5/8/2025 6:50	5/28/2025 17:36	70354498082	Lead	<1.0	5	ug/L
GOFF-02-BF-P-93	Girl's Room by 208 - Far R Bathroom Faucet	Lead	GOFF-02-BF-P-93	5/8/2025 6:59	5/28/2025 17:37	70354498083	Lead	1.3	5	ug/L
GOFF-02-IM-P-94	Maintenance Area Ice Machine Ice Machine	Lead	GOFF-02-IM-P-94	5/8/2025 7:05	5/28/2025 17:39	70354498084	Lead	<1.0	5	ug/L
GOFF-02-DW-P-95	Bottle Filler Red House with #71	Lead	GOFF-02-DW-P-95	5/8/2025 6:26	5/28/2025 17:40	70354498085	Lead	<1.0	5	ug/L
GOFF-02-DW-P-96	Water Fountain by Bathrooms in Taylor with #48 Bottle Filler	Lead	GOFF-02-DW-P-96	5/8/2025 6:02	5/28/2025 17:42	70354498086	Lead	<1.0	5	ug/L
GOFF-02-DW-P-97	Water fountain by 219 with #85 Bottle Filler	Lead	GOFF-02-DW-P-97	5/8/2025 6:46	5/28/2025 17:46	70354498087	Lead	<1.0	5	ug/L
GOFF-02-DW-P-98	Water fountain across from 264	Lead	GOFF-02-DW-P-98	5/8/2025 6:12	5/28/2025 17:48	70354498088	Lead	<1.0	5	ug/L
GOFF-02-DW-P-99	Cafeteria Water fountain	Lead	GOFF-02-DW-P-99	5/8/2025 5:37	5/28/2025 17:49	70354498089	Lead	<1.0	5	ug/L
GOFF-02-DW-P-100	Cafeteria Bottle filler	Lead	GOFF-02-DW-P-100	5/8/2025 5:38	5/28/2025 17:50	70354498090	Lead	<1.0	5	ug/L
GOFF-02-DW-P-101	Water Fountain Green House	Lead	GOFF-02-DW-P-101	5/8/2025 5:25	5/28/2025 17:52	70354498091	Lead	<1.0	5	ug/L
GOFF-02-DW-P-102	Water Fountain by 195	Lead	GOFF-02-DW-P-102	5/8/2025 5:39	5/28/2025 17:53	70354498092	Lead	<1.0	5	ug/L
GOFF-02-DW-P-103	Water Fountain by Gym	Lead	GOFF-02-DW-P-103	5/8/2025 5:46	5/28/2025 17:55	70354498093	Lead	<1.0	5	ug/L
GOFF-02-SF-P-104	Library	Lead	GOFF-02-SF-P-104	5/8/2025 7:08	5/29/2025 15:04	70354498094	Lead	1.1	5	ug/L
GOFF-02-CF-P-105	211 Classroom sink faucet	Lead	GOFF-02-CF-P-105	5/8/2025 7:06	5/29/2025 15:08	70354498095	Lead	<1.0	5	ug/L
GOFF-02-CF-P-106	Rm 142 with #37 and #38 new fixture	Lead	GOFF-02-CF-P-106	5/8/2025 5:56	5/29/2025 15:12	70354498096	Lead	<1.0	5	ug/L
GOFF-02-DW-P-107	Water Fountain by Music	Lead	GOFF-02-DW-P-107	5/8/2025 5:57	5/29/2025 15:14	70354498097	Lead	1.6	5	ug/L
GOFF-02-DW-P-108	Water Fountain by C107	Lead	GOFF-02-DW-P-108	5/8/2025 5:24	5/29/2025 15:16	70354498098	Lead	<1.0	5	ug/L