

PACE LABS										
Pace Labs address: 14 Walker Way, Albany, NY 12205										
District Name: East Greenbush CSD										
School Name: Red Mill Elementary School										
Street address: 225 McCullough Pl, Rensselaer, NY 12144										
Sample ID	Red Mill Location	Analysis Required	Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDO H Action Level	Units
RM-02-DW-P-01	Main Entrance Fountain - L Water Fountain	Lead	RM-02-DW-P-01	5/7/2025 5:05	5/29/2025 14:00	70354829001	Lead	<1.0	5	ug/L
RM-02-DW-P-02	Main Entrance Fountain - R Water Fountain	Lead	RM-02-DW-P-02	5/7/2025 5:06	5/29/2025 14:02	70354829002	Lead	<1.0	5	ug/L
RM-02-SF-P-03	Main Office Copy Room Sink Faucet	Lead	RM-02-SF-P-03	5/7/2025 5:07	5/29/2025 14:07	70354829003	Lead	<1.0	5	ug/L
RM-02-SF-P-04	143 - Food Lab Classroom Sink Faucet	Lead	RM-02-SF-P-04	5/7/2025 6:08	5/29/2025 14:08	70354829004	Lead	2.2	5	ug/L
RM-02-BF-P-05	8 Bathroom Faucet	Lead	RM-02-BF-P-05	5/7/2025 6:06	5/29/2025 14:10	70354829005	Lead	<1.0	5	ug/L
RM-02-SF-P-06	8 Classroom Sink Faucet	Lead	RM-02-SF-P-06	5/7/2025 6:07	5/29/2025 14:14	70354829006	Lead	<1.0	5	ug/L
RM-02-BF-P-07	6 Bathroom Faucet	Lead	RM-02-BF-P-07	5/7/2025 6:04	5/29/2025 14:19	70354829007	Lead	<1.0	5	ug/L
RM-02-SF-P-08	6 Classroom Sink Faucet	Lead	RM-02-SF-P-08	5/7/2025 6:05	5/29/2025 14:26	70354829008	Lead	<1.0	5	ug/L
RM-02-BF-P-09	4 Bathroom Faucet	Lead	RM-02-BF-P-09	5/7/2025 6:02	5/29/2025 14:28	70354829009	Lead	<1.0	5	ug/L
RM-02-SF-P-10	4 Classroom Sink Faucet	Lead	RM-02-SF-P-10	5/7/2025 6:03	5/29/2025 14:29	70354829010	Lead	<1.0	5	ug/L
RM-02-SF-P-11	3 - Outside Bathroom Classroom Sink Faucet	Lead	RM-02-SF-P-11	5/7/2025 6:00	5/29/2025 14:31	70354829011	Lead	<1.0	5	ug/L
RM-02-SF-P-12	3 Classroom Sink Faucet	Lead	RM-02-SF-P-12	5/7/2025 6:01	5/29/2025 14:32	70354829012	Lead	<1.0	5	ug/L
RM-02-BF-P-13	2 Bathroom Faucet	Lead	RM-02-BF-P-13	5/7/2025 5:53	5/29/2025 14:34	70354829013	Lead	<1.0	5	ug/L
RM-02-SF-P-14	2 Water Fountain	Lead	RM-02-SF-P-14	5/7/2025 5:54	5/29/2025 14:36	70354829014	Lead	<1.0	5	ug/L
RM-02-SF-P-15	2 Classroom Sink Faucet	Lead	RM-02-SF-P-15	5/7/2025 5:55	5/29/2025 14:37	70354829015	Lead	<1.0	5	ug/L
RM-02-BF-P-16	1 Bathroom Faucet	Lead	RM-02-BF-P-16	5/7/2025 5:50	5/29/2025 14:39	70354829016	Lead	<1.0	5	ug/L
RM-02-SF-P-17	1 Water Fountain	Lead	RM-02-SF-P-17	5/7/2025 5:51	5/29/2025 14:43	70354829017	Lead	<1.0	5	ug/L
RM-02-SF-P-18	1 Classroom Sink Faucet	Lead	RM-02-SF-P-18	5/7/2025 5:52	5/29/2025 14:45	70354829018	Lead	<1.0	5	ug/L
RM-02-BF-P-19	5 Bathroom Faucet	Lead	RM-02-BF-P-19	5/7/2025 5:48	5/29/2025 14:47	70354829019	Lead	<1.0	5	ug/L
RM-02-SF-P-20	5 Classroom Sink Faucet	Lead	RM-02-SF-P-20	5/7/2025 5:49	5/29/2025 14:48	70354829020	Lead	<1.0	5	ug/L
RM-02-BF-P-21	7 Bathroom Faucet	Lead	RM-02-BF-P-21	5/7/2025 5:46	5/29/2025 14:50	70354829021	Lead	<1.0	5	ug/L
RM-02-SF-P-22	7 Classroom Sink Faucet	Lead	RM-02-SF-P-22	5/7/2025 5:47	5/29/2025 14:51	70354829022	Lead	<1.0	5	ug/L
RM-02-BF-P-23	9 Bathroom Faucet	Lead	RM-02-BF-P-23	5/7/2025 5:44	5/29/2025 14:53	70354829023	Lead	<1.0	5	ug/L
RM-02-SF-P-24	9 Classroom Sink Faucet	Lead	RM-02-SF-P-24	5/7/2025 5:43	5/29/2025 14:55	70354829024	Lead	<1.0	5	ug/L
RM-02-BF-P-25	140 - Health Office Bathroom Faucet	Lead	RM-02-BF-P-25	5/7/2025 5:41	5/29/2025 14:56	70354829025	Lead	1.2	5	ug/L
RM-02-SF-P-26	140 - Health Office Sink Faucet	Lead	RM-02-SF-P-26	5/7/2025 5:42	5/29/2025 16:23	70354829026	Lead	<1.0	5	ug/L
RM-02-BF-P-27	Women's room main hall bathroom faucet	Lead	RM-02-BF-P-27	5/7/2025 5:35	5/29/2025 16:27	70354829027	Lead	<1.0	5	ug/L
RM-02-BF-P-28	106 - Old Custodial Office Bathroom Faucet	Lead	RM-02-BF-P-28	5/7/2025 5:37	5/29/2025 16:42	70354829028	Lead	1.2	5	ug/L
RM-02-BF-P-29	Boy's Room by 120 - L Bathroom Faucet	Lead	RM-02-BF-P-29	5/7/2025 5:39	5/29/2025 16:44	70354829029	Lead	<1.0	5	ug/L
RM-02-BF-P-30	Boy's Room by 120 - R Bathroom Faucet	Lead	RM-02-BF-P-30	5/7/2025 5:40	5/29/2025 16:45	70354829030	Lead	<1.0	5	ug/L
RM-02-BF-P-31	Girl's Room by 120 - L Bathroom Faucet	Lead	RM-02-BF-P-31	5/7/2025 5:37	5/29/2025 16:47	70354829031	Lead	<1.0	5	ug/L
RM-02-BF-P-32	Girl's Room by 120 - R Bathroom Faucet	Lead	RM-02-BF-P-32	5/7/2025 5:38	5/29/2025 16:49	70354829032	Lead	<1.0	5	ug/L
RM-02-SF-P-33	12 music- By door - L Classroom Sink Faucet	Lead	RM-02-SF-P-33	5/7/2025 5:34	5/29/2025 16:53	70354829033	Lead	2.1	5	ug/L
RM-02-SF-P-34	12 music - R Classroom Sink Faucet	Lead	RM-02-SF-P-34	5/7/2025 5:35	5/29/2025 16:55	70354829034	Lead	3.7	5	ug/L
RM-02-SF-P-35	13 Classroom Sink Faucet	Lead	RM-02-SF-P-35	5/7/2025 5:13	5/29/2025 16:56	70354829035	Lead	1.2	5	ug/L

RM-02-SF-P-36	222 - Girl's Locker Sink Faucet	Lead	RM-02-SF-P-36	5/7/2025 7:07	5/29/2025 16:58	70354829036	Lead	1.7	5	ug/L
RM-02-SF-P-37	221 Men's Locker Sink Faucet	Lead	RM-02-SF-P-37	5/7/2025 7:06	5/29/2025 17:00	70354829037	Lead	<1.0	5	ug/L
RM-02-DW-P-38	Gym Fountains - L Water Fountain	Lead	RM-02-DW-P-38	5/7/2025 7:04	5/29/2025 17:01	70354829038	Lead	<1.0	5	ug/L
RM-02-DW-P-39	Gym Bottle Filler Bottle Filler	Lead	RM-02-DW-P-39	5/7/2025 7:05	5/29/2025 17:03	70354829039	Lead	<1.0	5	ug/L
RM-02-SF-P-40	Kitchen - Handwashing by door Kitchen Faucet	Lead	RM-02-SF-P-40	5/7/2025 5:12	5/29/2025 17:04	70354829040	Lead	1.2	5	ug/L
RM-02-SF-P-41	Kitchen - Steam Table Kitchen Faucet	Lead	RM-02-SF-P-41	5/7/2025 5:11	5/29/2025 17:06	70354829041	Lead	<1.0	5	ug/L
RM-02-SF-P-42	Kitchen - Food Prep by stove Kitchen Faucet	Lead	RM-02-SF-P-42	5/7/2025 5:10	5/29/2025 17:08	70354829042	Lead	<1.0	5	ug/L
RM-02-SF-P-44	106 - Faculty Room Sink Faucet	Lead	RM-02-SF-P-44	5/7/2025 6:11	5/29/2025 17:12	70354829043	Lead	<1.0	5	ug/L
RM-02-BF-P-45	Gender Neutral L Bathroom Faucet	Lead	RM-02-BF-P-45	5/7/2025 6:12	5/29/2025 17:14	70354829044	Lead	<1.0	5	ug/L
RM-02-BF-P-46	Gender Neutral R Bathroom Faucet	Lead	RM-02-BF-P-46	5/7/2025 6:13	5/29/2025 17:16	70354829045	Lead	<1.0	5	ug/L
RM-02-SF-P-47	Library Office Prep Sink Faucet	Lead	RM-02-SF-P-47	5/7/2025 6:29	5/29/2025 17:20	70354829046	Lead	1.6	5	ug/L
RM-02-SF-P-48	Library by Desk Sink Faucet	Lead	RM-02-SF-P-48	5/7/2025 6:30	5/29/2025 17:25	70354829047	Lead	2.9	5	ug/L
RM-02-SF-P-49	21 Classroom Sink Faucet	Lead	RM-02-SF-P-49	5/7/2025 6:28	5/29/2025 17:32	70354829048	Lead	2	5	ug/L
RM-02-SF-P-51	20 Classroom Sink Faucet	Lead	RM-02-SF-P-51	5/7/2025 6:25	5/29/2025 17:34	70354829049	Lead	3.7	5	ug/L
RM-02-BF-P-52	20 Bathroom Faucet	Lead	RM-02-BF-P-52	5/7/2025 6:26	5/29/2025 17:35	70354829050	Lead	<1.0	5	ug/L
RM-02-BF-P-53	19 Bathroom Faucet	Lead	RM-02-BF-P-53	5/7/2025 6:24	5/29/2025 17:37	70354829051	Lead	<1.0	5	ug/L
RM-02-SF-P-54	19 Classroom Sink Faucet	Lead	RM-02-SF-P-54	5/7/2025 6:23	5/29/2025 17:38	70354829052	Lead	<1.0	5	ug/L
RM-02-SF-P-55	18 Classroom Sink Faucet	Lead	RM-02-SF-P-55	5/7/2025 6:22	5/29/2025 17:40	70354829053	Lead	<1.0	5	ug/L
RM-02-SF-P-56	17A Classroom Sink Faucet	Lead	RM-02-SF-P-56	5/7/2025 6:21	5/29/2025 17:42	70354829054	Lead	1.1	5	ug/L
RM-02-SF-P-57	16 Classroom Sink Faucet	Lead	RM-02-SF-P-57	5/7/2025 6:19	5/29/2025 17:43	70354829055	Lead	<1.0	5	ug/L
RM-02-SF-P-58	15 Classroom Sink Faucet	Lead	RM-02-SF-P-58	5/7/2025 6:18	5/29/2025 17:45	70354829056	Lead	<1.0	5	ug/L
RM-02-SF-P-59	14 Classroom Sink Faucet	Lead	RM-02-SF-P-59	5/7/2025 6:17	5/29/2025 17:49	70354829057	Lead	<1.0	5	ug/L
RM-02-SF-P-60	34 Classroom Sink Faucet	Lead	RM-02-SF-P-60	5/7/2025 6:37	5/29/2025 17:51	70354829058	Lead	<1.0	5	ug/L
RM-02-DW-P-61	34 Water Fountain	Lead	RM-02-DW-P-61	5/7/2025 6:38	5/29/2025 17:53	70354829059	Lead	1.5	5	ug/L
RM-02-SF-P-62	33 Classroom Sink Faucet	Lead	RM-02-SF-P-62	5/7/2025 6:40	5/29/2025 17:54	70354829060	Lead	<1.0	5	ug/L
RM-02-SF-P-63	32 Classroom Sink Faucet	Lead	RM-02-SF-P-63	5/7/2025 6:41	5/29/2025 17:56	70354829061	Lead	<1.0	5	ug/L
RM-02-SF-P-64	Fountain Outside 31 Water Fountain	Lead	RM-02-SF-P-64	5/7/2025 6:42	5/29/2025 17:57	70354829062	Lead	<1.0	5	ug/L
RM-02-SF-P-65	31 Classroom Sink Faucet	Lead	RM-02-SF-P-65	5/7/2025 6:43	5/29/2025 17:59	70354829063	Lead	<1.0	5	ug/L
RM-02-SF-P-66	30 Classroom Sink Faucet	Lead	RM-02-SF-P-66	5/7/2025 6:44	5/29/2025 18:01	70354829064	Lead	<1.0	5	ug/L
RM-02-BF-P-67	Girl's Room - L Bathroom Faucet	Lead	RM-02-BF-P-67	5/7/2025 6:46	5/29/2025 18:02	70354829065	Lead	<1.0	5	ug/L
RM-02-BF-P-68	Girl's Room - R Bathroom Faucet	Lead	RM-02-BF-P-68	5/7/2025 6:48	5/29/2025 18:10	70354829066	Lead	<1.0	5	ug/L
RM-02-BF-P-69	Boy's Room - L Bathroom Faucet	Lead	RM-02-BF-P-69	5/7/2025 6:49	5/29/2025 18:14	70354829067	Lead	<1.0	5	ug/L
RM-02-BF-P-70	Boy's Room - R Bathroom Faucet	Lead	RM-02-BF-P-70	5/7/2025 6:50	5/29/2025 18:19	70354829068	Lead	<1.0	5	ug/L
RM-02-SF-P-71	29A OT/PT Classroom Sink Faucet	Lead	RM-02-SF-P-71	5/7/2025 6:51	5/29/2025 18:20	70354829069	Lead	3.5	5	ug/L
RM-02-SF-P-72	28 Classroom Sink Faucet	Lead	RM-02-SF-P-72	5/7/2025 6:52	5/29/2025 18:22	70354829070	Lead	1	5	ug/L
RM-02-DW-P-73	28 Water Fountain	Lead	RM-02-DW-P-73	5/7/2025 6:53	5/29/2025 18:27	70354829071	Lead	<1.0	5	ug/L
RM-02-SF-P-74	27 Classroom Sink Faucet	Lead	RM-02-SF-P-74	5/7/2025 6:54	5/29/2025 18:28	70354829072	Lead	<1.0	5	ug/L
RM-02-SF-P-75	26 Classroom Sink Faucet	Lead	RM-02-SF-P-75	5/7/2025 6:55	5/29/2025 18:30	70354829073	Lead	<1.0	5	ug/L
RM-02-SF-P-76	25 Classroom Sink Faucet	Lead	RM-02-SF-P-76	5/7/2025 6:56	5/29/2025 18:31	70354829074	Lead	2.4	5	ug/L
RM-02-DW-P-77	Fountain Outside 25 Water Fountain	Lead	RM-02-DW-P-77	5/7/2025 6:59	5/29/2025 18:33	70354829075	Lead	<1.0	5	ug/L
RM-02-SF-P-78	24 Classroom Sink Faucet	Lead	RM-02-SF-P-78	5/7/2025 7:00	5/29/2025 18:35	70354829076	Lead	<1.0	5	ug/L
RM-02-SF-P-79	Kitchen - Multiuse Sink - L Kitchen Faucet	Lead	RM-02-SF-P-79	5/7/2025 5:08	5/29/2025 18:36	70354829077	Lead	<1.0	5	ug/L
RM-02-SF-P-80	Kitchen - Multiuse Sink - R Kitchen Faucet	Lead	RM-02-SF-P-80	5/7/2025 5:09	5/29/2025 18:38	70354829078	Lead	<1.0	5	ug/L
RM-02-BF-P-83	2nd Floor Boy's Bathroom by Room 14 - R Bathroom Faucet	Lead	RM-02-BF-P-83	5/7/2025 7:16	5/29/2025 18:39	70354829079	Lead	<1.0	5	ug/L

RM-02-BF-P-84	2nd Floor Boy's Bathroom by Room 14 - C Bathroom Faucet	Lead	RM-02-BF-P-84	5/7/2025 7:17	5/29/2025 18:41	70354829080	Lead	<1.0	5	ug/L
---------------	---	------	---------------	---------------	-----------------	-------------	------	------	---	------